

CO₂ Mitigation for a Network of Power Plants Using Mathematical Programming

Haslenda Hashim^{1*}, Peter Douglas², Eric Croiset², Ali Elkamel²

¹Faculty of Chemical and Natural Resources Engineering,
Universiti Teknologi Malaysia, 81310 UTM Skudai, Johor, Malaysia.

²Department of Chemical Engineering, University of Waterloo, Waterloo, Ontario, Canada N2L 3G1.

Abstract

This paper presents a case study focusing on the structural optimization of Ontario Power Generation, OPG's fleet of power plants to meet a given CO₂ reduction target by minimizing the cost of electricity (COE). The optimization takes into account the possible implementation of carbon capture and storage (CCS) and the possibility of constructing new power plants, with or without CCS, to maintain or increase electricity to the grid depending on the growth in electricity demand. The model is formulated as Mixed Integer Non Linear Programme (MINLP) and implemented in GAMS (General Algebraic Modeling System). Exact linearization techniques were employed to facilitate solution development. Three mitigation options were considered in this study: fuel balancing (optimal adjustment of the operation of existing generating stations to reduce CO₂ emissions without making structural changes to the fleet), fuel switching (switching from carbon intensive fuel to less carbon intensive fuel, e.g. coal to natural gas) and retrofitting CCS on existing coal fired power plants. Both, fuel switching and retrofitting CCS involve structural changes on the existing fleet. The computer programme is capable of determining the best mix of fuel, annual capacity factor for existing power plants, location and size of CO₂ capture process and finally, construction of new state-of-the-art power plants, such as supercritical pulverized coal (PC), integrated gas combined cycle (IGCC) or natural gas combined cycle (NGCC) with and without CCS.

Keywords: Optimization, CO₂ emission, CO₂ mitigation, carbon capture and storage e(CCS)

1.0 Introduction

Canada signed The Kyoto Protocol, committing to reduce greenhouse gas (GHG) emissions that cause climate change by 6% compared to 1990 levels by 2012. In the year 2004, 20% of Canada's greenhouse gases, primary CO₂ emission was emitted from combustion of fossil fuel power plant. In Ontario, Ontario Power Generation (OPG) produces 75% of Ontario's electricity from mix of energy sources: coal accounts for 35% of OPG's electricity generating capacity, nuclear supplies 44%, hydroelectric 27%, and the remaining 10% is renewable energy. As a major electricity production in Ontario, OPG generated 115 TWh electricity and was emitted about 36.7 million tonne of CO₂ in 2003. There are several promising strategies to reduce the amount of CO₂ emitted from fossil fuels power plants. The potential approaches include: improves power plant efficiency, fuel balancing (decrease capacity factor for coal fuel power

* Corresponding author: Tel: 07-5535478, Fax No. 07-5581463, E-mail: hhashim@fkkksa.utm.my

plant, increase capacity factor for non fossil fuel power plant such as nuclear, hydroelectric and alternative energy), fuel switching (switching from carbon intensive fuels i.e. coal, to less carbon intensive fuels i.e. oil or natural gas), enhanced use of renewable energy (i.e. wind turbines, solar, biomass, fuel cells), and CCS. Fuel balancing is the optimal adjustment of the operation of generating stations to reduce CO₂ emissions without making structural changes to the fleet. On the other hand, fuel switching, which is switching from carbon intensive fuels to less carbon intensive fuels and CO₂ capture and sequestration involves structural changes to the fleet. Although fuel switching may be likely possible options, greater reduction of CO₂ from power plant flue gas in a short term is expected to be technically possible using CO₂ capture and sequestration. However, CCS would lead to a reduction in plant output due to energy supply for CO₂ capture process. In this paper, we will discuss 3 possible options to reduce CO₂ emission by a certain target while maintaining the electricity to the grid according to growth demand, this includes fuel balancing, fuel switching, and retrofitting CCS on existing fossil generating stations.

2.0 Methodology

2.1 Superstructure representation

Figure 1 shows a superstructure that represents all possible alternative configurations for producing the required electricity demand by the grid considering a CO₂ reduction target, fuel balancing or fuel switching, CO₂ capture process and sequestration technology containing a large number of feasible alternative configurations. C_i , NG_i , O_i , N_i , H_i and A_i represents existing coal, natural gas, oil, nuclear, hydroelectric and alternative energy power plants respectively. Hypothetical new power plants are represented by N_i^{new} , H_i^{new} , A_i^{new} , PC_i^{new} , NG_i^{new} , IG_i^{new} for nuclear, hydroelectric, alternative energy, PC, NGCC and IGCC with and without capture. $C-C_i$, $C-NG_i$, $C-O_i$, $C-N_i^{new}$, $C-H_i^{new}$, $C-A_i^{new}$, $C-PC_i^{new}$, $C-NG_i^{new}$, $C-IG_i^{new}$ represent possible CO₂ capture processes, and *Sequestration 1* and *2* represent the two potential locations




Figure 1 Generic superstructure

for sequestration in Ontario.

2.2 Model Formulation

The optimization problem to be studied in this paper can be formulated in words as: “for a given CO₂ reduction target, what is the best generating plant load distribution, mix of fuels and CO₂ capture and sequestration to meet electricity demand growth?” The objective of this study is to synthesize the OPG’s existing fleet, incorporating CCS on existing coal-fired power plants and constructing hypothetical new power plants with or without capture to meet a given CO₂ reduction target while maintaining or enhancing electricity to the grid at the minimum overall cost. The cost function includes: operating cost of electricity generation for the fleet of generating stations, retrofitting cost associated with fuel switching from coal to natural gas, retrofitting cost for carbon capture retrofit on existing coal-fired power plants and capital and operational cost for hypothetical new power plants and sequestration cost. Note that in the case of a fossil fuel already operating on gas ($j = I$), there is no retrofitting cost involved (i.e. $R_{ij} = 0$). The objective function is given by:

$$\underbrace{\sum_{i \in F} \sum_j C_{ij} E_{ij}}_{\text{operational cost for existing plants}} + \underbrace{\sum_{i \in NF} C_i^{NF} E_i}_{\text{operational cost for new non-fossil fuel plants}} + \underbrace{\sum_{i \in F^c} \sum_j R_{ij} X_{ij}}_{\text{retrofit cost}} + \underbrace{\sum_{i \in P^{new}} S_i^{new} E_i^{\max} y_i}_{\text{capital cost for new power plants}} + \underbrace{\sum_{i \in P^{new}} C_i^{new} E_i^{new}}_{\text{operational cost for new power plants}} \quad (1)$$

$$+ \underbrace{\sum_{i \in F^c} \sum_k S_{ik}^c z_{ik}}_{\text{capital and operational cost of carbon capture retrofit}} + \underbrace{\sum_{i \in F^c} \sum_k C_k^c E_{ik}}_{\text{operational cost for carbon capture}} + \underbrace{\sum_{i \in F^c \cup P^{new}} \sum_s C_{is}^{seq} \alpha_i \varepsilon_i w_{is}}_{\text{sequestration cost}}$$

where C_{ij} is the electricity generation cost per MWh if j^{th} fuel is used in i^{th} fossil-fuel boiler; C_i (C_i^{new}) is the electricity generation cost per MWh for i^{th} non-fossil-fuel power plant (i^{th} new hypothetical boiler); C_k^c is operational cost for k^{th} CO₂ capture process (\$/MWh); C_{is}^{seq} is sequestration cost from i^{th} boiler to s^{th} storage location (\$/tonne CO₂ captured); E_i (E_i^{new}) is the electricity generated (MWh/year) from i^{th} non-fossil-fuel power plant (i^{th} hypothetical boilers); E_{ij} is the electricity generated (MWh/year) from i^{th} fossil-fuel boilers when using j^{th} fuel; E_{ijk} is electricity required for k^{th} CO₂ capture process (MWh/year) incorporated in i^{th} coal-fired boiler which running with j^{th} fuel; R_{ij} is the retrofitting cost for switching i^{th} coal-fired boiler to j^{th} fuel (natural gas) express in US\$/year; S_i^{new} is capital cost for new power plant in \$/KW; S_{ik}^c is annualized capital cost for k^{th} capture process in \$/year; ε_{ik} is the fractional of CO₂ capture; X_{ij} is a binary variable that indicates fuel selection or whether the plant should be shut down for i^{th} fossil-fuel boiler; binary variable y_i is represents existence/non existence of i^{th} hypothetical new boiler; binary variable z_{ik} is introduced for the selection of k^{th} retrofit carbon capture on i^{th} existing coal-fired boiler; w_{is} is a binary variable that indicates the selection of s^{th} potential location for CO₂ sequestration; i is the set of existing fossil fuel boilers, non-fossil power plants and new hypothetical boilers with and without capture; j is the set of j^{th} fuel selection that consists of coal or natural gas; F is the set of fossil-fuel boilers including coal (F^c) and natural gas (F^{ng}); NF is the set of non-fossil-fuel power stations, including nuclear, hydroelectric, and wind turbine sources; and P^{new} is the set of hypothetical new boilers that includes pulverized coal, P^{PC} (P^{PCcap}), integrated gas combined cycle, P^{IGCC} ($P^{IGCCcap}$) and natural gas combined cycle, P^{NGCC} ($P^{NGCCcap}$) with and (without capture). Note that, in the case of non-fossil-fuel plants, no associated binary variables are defined, as the fuel type for these plants is known a priori.

The objective function represented by equation (1) is subjected to the following constraints:

a) Energy balance/demand satisfaction

The total electricity injected to the grid comes from existing non fossil power, from new hypothetical boilers (E_i^{NF}/E_i^{new}) and from fossil generating stations operating with j^{th} fuel, E_{ij} . The supplemental energy required, E_{ik} for CO₂ capture processes, however, results in an electricity reduction/power de-rate. Therefore, the net electricity generation for the whole fleet must be equal to or greater than the desired total electricity demand.

$$\left[\sum_{i \in NF} E_i^{NF} + \sum_{i \in P^{new}} E_i^{new} + \sum_{i \in F} \sum_j E_{ij} \right] - \sum_i \sum_k E_{ik} \geq \text{Demand} \quad (2)$$

b) Energy balance on capture process

CO₂ capture processes are energy intensive. In this study, the energy for CO₂ capture process is consider to be extracted from the steam cycle of the existing fossil power plant itself as written in equation (3):

$$E_{ik} = \sum_{i \in F^c} \sum_j E_{ij}' \quad \forall i \in F^c, \forall k \quad (3)$$

c) Capacity constraint on capture process

$$E_{ik} \leq z_{ik} E_k^{max} \quad \forall i \in F^c, \forall k \quad (4)$$

The parameter E_k^{max} represents the maximum supplemental energy required for k^{th} capture technologies. It also ensures that the energy required for any k^{th} capture process is zero when no capture process is assigned to the i^{th} coal-fired boilers. Note that capture process considered to be incorporated only on coal-fired boilers because natural gas is less carbon intensive fuel which emit less amount of CO₂ emission.

d) Fuel selection and plant shut-down:

For i^{th} fossil fuel boilers, either the process is operating with one chosen fuel or is shut down.

$$\sum_j X_{ij} \leq 1 \quad \forall i \in F \quad (5)$$

e) Plant capacity constraints:

$$\sum_j X_{ij} \leq 1 \quad \forall i \in F \quad (6a)$$

$$E_i \leq M \quad \forall i \in NF \quad (6b)$$

$$E_i \leq My_i \quad \forall i \in P^{new} \quad (6c)$$

The above constraint set upper bounds on energy produced from the different electricity generating stations. It also ensures that the energy production from fossil fuel plants ($i \in F$) is zero when no fuel is assigned to the plant and a decision of plant shut-down has been made. The parameter M is any large number and represents an upper bound on energy production for i^{th} non fossil power plants/new hypothetical boilers. M can be chosen to be the maximum installation capacity.

f) Upper bound on operational changes:

The electricity generated from the i^{th} unit cannot exceed the current electricity generation for the unit by r_i (the maximum increase in the base load, $E_i^{current}$ due to operational constraints).

$$E_{ij} \leq (1 + r_i) E_i^{current} X_{ij} \quad \forall i \in F, \forall j \quad (7a)$$

$$E_i^{NF} \leq (1 + r_i) E_i^{current} \quad \forall i \in NF \quad (7b)$$

$$E_i^{new} \leq E_i^{max} y_i \quad \forall i \in P^{new} \quad (7c)$$

g) Lower bound on operational constraints:

The capacity factor must be greater than some minimum; otherwise the plants will be shut down.

$$f_{ij} \geq l_{ij} \times X_{ij} \quad \forall i \in F, \forall j \quad (8a)$$

$$f_i \geq l_i \quad \forall i \in NF \quad (8b)$$

$$f_i \geq l_i y_i \quad \forall i \in NF \quad (8c)$$

where l_{ij} (l_i) is the minimum annual capacity factor for i^{th} fossil fuel boiler (non-fossil fuel plant and hypothetical new boiler) and f_{ij} (f_i) is the corresponding annual capacity factor. The relationship between the annual capacity factor and electricity generation is given below:

$$E_{ij} = f_{ij} E_{ij}^{max} \quad \forall i \in F, \forall j \quad (9a)$$

$$E_i = f_i E_i^{max} \quad \forall i \in NF \quad (9b)$$

$$E_i = f_i E_i^{max} y_i \quad \forall i \in P^{new} \quad (9c)$$

where E_{ij}^{max} (E_i^{max}) is installed capacity of i^{th} fossil (non-fossil power plants/new hypothetical boilers).

h) Selection of CO₂ capture process to be installed in power plant i

Location for CO₂ capture to put online on i^{th} existing coal-fired boilers will be determined. This constraint only applies to the case of carbon capture retrofit on existing coal-fired power plants.

$$\sum_k z_{ik} \leq 1 \quad \forall i \in F^c \quad (10)$$

i) If the existing coal-fired boilers shut down, no capture process will put online

$$z_{ik} \leq \sum_j X_{ij} \quad \forall i \in F^c \quad (11)$$

This constraint is associated to constraints (7a) which indicates that, the i^{th} fossil fuel boilers will be shut down if the binary variable (fuel selection variable), X_{ij} , is equal to 0. The above constraints are to ensure that no capture process will be put online if the coal-fired boilers are shut down.

j) Selection of hypothetical new power plants

In this study, six types of technology have been considered to supply supplemental energy for capture process as well as to meet growth rate demand. These technologies are: supercritical pulverized coal (PC), supercritical pulverized coal with capture (PC+CCS), Integrated gas combined cycle (IGCC), Integrated gas combined cycle with capture (IGCC+CCS), Natural gas combined cycle (NGCC) and natural gas combined cycle with capture (NGCC+CCS) Three different boilers performance and sizes for each technology has been incorporated in the model.

$$\sum_i y_i \leq b \quad \forall i \in P^{new} \quad (12)$$

where b is the number of boilers of new technology that will be incorporated in the model.

k) Selection of CO₂ sequestration location

For identical coal-fired boilers

This constraint is to ensure that only one sequestration site will be selected for one identical coal-fired boiler.

$$\sum_s w_{is} \leq 1 \quad \forall i \in F^c \cup P^{PCcap} \cup P^{IGcap} \cup P^{NGcap} \quad (13a)$$

For coal-fired stations

Only one sequestration location will be selected for one coal-fired stations and new power plants with capture that consist of several identical boilers

$$w_{is} + w_{i's'} \leq 1 \quad \forall i \in F^g \cup P^{new}, \forall s, i' \neq i, s' \neq s \quad (13b)$$

where w_{is} is a binary variable that indicates the selection of s^{th} potential location for CO₂ sequestration and F^g is coal-fired power plants that consists of several boilers.

l) CO₂ sequestration must be determined once capture process is put online

Once carbon capture retrofit is implemented in i^{th} existing coal fired boilers or new hypothetical boilers with capture process is constructed, s^{th} potential location for CO₂ sequestration is determined in order to store the CO₂ captured securely and permanently.

$$\sum_s w_{is} = \sum_k z_{ik} \quad \forall i \in F^c \cup P^{PCcap} \cup P^{IGCCcap} \cup P^{NGCCcap} \quad (14)$$

m) Emission constraint/CO₂ balance:

CO₂ emissions from all existing coal-fired boilers and new potential boilers, α_i (million tonne/yr) are defined as below:

$$\alpha_i = \sum_j CO_{2ij} E_{ij} \quad \forall i \in F \quad (15a)$$

$$\alpha_i = CO_{2i} E_i \quad \forall i \in P^{new} \quad (15b)$$

where CO_{2ij} is the CO₂ emission for the i^{th} existing fossil fuel boilers using the j^{th} fuel per electricity generated and CO_{2i} is CO₂ emission from new hypothetical boilers (tonne CO₂/MWh). CO_{2ij} and CO_{2i} is calculated using basic chemical equations that relate the production of CO₂ emission to the quantity and quality of fuel burned.

$$CO_{2ij} = 0.03667(EF)_{ij} \quad \forall i \in F \quad (16a)$$

$$CO_{2i} = 0.03667(EF)_i \quad \forall i \in P^{new} \quad (16b)$$

where 0.03667 is the conversion factor from coal to CO₂, EF_{ij} is the CO₂ emission factor of the i^{th} fossil fuel station using j^{th} fuel and EF_i is the CO₂ emission factor of the i^{th} potential new boilers as represents below:

$$EF_{ij} = \frac{1}{\eta_{ij}} \left(\frac{\%C}{HHV_{ij}} \right) \quad (17a)$$

$$EF_i = \frac{(1 - \varepsilon_{ik})}{\eta_i} \left(\frac{\%C}{HHV_{ij}} \right) \quad (17b)$$

where η_{ij} is the efficiency of i^{th} fossil fuel boilers while operating on j^{th} fuel and η_i is the efficiency of potential new boilers. $\%C$ represents the percentage of carbon content and HHV_{ij} is the fuel higher heating value.

In constraints (15), CO₂ emissions from fossil power plants, α_i will be captured in k^{th} capture process also can be defined as $\alpha_i^{seq} + \alpha_i^{released}$, where α_i^{seq} is CO₂ captured by k^{th} capture process and $\alpha_i^{released}$ is CO₂ emitted to the atmosphere. For the case of CO₂ capture with k^{th} capture

process, $z_{ik} = 1$ and ε_{ik} fraction of CO₂ captured,

$$\alpha_i^{released} = \alpha_i \left(1 - \sum_k \varepsilon_{ik} z_{ik} \right) \quad \forall i \in F^c \quad (18a)$$

$$\alpha_i^{seq} = \alpha_i \sum_k \varepsilon_{ik} z_{ik} \quad \forall i \in F^c \quad (18b)$$

If there is no CO₂ capture exist, $z_{ik} = 0$, then all CO₂ emitted from the i^{th} fossil fuel boilers, α_i , will be released to the atmosphere, which results to:

$$\alpha_i^{released} = \alpha_i \quad \forall i \in F^c \quad (19a)$$

$$\alpha_i^{seq} = 0 \quad \forall i \in F^c \quad (19b)$$

Note that constraints (18a, 18b) and (19a, 19b) only apply to existing coal fired boilers. Besides CO₂ emission from existing fossil fuel boilers, the new hypothetical boilers e.g. PC, IGCC and NGCC with and without capture also contribute to the total CO₂ emissions. Thus, the total CO₂ emission (million tonne/year) from existing fossil fuel boilers and new hypothetical boilers can be written as:

$$\sum \alpha_i^{released} = \sum_{i \in F} \alpha_i \left(1 - \sum_k \varepsilon_{ik} z_{ik} \right) + \sum_{i \in P^{new}} CO_{2i} E_i \quad (20)$$

Substitution equation (16a) into equation (21) will result in the following equation:

$$\sum \alpha_i^{released} = \sum_{i \in F} \left[\left(\sum_j CO_{2ij} E_{ij} \right) \left(1 - \sum_k \varepsilon_{ik} z_{ik} \right) \right] + \sum_{i \in P^{new}} CO_{2i} E_i \quad (21)$$

Annual total CO₂ emissions from all existing fossil fuel boilers and potential new boilers must satisfy a specific CO₂ reduction target, %CO₂.

$$\sum_{i \in F} \left[\left(\sum_j CO_{2ij} E_{ij} \right) \left(1 - \sum_k \varepsilon_{ik} z_{ik} \right) \right] + \sum_{i \in P^{new}} CO_{2i} E_i \leq (1 - \%CO_2) CO_2 \quad (22)$$

In above the constraints, the nonlinearity is due to the multiplication of continuous variable E_{ij} and binary variable, z_{ik} . To linearize the non-linear term, 'exact linearization' method has been employed.

3.0 Case Study

3.1 Description of OPG Power Stations

Currently, OPG operates 79 electricity generating stations, 5 are coal fired generating stations, C($i=1-5$), 1 is a natural gas generating station, NG($i=6$), 3 are nuclear generating stations, N($i=7-9$), 69 are hydroelectric generating station, H ($i=10-78$), and 1 is a small wind turbine, A($i=79$). At nominal levels, OPG generates about 115.8 TWh. and injects it into the grid from a mix of sources i.e. coal, hydroelectric, nuclear and renewable energy. No CO₂ capture process currently exists at any OPG power plant; about 36.7 million tonnes of CO₂ was emitted in 2002, mainly from fossil fuel power plants. There are 27 fossil fuel boilers at the 6 fossil fuel stations: 4 boilers at Lambton (L1-L4), 8 boilers at Nanticoke (N1-N8), 8 boilers at Lakeview (LV1-LV8), 1 boiler at Atikokan (A1), 4 boilers at Lennox (L1-L4) and Thunder Bay has 2 boilers (TB1-TB2). Currently, 4 (out of 8) boilers operated by Lennox are running on natural gas and the other 4 boilers are running on coal.

The operating cost for nuclear, hydroelectric, and wind turbine was estimated to be US\$21/MWh, US\$3.30/MWh, and US\$2.70/MWh, respectively. Note that, currently, natural gas is the most expensive fuel used by OPG which is US\$47/MWh (OPG, 2002). Since the main objective of this paper is to study CO₂ emission reduction through fuel balancing, fuel switching and CO₂ capture, no attempt is made to study the effect of improved technology. An improvement in boiler technology will, in principle, lead to an efficiency higher than our assumed efficiency of 35%.

Index i ($i=1\sim 79$) represents all of OPG's power plants. The index j ($j=1\sim 2$) represents the fuel selection, $j=1$ (coal), 2 (natural gas). The retrofit cost was estimated to be US\$20 million/1000 MW with a 30 year lifetime and 15% annual interest rate. The reserve margin, r_i for load distribution for all OPG's fleet power plants is set at 1% higher than current operational level due to the design constraints and the lower bound was set to be 10%. In other words, the plants have to operate at least with 10% annual capacity factor; otherwise the plants will be shut down. A summary of OPG's current fossil fuel generating stations is contained in Table 1.

Table 1 Ontario Power Generation fossil fuel power stations

Station	Fuel	Heat rate (GJ/MWh)	Installed Capacity (MW)	Number of units	Annual capacity factor	Operational cost (\$/MWh)	CO ₂ emission (tonne/MWh)
Nanticoke 1 (N1)	Coal	9.88	500	2	0.75	20	0.93
Nanticoke2 (N2)	Coal	9.88	500	6	0.61	20	0.93
Lambton1 (L1)	Coal	9.84	500	2	0.5	22	0.94
Lambton2 (L2)	Coal	9.84	500	2	0.75	17	0.94
Lakeview (LV)	Coal	10.8	142	8	0.25	23	0.98
Lennox (LN)	NG	7.82	535	4	0.15	47	0.65
Thunder Bay (TB)	Coal	11.7	155	2	0.55	20	1.03
Atikokan (A)	Coal	9.82	215	1	0.44	20	1.03

According to Rubin et al. (2004), energy penalty associated with CO₂ capture process can be calculated using the following equation

$$EP = 1 - \frac{\eta_{CCS}}{\eta_{ref}} \quad (23)$$

where EP is the energy penalty (fraction reduction in output), η_{CCS} and η_{ref} are the net efficiencies of the capture plant and reference plant respectively. This energy penalty also can be defined as the reduction in plant output for a constant fuel input and called "plant derating". For the case of CCS retrofit on existing coal-fired power plant, the energy penalty was assumed at 22% as suggested by Rubin et al. (2002). The detailed of existing coal fired stations with and without capture characteristics are shown in Table 2. 'ref' is represents existing coal fired power plant characteristics, whereas 'cap' represents the plant performance once CCS is incorporated. New state-of-the-art PC, IGCC and NGCC with and without capture cost estimation for different sizes are adjusted to the same economic references, which is described in Table 3.

In this study, the performances of power plant were obtained from the literature (Rubin, 2004; Ordorica et al., 2004; McDaniel, 2002; Parson 1998). Data for new supercritical PC power plants without capture at two different capacities (500 MW, 575 MW) and with capture at three different capacities (500 MW, 670 MW, 710 MW with 90% CO₂ capture) were obtained from Rubin et al. (2004) reported in 2001\$US. On the other hand, plant performance and cost (mid 2001US\$) for a 250 MW IGCC was gathered from real plant data (McDaniel, 2002). Two different plant designs and cost estimation of IGCC with capture (500 MW with 80% CO₂

capture and 513 MW IGCC with 60% CO₂ capture) were based on a study by Ordorica et al.

Table 2 Parameters and cost comparison of retrofit CO₂ capture on existing coal fired power plants

Parameters	N1		N2		L1		L2		LV		TB		A	
	ref	cap	ref	cap	ref	cap	ref	cap	ref	cap	ref	cap	ref	cap
Gross capacity (MW)	512	512	512	512	515	515	515	515	150	150	163	163	230	230
Net power gen. (MW)	490	382	490	382	493	385	493	385	142	111	155	120	215	168
Heat rate, HHV (GJ/MWh)	9.88	12.7	9.88	12.7	9.84	12.6	9.84	13.1	10.8	13.8	9.82	12.5	9.82	12.5
Capacity factor, ACF	0.75	0.75	0.61	0.61	0.5	0.5	0.75	0.75	0.25	0.25	0.55	0.55	0.44	0.44
CO ₂ capture (%)	-	90	-	90	-	90	-	90	-	90	-	90	-	90
CO ₂ emission (tonne/MWh)	0.93	0.09	0.93	0.09	0.94	0.09	0.94	0.09	0.98	0.09	1.02	0.11	1.02	0.11
CO ₂ capital cost (M\$) ^a	-	236	-	236	-	238	-	270	-	290	-	86	-	121
O&M cost (\$/MWh) ^a	20	13.9	20	13.9	22	13.9	17	13.9	23	13.9	20.0	13.9	20.0	13.9
COE (¢/KWh) ^a	2.0	4.01	2.0	4.27	2.2	4.55	1.7	4.16	2.3	8.0	2.0	5.11	2.0	5.75
Capture cost (\$/tonne)	-	24.0	-	27.1	-	26.6	-	27.1	-	64.5	-	33.8	-	40.7
CO ₂ avoided ^a														

^a Cost is adjusted according to standard methodology and reported in 2004 US\$ using Chemical Engineering Plant Cost Indexes (Chemical Engineering Magazine, 1990-2004) with coal price is US\$1.2/GJ

Table 3 Specification of economic parameters (All cost are in 2004 USD)

Economic life time	30 year
Interest rate of return	15%
Fuel cost	
Coal	US\$1.2/GJ
Natural gas	US\$4.0/GJ

(2004). Plant performance for NGCC without capture of two different plant sizes (326 MW, 395 MW) were obtained from Parson (1998) and for 517 MW from Rubin et al. (2004). Plant characteristics for two different sizes of NGCC with capture (517 MW and 750 MW with 90% CO₂ capture) were obtained from Rubin (2004) and Bechtel (2002), respectively. Finally, cost of all proposed new power plants were adjusted with the same economic assumption and reported in 2004US\$ using Chemical Engineering Plant Cost Indexes (Chemical Engineering Magazine, 1990-2004) with coal price of US\$1.2/GJ and natural gas price of US\$4/GJ.

4.0 Results

This section will discussed 2 main results: (1) The effect of cost of electricity (COE) by adjusting the CO₂ emission reduction by fuel balancing, fuel switching or capturing and (2) The effect of CO₂ reduction on distribution of electricity generation for existing and new plants for base load demand.

Figure 2 shows the effect of CO₂ reduction on COE. As can be seen, increasing the CO₂ emission reduction would result in increase in the cost of generating electricity. Currently, OPG electricity cost is 1.57¢/KWh which represents by 0% CO₂ reduction. The optimization results show that fuel balancing can contribute to the reduction of CO₂ emissions by only 3%. Fuel balancing also results in a reduction of cost of electricity to 1.54¢/KWh by reducing electricity generation from all four natural gas boilers by 32.1% and two coal fired boilers by 33.4% and 59.4%, respectively. The electricity generation from other fossil fuel boilers and non fossil fuel power plants were increased by 1% above the nominal operational level to maintain the electricity to the grid.




Figure 2 Effect of CO₂ reduction to the COE




Figure 3 Current OPG's fossil-fuel electricity generation by plants in 2002

However, if CO₂ emissions are to be reduced beyond than 3% (e.g. 20% for Canada Kyoto Target), more stringent measures that include fuel switching, plant retrofitting and CO₂ capture will have to be employed. The optimization results show electricity generation from one natural gas boilers (LN4) need to be reduced by 32.1%, one natural gas boiler (LN2) reduced by 4.1% and nine coal fired boilers (L1,L2,N1,N2, N3, N4,LV7,LV8,TB1) need to be switched to natural gas resulting in an increase of cost of electricity of about 7.1%. Finally, the other coal fired boilers and non-fossil fuel power plants increase the electricity generation by 1% higher than the nominal operational level to meet the electricity demand. For the case of 60% CO₂ reduction, cost of electricity is increased by 35.6% since 4 new natural gas boilers are put online to compensate with the reduction in electricity output due to implementation of CO₂ capture retrofit on five Nanticoke coal-fired boilers, shut down of all 8 Lakeview boilers, 2 Lambton boilers (L1, L2) and 2 Thunder Bay boilers (TB1, TB2) as well as to achieve greater CO₂ reduction.

Figure 3-8 illustrate the electricity distribution for base case, 3%, 6%, 20%, 40% and 60% CO₂ reduction target in order to meet current electricity demand. Figure 3 shows the base case which represents OPG's current operational level (2002).

Figure 4 shows the optimization results for the case of 3% CO₂ reduction. For this case, and as is clear from the figure, no fuel switching is needed. In other words, this objective can be obtained by only adjusting operation of current boilers e.g. increasing load from existing non fossil power plants and decreasing load from existing fossil power plants (fuel balancing). The results show that electricity generation from all four natural gas boilers has been reduced by 32.1%. The electricity generation from other fossil fuel boilers and non fossil fuel power plants were increased at 1% higher than the nominal operational level to maintain the electricity to the grid.

In order to achieve more than 3% CO₂ reduction (Figure 5), it was found that fuel switching must be implemented. This involves fleet changes from coal to natural gas. The optimization results show, for instance, that in order to achieve 6% CO₂ reduction (Canada's Kyoto target at 1990) while maintaining the electricity to the grid at minimum cost, the electricity generation from 3 natural gas boilers (LN1, LN2 and LN3) need to be reduced by 32.1%, one natural gas boiler (LN4) reduced by 8.2%, 2 coal fired boiler (LV1 and LV2) reduced by 59.4% and 34.8% respectively and the other coal fired boilers and non-fossil fuel power plants increase the electricity generation by 1% higher than the nominal operational level. Finally, one Nanticoke boiler (N8) which is the largest coal-fired boilers for OPG need to be switched to natural gas.




Figure 4 Optimal electricity generation for fossil fuel-plants & 3% CO₂ reduction




Figure 5 Optimal electricity generation for fossil fuel-plants & 6% CO₂ reduction

Figure 6 shows that, 20% CO₂ reduction and meet current electricity demand could be achieved by implementing fuel balancing and switching nine coal-fired boilers to natural gas. For the case of 40% CO₂ reduction as illustrated in Figure 7, the optimizer choose to switch most of coal fired boilers to natural gas and replacing all 8 Lakeview boilers with a new NGCC.




Figure 6 Optimal electricity generation for fossil fuel-plants & 20% CO₂ reduction




Figure 7 Optimal electricity generation for fossil fuel-plants & 40% CO₂ reduction

In order to achieve greater CO₂ emission reduction (e.g. 60% CO₂ reduction) and generating current electricity generation, the optimizer choose to implement CO₂ capture on five existing Nanticoke boiler (N1, N2, N3, N4, N5) and put on stream four new NGCC (two 326 MW, one 395 MW, one 517 MW) resulting in a COE of 2.44¢/kWh.

5.0 Conclusions

In this study, the model is formulated as Mixed Integer Non Linear Programme (MINLP) and implemented in GAMS (General Algebraic Modeling System). Exact linearization techniques were




Figure 8 Optimal electricity generation for fossil fuel-plants & 60% CO₂ reduction

employed to facilitate solution development. The computer programme is capable of determining the best mix of fuel, annual capacity factor for existing power plants, location and size of CO₂ capture process and finally, construction of new state-of-the-art power plants, such as supercritical pulverized coal (PC), integrated gas combined cycle (IGCC) or natural gas combined cycle (NGCC) with and without CO₂ capture. As can be seen, increasing CO₂ reduction target leads to switching of more coal-fired boilers to natural gas. For a greater CO₂ reduction target, new plants with and without CCS will compete with existing plant that have been paid off but remain competitive due to lower overall cost. Among the option, NGCC is more favorable although average coal prices are projected to fall throughout the forecast due to lower capital costs, higher fuel efficiency and lower CO₂ emissions.

Optimization results for maintaining current electricity demand shows that fuel balancing could contribute up to 3% CO₂ reduction by increasing all non fossil fuel power plants by 1% above the nominal operation level, while reducing electricity generation from all four natural gas boilers (the most expensive fuel) by 32.1%. To meet the electricity demand, the optimization suggests then to increase all coal power plants by 1% above the nominal annual capacity factor. This result in a decrease of COE by 1.9% compare to the current situation (1.57¢/kWh). However if CO₂ emissions are to be reduced by more than 3%, more stringent measures that include fuel switching and retrofitting carbon capture on existing coal-fired boilers have to be employed. For instance, to achieve 6% CO₂ reduction (Canada's Kyoto target), the largest coal fired boilers, Nanticoke (N2), need to be switch to natural gas. In addition, electricity generation from all four existing natural gas boilers is reduced by 32.1%. Finally, electricity generation from the other coal-fired boilers and non fossil fuel power plants need to be increased by 1% higher than nominal operational level. For this scenario, COE is the same as the base case without optimization, which is 1.57¢/KWh. In order to achieve greater CO₂ emission reduction (e.g. 60% CO₂ reduction) and generating current electricity generation, the optimizer choose to implement a CO₂ capture on five existing Nanticoke boiler (N1, N2, N3, N4, N5) and put on stream four new NGCC (two 326 MW, one 395 MW, one 517 MW) resulting in an increase of COE by 35.6%. The optimiser also recommended to store the captured CO₂ in Lake Erie.

Acknowledgements

The authors wish to thank Ontario Power Generation (OPG) for their technical support towards

this opportunity to contribute to the academic study of CO₂ capture. The information expressed herein is that of the authors and OPG takes no position on CO₂ capture and is simply furthering scientific endeavours.

References

- [1] Ontario Power Generation (2003): Personal communication.
- [2] Genchi, Y., K. Saitoh, N. Arashi, and A. Inaba. 2002. Assessment of CO₂ Emissions Reduction Potential by Using an Optimization Model for Regional Energy Supply Systems. Paper B5-6 presented at the Sixth International Conference on Greenhouse Gas Control Technologies, Kyoto International Conference Hall, Japan.
- [3] Mavrotas, G. 1999. An energy planning approach based on mixed 0-1 Multiple Objective Linear Programming. *International Transactions in Operational Research*. 6: 231-244.
- [4] Bai, H., and Wei, J. 1996. The CO₂ mitigation options for the electric sector. *Energy Policy*. 24: 221-118.
- [5] Climaco J. 1995. A multiple objective linear programming model for power generation expansion planning. *International Journal of Energy Research*. 19: 419-432.
- [6] Noonan F. 1977. Planning electric power generation: A linear mixed integer model employing benders decomposition. *Management Science*. 23: 946-956.
- [7] Brooke A., D. Kendrick, and A. Meeraus. 1988. GAMS: A User's Guide. The Scientific Press, South San Francisco, CA.
- [8] Noonan, F., and R. Giglio. 1977. Planning Electric Power Generation: A Nonlinear Mixed Integer Model Employing Benders Decomposition. *Management Science*. 23: 946-956
- [9] Analysis and Modeling Division, Natural Resources Canada.
[http://climatechange.nrcan.gc.ca/english/Home.asp?x\)1](http://climatechange.nrcan.gc.ca/english/Home.asp?x)1)
- [10] McDaniel, J.E. 2002. Tampa Electric Polk Power Station integrated gasification combined cycle project. Final technical report. Tampa: Tampa Electric Company.
- [11] Ordorica-Garcia, G., E. Croiset, P. L. Douglas., and L. Zheng. 2004. Simulation of IGCC power plants with glycol-based CO₂ capture using Aspen Plus. *Energy Conversion and Management*.
- [12] Rubin, E.S. et al. September 5-9, 2004. Comparative assessments of fossil fuel power plants with CO₂ capture and storage. Proceedings of the 7th International Conference on Greenhouse Gas Control Technologies, Vancouver, BC.
- [13] Shafeen, A., E. Croiset, P. L. Douglas, and I. Chatzis. 2004. CO₂ sequestration in Ontario, Canada. Part I: storage evaluation of potential reservoirs. *Energy Conversion and Management*. 45: 2645-2659.
- [14] Shafeen, A., E. Croiset, P. L. Douglas, and I. Chatzis. 2004. CO₂ sequestration in Ontario, Canada. Part II: cost estimation. *Energy Conversion and Management*. 45: 2645-2659.
- [15] Yokoyama, R., Y. Hasegawa, and K. Ito. 2002. A MILP decomposition approach to large scale optimization in structural design of energy supply systems. *Energy Conversion and Management*. 43: 771-790.