

DEVELOPMENT OF AEROBIC GRANULAR SLUDGE TECHNOLOGY
FOR DOMESTIC WASTEWATER TREATMENT IN HOT CLIMATES

AZNAH BTE NOR ANUAR

UNIVERSITI TEKNOLOGI MALAYSIA

DEVELOPMENT OF AEROBIC GRANULAR SLUDGE TECHNOLOGY
FOR DOMESTIC WASTEWATER TREATMENT IN HOT CLIMATES

AZNAH BINTI NOR ANUAR

A thesis submitted in fulfilment of the
requirements for the award of the degree of
Doctor of Philosophy (Civil Engineering)

Faculty of Civil Engineering
Universiti Teknologi Malaysia

SEPTEMBER 2008

To Dania, Aklam and my parents

ACKNOWLEDGEMENT

Thanks to Allah S.W.T. the Exalted, the Most Merciful, for giving me the strength and persistence to keep going with this research even during the most difficult moments. May Allah S.W.T accept this work and count it as a good deed.

I would like to express my thanks to my main supervisor: Dato' Prof. Ir. Dr. Zaini Ujang, who stimulated and supported the formulation of my Ph.D. Prof Zaini, I really learnt lots of things from you and I think the word "lots" does not amount to the quantity and the quality of the knowledge I got from you. I was always during this research period trying to run as fast as possible to catch your knowledge as much as possible. Your ever valuable feedback, enthusiasm and friendship have helped me a lot. You were always inspiring, educating and available when I needed you.

I am also grateful to my co-supervisor Prof. Ir. Dr. Mark van Loosdrecht (*formal*) and Dr. Ir. Merle de Kreuk (*informal*) from Delft University of Technology (TU Delft), the Netherlands for their guidance, advices and motivation. Without their continued support and interest, this thesis would not have been the same as presented here. My thanks are as well for Delft, the small city where I gained lots of knowledge and learned lots of things in different subjects of life during nine months attachment at TU Delft.

A special thanks also goes to Prof. Gustaf Olsson, from Lund Technical University, Sweden of his willingness to spend his valuable time, did a detailed review for Chapter 5 of this thesis and 3 technical papers that were submitted to international journals (*one accepted for Water Science Technology and another two is still under the reviewing process*). Thank you as well for agreeing to be a co-author. All the valuable comments, corrections and improvements made by you are really appreciated. Thank you very much again.

I would like also to acknowledge my special assistants, students from Biology Department, Faculty of Science who helped me during the experiments, Mun and Lan. And because of them too, I always get the opportunity to use any laboratory facilities in the Biology Department without any problem. I wished they were here to share with me the happy feelings of finalizing this work.

I would like also to express my appreciations for the endless help and support of the laboratory staff at Environmental Laboratory, Faculty of Civil Engineering, Universiti Teknologi Malaysia (UTM): Pak Usop, Abg Ramlee, Abg Ramli, K.Ros, Muz; staff at Biology Department: Dr. Madihah, PM Dr. Zaharah, Dr. Adibah and

Kak Timah; laboratory staff at Kluyver Laboratory of TU Delft: Stef van Hateren and Udo van Dongen; technical staff of Indah Water Konsortium (IWK), Tampoi : Pn Nurul, En Ishak, En. Nazri and technical staff at Front Instruments especially Mr. P.M Liew for their help in this study.

I am also indebted to UTM for funding my study and the Ministry of Science, Technology and Innovation (ScienceFund-79004) for funding this research. Thank you very much to Prof. Dr. Mohd Razman Salim (on his contributions as being a very enthusiastic and helpful research leader too, other than Prof. Zaini). Librarians at UTM as well as TU Delft also deserve special thanks for their assistance in supplying the relevant literatures.

Great thanks to all my friends in Delft: Wouter, Marlies and Mario (Dutch), Christian and Ana (Romanian), Xavier and Stefano (Italian), Penia, Uly and Tanti (Indonesian) and Gee, Fikri, Ina, Halik, Dora, Muaz and Bad (Malaysian). I will never forget you all and I hope that Allah S.W.T will gather us all in superior place and time.

To all my other friends, *my best friend ever* – K.Yati & K.Anim; *Kroni BMB* - (Aza, Dila, Azra, Tata, Aida, Lini, Fad, Fidah and Lina); *Kroni KP* - (Zalina, Zizah & Mimi); *Kroni 2nd Floor CO9* - (K.Ida, K.Mala, K.Su, K.Mila and K.Gee); *Kroni IPASA* - (My, Che A, Sha, Farah, Ju, Lin, Syikin, Lukman, Fahmi and Zul) and *Kroni Lab* (K.Seri, K.Isal, Alia, Zulfa, Sue Ann, Azri, Fadhil, Abdullah, Pak Niam, Pak Adi and En. Zul) who were always with me, praying for me, and supporting me all the time. Thank you very much.

I remain very grateful and gratified to my family, especially my parents who did and still do lots to me, my brother and younger sisters, to my parents-in-law, for their praying and support and to my siblings-in-law.

These acknowledgments would not be completed without expressing my thanks and love to my husband (*formal*) and mentor (*informal*), Khairulaklam Omar. Whatever I said, it will express my feelings towards him, appreciation, respect, and ever love. I think for a married (with children) PhD student, the degree is unattainable unless a very cooperative and helpful husband (as much as Aklam) is there.

This work will never come to the end if my angel was not there. The one who most inspired me to finalize the work as soon as possible, so that I can totally focus on her (*and soon to her future younger brothers / sisters, Insyallah*). She is my lovely young researcher, Dania. She was always behind me despite that I should always take care of her. She was always silent, polite, no problematic and understanding as much as I never thought. I love you so much and I hope you will appreciate what I've done and forgive me for everything. I promise you, I will try from now on to be always with you and compensate you for this tough period that we all had. I will forever thank Allah S.W.T for having Aklam as my husband and Dania as my lovely daughter.

ABSTRACT

Conventional domestic wastewater treatment plants based on activated sludge technology require large footprint (big settling tank) due to the relatively slow settling characteristics of sludge flocs. Aerobic Granular Sludge (AGS) technology offers a possibility to design a compact system based on simultaneous organic and nutrient removal and because of the good settling characteristics of the AGS, the use of a big settling tank is not necessary. Therefore, the installation can be more compact, at a cheaper cost. The aim of this study was to develop AGS system for domestic wastewater treatment applications in hot climate conditions. Special emphasis is given to the settling characteristics and physical strength of the AGS. Therefore, a 3-litre laboratory-scale reactor known as Cyclic Aerobic Granular Sludge Bioreactor (CAGSBio) was designed and used. The operation of the reactor was based on the Sequencing Batch Reactor (SBR) system with a complete cycle operation of three (3) hours and specifically designed to be operated for twenty-four (24) hours continuously at temperature of 30°C. A 3-litre laboratory-scale reactor in Delft University of Technology (TU Delft), the Netherlands operated at 20°C was also used to compare the results on AGS granulation and performance. AGS developed at this low temperature and from a 1.4 m³-pilot plant at Ede Wastewater Treatment Plant, the Netherlands (fed with pre-treated domestic wastewater) were also used for a physical strength study, to compare with AGS at 30°C. All analytical measurements performed in this study were conducted according to *Standard Methods for the Examination of Water and Wastewater* (APHA, 2005). The study shows that after ninety (90) days of operation, stable AGS (fed with synthetic wastewater) with average size of 1.1 mm were formed at 30°C. To demonstrate the simultaneous organic and nutrient removal by AGS, a removal study was also conducted. CAGSBio system showed stable removal performance. Average removal efficiencies during steady state cycles at 30°C of organic carbon, total inorganic nitrogen and phosphorus reached 100%, 94% and almost 98% respectively. A study with actual wastewater (pre-treated domestic wastewater) at 30°C indicates that the granulation process does occur but at a slower rate (125 days is essential to develop mature granules) compared to synthetic influent (90 days). Meanwhile, AGS settling behaviour study shows that AGS settled relatively fast (velocities >12 mh⁻¹ for size > 0.2 mm) compared to other conventional sludge flocs. The study also indicates that excessive mixing is not favourable for AGS reactors. Thus, the mixing criteria for AGS reactors was developed based on results obtained through experiments under mechanical and aerated-mixing conditions. Finally, a procedure was developed to evaluate the AGS strength based on the stability of AGS against shear stress. Determination of a stability coefficient (*S*) was introduced as an indicator of AGS strength. The results shows that AGS at 20°C and 30°C, fed with synthetic wastewater are very stable. For AGS fed with pre-treated domestic wastewater, the AGS at 30°C (produced using the laboratory-scale reactor) is more stable than the AGS at 20°C (produced using the pilot plant). As a conclusion, stable and compact AGS can be developed and performed effectively in hot climate conditions for domestic wastewater treatment applications, particularly as an alternative technology which is compact, high speed operation process (≈3 hours complete cycle) and more efficient.

ABSTRAK

Loji rawatan air sisa domestik konvensional yang berasaskan kepada teknologi enapcemar teraktif memerlukan keluasan tapak yang besar (tangki enapan besar) disebabkan oleh ciri enapan flok enapcemar yang secara relatifnya perlahan. Teknologi Enapcemar Granular Aerobik (AGS) menawarkan kemungkinan untuk mereka bentuk sistem kompak berdasarkan kepada penyingkiran organik dan nutrien serentak dan disebabkan oleh ciri enapan AGS yang baik, penggunaan tangki enapan yang besar tidak diperlukan. Oleh itu, pemasangan boleh lebih kompak, pada kos yang murah. Matlamat kajian ini adalah membangunkan sistem AGS untuk aplikasi rawatan air sisa domestik pada keadaan iklim panas. Penekanan khas diberikan kepada ciri enapan dan kekuatan fizikal AGS. Oleh itu, reaktor berskala makmal-3 liter dikenali sebagai Bioreaktor Enapcemar Granular Aerobik Berkitar (CAGSBio) telah direka bentuk dan digunakan. Pengendalian reaktor adalah berdasarkan kepada sistem Reaktor Kelompok Berjjukan (SBR) dengan pengendalian kitaran lengkap tiga (3) jam dan direka bentuk khas supaya boleh dikendalikan untuk dua puluh empat (24) jam secara berterusan pada suhu 30°C. Reaktor berskala-makmal-3 liter di Universiti Teknologi Delft (TU Delft), Netherlands yang dikendalikan pada 20°C juga telah digunakan bagi perbandingan keputusan granulasi dan prestasi AGS. AGS yang telah dihasilkan pada suhu yang rendah ini dan AGS dari Loji Pandu-1.4 m³ di Loji Rawatan Air Sisa Ede, Netherlands (suapan dengan air sisa domestik pra-rawatan) juga telah digunakan untuk kajian kekuatan fizikal, bagi perbandingan dengan AGS pada 30°C. Semua pengukuran analitikal dalam kajian ini telah dikendalikan mengikut *Kaedah Piawaian bagi Penilaian Air dan Air Sisa* (APHA, 2005). Kajian ini menunjukkan bahawa selepas sembilan puluh (90) hari pengendalian, AGS yang stabil (suapan dengan air sisa sintetik) dengan saiz purata 1.1 mm telah terbentuk pada 30°C. Untuk menunjukkan penyingkiran organik dan nutrien serentak oleh AGS, kajian penyingkiran juga telah dibuat. Sistem CAGSBio telah menunjukkan prestasi penyingkiran yang stabil. Kecekapan penyingkiran purata organik karbon, nitrogen tak organik dan fosforus semasa kitaran keadaan mantap pada 30°C mencapai 100%, 94% dan hampir 98%. Kajian dengan air sisa sebenar (air sisa domestik pra-rawatan) pada 30°C pula menunjukkan bahawa proses granulasi berlaku tetapi pada kadar perlahan (125 hari diperlukan untuk menghasilkan granular yang matang) berbanding dengan influen sintetik (90 hari). Sementara itu, kajian kelakuan enapan AGS menunjukkan bahawa AGS terenap secara relatifnya cepat (halaju > 12 mh⁻¹ untuk saiz > 0.2 mm). Kajian juga menunjukkan bahawa pembauran yang berlebihan tidak sesuai bagi reaktor AGS. Dengan itu, kriteria pembauran untuk reaktor AGS telah dibangunkan berdasarkan kepada keputusan yang telah diperolehi melalui eksperimen pada keadaan pembauran-pengudaraan dan mekanikal. Akhir sekali, satu tatacara telah dihasilkan untuk menilai kekuatan AGS berdasarkan kepada kestabilan AGS melawan tegasan ricih. Penentuan pekali kestabilan (*S*) telah diperkenalkan sebagai penunjuk kekuatan AGS. Keputusan menunjukkan bahawa AGS pada 20°C dan 30°C, suapan dengan air sisa sintetik adalah sangat stabil. Bagi AGS suapan dengan air sisa domestik pra-rawatan, AGS pada 30°C (telah dihasilkan dengan menggunakan reaktor berskala-makmal) adalah lebih stabil berbanding AGS pada 20°C (telah dihasilkan dengan menggunakan loji pandu). Sebagai kesimpulan, AGS stabil dan padat boleh dihasilkan dan bertindak secara cekap untuk aplikasi rawatan air sisa domestik pada keadaan iklim panas, terutamanya sebagai teknologi alternatif yang mana kompak, proses pengendalian yang pantas (kitaran lengkap 3 jam) dan lebih cekap.

TABLE OF CONTENTS

CHAPTER	TITLE	PAGE
	DECLARATION	ii
	DEDICATION	iii
	ACKNOWLEDGEMENT	iv
	ABSTRACT	vi
	ABSTRAK	vii
	TABLE OF CONTENTS	viii
	LIST OF TABLES	xiv
	LIST OF FIGURES	xvii
	LIST OF ABBREVIATIONS	xxiii
	LIST OF SYMBOLS	xxvi
	LIST OF APPENDICES	xxvii
1	INTRODUCTION	1
	1.1 Background of the Study	1
	1.2 Objectives of the Study	3
	1.3 Scope of the Study	4
	1.4 Importance of the Study	5
	1.5 Organization of the Thesis	7

2	LITERATURE REVIEW	8
2.1	Conventional Activated Sludge System:	
	Main Features and Weaknesses	8
2.1.1	Characteristics of Conventional Activated Sludge System	8
2.1.2	Aerobic Biological Oxidation	10
2.1.3	Biological Nitrification and Denitrification	11
2.1.4	Biological Phosphorus Removal	12
2.1.5	Biomass and Effluent Separation	13
2.2	Issues on Design, Operation and Maintenance of Conventional Activated Sludge System	14
2.2.1	Sludge Bulking	14
2.2.2	Sludge Foaming	16
2.2.3	Rising Sludge	17
2.2.4	Surplus Sludge Production	17
2.2.5	Processing Time	19
2.2.6	Large Footprints and High Energy Cost	19
2.3	Compact Wastewater Treatment Systems	20
2.3.1	Sequencing Batch Reactors	20
2.3.2	Membrane Bioreactors	22
2.3.3	Particle-Based Biofilm (Bio-granulation) Reactors	23
2.4	Bio-granulation Technology	25
2.4.1	Anaerobic Granulation	25
2.4.2	Aerobic Granulation	26
2.5	Aerobic Granulation Technology	27
2.5.1	Formation of Aerobic Granular Sludge	27
2.5.2	Factors Affecting Aerobic Granulation	30
	2.5.2.1 Substrate Composition	30
	2.5.2.2 Organic Loading Rate	30
	2.5.2.3 Hydrodynamic Shear Stress	31
	2.5.2.4 Settling Time	32
	2.5.2.5 Hydraulic Retention Time	33
	2.5.2.6 Aerobic Starvation	34

2.5.2.7	Presence of Calcium Ion in Feed	35
2.5.2.8	Dissolved Oxygen	36
2.5.2.9	pH	36
2.5.2.10	Temperature	36
2.5.2.11	Seed Sludge	37
2.5.2.12	Reactor Configuration	41
2.6	Characteristics of Aerobic Granular Sludge	42
2.6.1	Morphology	43
2.6.2	Settling Characteristics	43
2.6.3	Density, Strength and Stability	44
2.7	Applications of Aerobic Granulation Technology	45
2.7.1	High-Strength Organic Wastewater	45
2.7.2	Simultaneous Organic and Nitrogen Removal	46
2.7.3	Phosphorus Removal	47
2.7.4	Simultaneous Organic, Nitrogen and Phosphorus Removal	48
2.7.5	Wastewater Rich in Particulate Matter	51
2.7.6	Phenolic Wastewater	51
2.7.7	Biosorption of Heavy Metals	52
2.8	Conclusions	53
3	METHODOLOGY	55
3.1	Methods	55
3.1.1	Study Perspective	55
3.1.2	Study Outline	56
3.2	Materials	60
3.2.1	Reactor Descriptions	60
3.2.1.1	Cyclic Aerobic Granular Sludge Bioreactor - UTM Skudai, Johor	60
3.2.1.2	Sequencing Batch Airlift Reactor - TU Delft, the Netherlands	61
3.2.1.3	Granular Sludge Batch Reactor - Ede, the Netherlands	70

3.2.2	Seed Sludge	74
3.2.3	Influent Feeding	75
3.2.3.1	Synthetic Wastewater	75
3.2.3.2	Actual Wastewater	76
3.2.4	AGS Samples	77
3.2.4.1	Study on AGS Settling Profile Compared with Other Conventional Sludge Flocs	77
3.2.4.2	Study on AGS Physical Strength	79
3.2.5	Analytical Procedures	80
3.3	Detailed Study Procedures	82
3.3.1	Study on AGS Granulation and Performance at 30°C	82
3.3.2	Study on AGS Settling Behavior	84
3.3.3	Study AGS Physical Strength	85
3.4	Detailed Experimental Set-up	86
3.4.1	Study on AGS Settling Profile Compared with Other Conventional Sludge Flocs	86
3.4.2	Study on AGS Settling Characteristics under Mechanical-Mixing Conditions	87
3.4.3	Study on AGS Settling Characteristics under Aerated-Mixing Conditions	89
3.4.4	Study on AGS Physical Strength	92
4	RESULTS AND DISCUSSION: GRANULATION AND PERFORMANCE OF AEROBIC GRANULAR SLUDGE AT TEMPERATURE OF 30°C	94
4.1	Aerobic Granulation at 30°C using Synthetic Wastewater	94
4.1.1	Physical characteristics	95
4.1.2	Biomass Concentrations	96
4.1.3	Formation and Morphology	98
4.1.4	Sludge Volume Index and Settling Velocity	103

4.2	Performance of Aerobic Granular Sludge	105
4.2.1	Removal Efficiency of Nitrogen	106
4.2.2	Removal Efficiency of Phosphorus	108
4.2.3	Removal Efficiency of Organic Carbon	108
4.2.4	Simultaneous Organic Carbon, Nitrogen and Phosphorus Removal by Aerobic Granular Sludge throughout One Cycle	110
4.3	Identification of Microbial Populations of AGS using Molecular Techniques	115
4.3.1	Bacteria Isolation and Screening	115
4.3.2	Bacteria Identification	125
4.4	Experiments with Actual Wastewater	129
4.4.1	Granulation Process	130
4.4.2	Removal Process	137
5	RESULTS AND DISCUSSION: SETTLING BEHAVIOR AND PHYSICAL STRENGTH OF AEROBIC GRANULAR SLUDGE	141
5.1	Settling Behavior of Aerobic Granular Sludge	141
5.1.1	Settling Profile of Aerobic Granular Sludge Compared to Other Conventional Sludge Flocs	142
5.1.2	Settling Characteristics of Aerobic Granular Sludge under Mechanical-Mixing Condition	147
5.1.2.1	Relationship between AGS Settling Velocity (v_{AGS}) with Variation of Stirrer Speed (N) and Shear Rates (γ)	148
5.1.2.2	Relationship between AGS Settling Velocity (v_{AGS}) with Variation Ratio of Blade and Vessel Diameter (D/T_v)	150

LIST OF TABLES

TABLE NO.	TITLE	PAGE
2.1	Description and causes of activated sludge foams (Richard, 2003)	16
2.2	Types of sludge treatment, advantages and some potential limitations (Badreddine, 2008)	18
2.3	Overview of published data about AGS concerning growth conditions, diameter, sludge volume index and suspended solids	38
3.1	Features of CAgSBio	63
3.2	Composition of the synthetic wastewater	75
3.3	Composition of sewage and synthetic influent used for CAgSBio	76
3.4	Description of samples for AGS settling profile study	78
3.5	Description of AGS samples for physical strength study	79
3.6	Analytical measurements performed in this study. (a) Measurements for reactor monitoring (b) Measurements for AGS granulation, formation and morphology monitoring (C)AGS performance monitoring (to remove organic and nutrient simultaneously)	80

3.7	Experimental procedure of AGS granulation and performance study	83
3.8	Experimental procedure of AGS settling behaviors study	84
3.9	Experimental procedure of AGS physical strength study	85
3.10	Shear rates applied in experiment	88
3.11	Size of vessel (T_v) and blade diameter (D) used in experiment	89
4.1	Physical characteristics of AGS developed at 30°C using synthetic wastewater (AGS-30°C-synthetic) compared with (AGS-20°C-synthetic) and seed sludge	95
4.2	The differences of AGS granulation process at TU Delft (SBAR) and UTM (CAgSBio)	104
4.3	Summary of results On AGS performance studies in the reactor at steady state conditions (with controlled DO at a low concentration $< 2 \text{ mgL}^{-1}$)	113
4.4	A total of 26 isolated strains of bacteria from AGS samples	117
4.5	Percentage of CH_3COO^- -C, TIN and PO_4^{3-} -P removal of 26 isolated strains	120
4.6	The percentage of removal and X_{\max} of 6 selected strains	121
4.7	Physical and chemical characteristics of $B_{\text{AGS-1}}$, $B_{\text{AGS-2}}$ and $B_{\text{AGS-25}}$ strain	128
4.8	Physical characteristics of AGS developed at 30°C using domestic wastewater (AGS-30°C-sewage) compared with (AGS-30°C-synthetic), (AGS-20°C-synthetic), (AGS-20°C-sewage) and seed sludge	132

4.9	Average composition of influent and effluent of the the CAgSBio system during experiments with actual wastewater	139
5.1	Problems associated with biomass separation in activated sludge systems (Jenkins <i>et al.</i> , 1993)	145
5.2	Statistical results of correlation between settling velocity of AGS (v_{AGS}) with the stirrer speed (N) and shear rates (γ)	150
5.3	Statistical results of relationship between AGS settling velocity (v_{AGS}) with variation of airflow rate (Q_{air}) and bubble size (r^2)	155
5.4	Statistical results of relationship between turbulent diffusion coefficient (K') with variation of airflow rate (Q_{air}) and bubble size (r^2)	156
5.5	Statistical results of relationship between AGS settling velocity (v_{AGS}) and turbulent diffusion coefficient (K')	159
5.6	Mixing criteria of AGS reactors	160
5.7	Physical characteristics of AGS developed at 20°C and 30°C	164
5.8	Procedures to evaluate AGS strength; determination of stability coefficient (S) and percentage of change of ϕ_{AGS} , (Σ)	167
5.9	Strength characteristics of AGS developed at 20°C and 30°C	169
5.10	Statistical results of correlation between stability coefficient (S), AGS density (ρ_{AGS}) and percentage of change of AGS size (Σ) with temperature (T)	170
5.11	Correlation function parameters of the experiment	173
5.12	Indicators for evaluation of AGS strength	174

LIST OF ABBREVIATIONS

AGS	-	Aerobic Granular Sludge
APHA	-	American Public Health Association
B_{AGS-1}	-	No. of Bacteria Strain
BAS	-	Biofilm Airlift Suspension
BFB	-	Biofilm Fluidized Bed
CAGSBio	-	Cyclic Aerobic Granular Sludge Bioreactor
Ca^{2+}	-	Calcium (II)
Cd^{2+}	-	Cadmium (II)
CH_3COO^-C	-	Acetate
CH_4	-	Methane
CO_2	-	Carbon Dioxide
CAS	-	Conventional Activated Sludge
COD	-	Chemical Oxygen Demand
CMTR	-	Completely Mixed Tank Reactor
DPAO	-	Denitrifying Phosphate Accumulating Organisms
DO	-	Dissolved Oxygen
EA	-	Extended Aeration
EBPR	-	Enhanced Biological Phosphorus Removal
EGSB	-	Expanded Granular Sludge Blanket
FISH	-	Fluorescence In Situ Hybridization
GAOs	-	Glycogen Accumulating Organisms
GSBR	-	Granular Sludge Batch Reactor
HCl	-	Acid Hydrochloric
H/D	-	Ratio of Reactor Height to Diameter
HRT	-	Hydraulic Retention Time

IC	-	Internal Circulation
KCl	-	Kalium Chloride
K ₂ HPO ₄	-	Potassium Hydrogen Phosphate Anhydrous
KH ₂ PO ₄	-	Potassium Dihydrogen Phosphate
MBR	-	Membrane Bioreactor
MgSO ₄ ·7H ₂ O	-	Magnesium Sulfate Heptahydrate
MLSS	-	Mixed Liquor Suspended Solids
MLVSS	-	Mixed Liquor Volatile Suspended Solid
N/COD	-	Nitrogen and Organic Ratio
N ₂	-	Nitrogen Gas
NaAc	-	Sodium Acetate
NaOH	-	Sodium Hydroxide
NH ₄ ⁺ -N	-	Ammonium
NH ₄ Cl	-	Ammonium Chloride
NO ₂ ⁺ -N	-	Nitrite
NO ₃ ⁺ -N	-	Nitrate
OLR	-	Organic Loading Rate
P	-	Phosphorus
P/COD	-	Phosphorus and Organic Ratio
PAOs	-	Phosphate Accumulating Organisms
PHA	-	poly-a-hydroxyalkanoates
PHB	-	poly-b-hydroxybutyrates
PO ₄ ⁻³ -P	-	Phosphate
SBR	-	Sequencing Batch Reactor
SND	-	Simultaneous Nitrification and Denitrification
SBAR	-	Sequencing Batch Airlift Reactor
SRT	-	Solids / Sludge Retention Time
STP	-	Sewage Treatment Plant
SVI	-	Sludge Volume Index
Total-N	-	Total Nitrogen
TUDeft	-	Delft University of Technology
TSS	-	Total Suspended Solids
UASB	-	Upflow Anaerobic Sludge Blanket
USB	-	Upflow Sludge Blanket

UTM	-	Universiti Teknologi Malaysia
VFA	-	Volatile Fatty Acid
WWTP	-	Wastewater Treatment Plant
Zn ²⁺	-	Zinc (II)

LIST OF SYMBOLS

D	-	Blade diameter
D/T_v	-	Ratio of blade and vessel diameter
K'	-	Turbulent diffusion coefficient
N	-	Stirrer speed
P_0	-	Standard pressure
P_T	-	Absolute pressure
p -value	-	Significance level
Q_{air}	-	Airflow rate
r	-	Bubbles size
r -value	-	Correlation coefficient
S	-	Stability coefficient
T	-	Temperature
T_v	-	Vessel diameter
X	-	Total dry weight of aerobic granular sludge
X'	-	Total dry weight of aerobic granular sludge residual
Σ	-	Percentage of change of AGS diameter
θ	-	Temperature coefficient
γ	-	Shear rate
ϕ	-	Diameter
ϕ_{AGS}	-	Diameter of aerobic granular sludge
ρ_{AGS}	-	Density of aerobic granular sludge
v_{AGS}	-	Settling velocity of aerobic granular sludge
X_{max}	-	Maximum growth concentrations of cell

LIST OF APPENDICES

APPENDIX	TITLE	PAGE
A	Dextran blue test (Beun <i>et al.</i> , 2000)	198
B1	Gram staining procedures	200
B2	Procedures of 16S rDNA sequence analysis	204
B3	BLASTn analysis to determine alignment scores of forward and reverse sequence of partial 16S rDNA from strain <i>B</i> _{AGS-1}	208
B4	BLASTn analysis to determine alignment scores of forward and reverse sequence of partial 16S rDNA from strain <i>B</i> _{AGS-2}	209
B5	BLASTn analysis to determine alignment scores of forward and reverse sequence of partial 16S rDNA from strain <i>B</i> _{AGS-25}	210
C	List of papers published	211

CHAPTER 1

INTRODUCTION

1.1 Background of the Study

Before World War II, only several municipal and industrial wastewater treatment plants were built, mainly consisting of mechanical separation and settling tanks. These treatment systems could be extended with anaerobic tanks for sludge stabilisation. The first generation of activated sludge systems was built in the 1920's, after the study on suspended growth treatment and the discovery of activated sludge by Arden and Lockett in 1914 (de Kreuk, 2006). A number of activated sludge processes and design configurations have evolved since its early conception as a result of : (1) engineering innovation in response to the need for high quality effluents; (2) technological advances in equipment and process control; (3) increased understanding of microbial processes and fundamentals; and (4) the continual need to reduce capital and operating costs for municipalities and industries. Other activated sludge processes that have been found in many applications, with their dates of major interest in parentheses, include the oxidation ditch (1950s), contact stabilisation (1950s), Krause process (1960s), pure oxygen activated sludge (1970s), Orbal process (1970s), deep shaft aeration (1970s) and sequencing batch reactor (SBR) process (1980s) (Metcalf and Eddy, 2003). The basic idea behind the system was to reduce the treatment of wastewater to a one-reactor system. Although, major

problems of this system were filaments often developed and biomass effluent separation was poor (Irvine and Ketchum, 1989; Wilderer *et al.*, 2000; Badreddine, 2008). However, the SBR system did receive worldwide attention and several thousands SBR facilities have since been designed, built and put into operation (Wilderer *et al.*, 2000, Hastings *et al.*, 2007). Most sewage treatment facilities are still based on the continuously-operated activated sludge processes.

In an activated sludge system, a mixed culture of suspended biomass is growing and removing organic carbon and nutrients from the influent. In such a process the biomass (the activated sludge), which are usually present as flocs, are mixed with the wastewater in a large aerated basin. Supply of fresh wastewater to the bioreactor and discharged of treated wastewater from the bioreactor occur continuously. The discharged wastewater is led to a settling tank. In the settler, separation of activated sludge from the treated wastewater is carried out by means of gravitational forces. The treated wastewater can then be discharged into surface waters, or is used for further treatment (Metcalf and Eddy, 2003). Conventional activated sludge plants produce surplus sludge. Part of the settled activated sludge is recycled to the bioreactor. The remainder of the sludge is usually treated anaerobically and later disposed in landfills, or is used as fertilizer in agriculture. Conventional activated sludge plants take up a substantial footprint. In order to treat large amounts of wastewater completely, large aeration tanks are needed. The settling tanks cover a large areas, because the settling velocity of the activated sludge flocs is very low, normally $<1 \text{ mh}^{-1}$ (Beun *et al.*, 2001; Metcalf and Eddy, 2004; Katja and Mika, 2007). Since the available ground area to build the treatment plant is usually limited, especially in Malaysia, there is a need for a more compact and high performance reactor.

This need for more compact reactors and short hydraulic retention time (HRT) directed the study towards the development of systems with high biomass concentrations. The AGS technology was proven as an alternative technology for compact and high performance system to treat wastewaters (Morgenroth *et al.*, 1997; Beun *et al.*, 1999; Tay *et al.*, 2002; de Bruin *et al.*, 2004; Liu and Tay, 2004; de

Kreuk *et al.*, 2005; Zitomer *et al.*, 2007; Sunil *et al.*, 2008). AGS technology offers a possibility for compact wastewater treatment plant based on simultaneous organic (Chemical Oxygen Demand, COD) and nutrient (Nitrogen and Phosphorus) removal in one sequencing batch reactor. Because of the high settling capacity of the granules, the use of a traditional settler is not necessary and therefore, the installation can be very compact and at a cheaper cost.

Most of the AGS studies carried out so far were at low temperature (between 8 and 15°C) and room temperature (between 20 and 25°C). As a result, it is not fully known how these systems respond to changes at high temperature. In Malaysia, the temperature of domestic sewage is usually around 30°C. The formation and stability of AGS at this temperature have not been studied extensively up to this date.

1.2 Objectives of the Study

The overall aim of this study was to develop an AGS system with special emphasis on temperature effects, settling and physical characteristics for the enhancement of domestic wastewater treatment systems. This can be achieved by the following specific objectives:-

- i. To develop AGS at 30°C using Cyclic Aerobic Granular Sludge Bioreactor (CAgSBio) and to compare with AGS at 20°C developed using Sequencing Batch Airlift Reactor (SBAR), TU Delft, and Granular Sludge Batch Reactor, Ede, the Netherlands.

- ii. To investigate the performance of AGS to remove organic matter and nutrients simultaneously at 30°C in CAgSBio system, and to identify microbial populations of AGS using molecular techniques (via 16S rDNA sequence analysis).
- iii. To develop AGS in CAgSBio system using actual wastewater (pre-treated domestic wastewater).
- iv. To study the settling behaviour of AGS and to develop mixing criteria for AGS reactors.
- v. To study the physical strength of AGS and to develop procedures for evaluation of AGS physical strength based on determination of stability coefficient (S), in which S represents an indicator of AGS strength (stability of AGS against shear stress). AGS from different sources, (i.e. developed at 20 and 30°C, fed with synthetic and pre-treated sewage from CAgSBio, SBAR and GSBR) were used as samples to establish S values.

1.3 Scope of the Study

A 3-litre laboratory-scale reactor known as CAgSBio was designed and used. The operation of the reactor was based on the SBR system with a complete cycle operation of 3 hours and specifically designed to be operated for 24 hours continuously. Fresh activated sludge from local municipal wastewater treatment plants were used as inoculums (seed sludge) to start-up the reactor.

In addition, a 3-litre laboratory-scale reactor in Delft University of Technology (TU Delft), the Netherlands, operated at 20°C was used to compare the results on AGS granulation and performance. Furthermore, AGS developed at this low temperature as well as from a 1.4 m³ pilot plant at Ede wastewater treatment plant, the Netherlands (fed with pre-treated domestic wastewater), were also used for AGS strength study to compare with AGS developed at 30°C. All analytical measurements performed in this study were conducted according to *Standard Methods for the Examination of Water and Wastewater* (APHA, 2005).

Two types of wastewater were used to develop AGS at 30°C i.e. synthetic wastewater and pre-treated domestic wastewater from local municipal wastewater treatment plants (actual wastewater). Finally, special attention on the study of settling behaviour and physical strength of AGS was also given in this thesis.

1.4 Importance of the Study

Since wastewater treatment systems are needed in dense populated regions, therefore, utilization of space is to be optimized. Available space for existing treatment plants is often limited, which can cause problems when treatment plants need to be extended for upgrading purposes. To avoid large footprints, compact treatment systems are needed. Since the last decade, different compact treatment systems have been developed, such as the biofilm system (Mulder *et al.*, 2001; Nicollela *et al.*, 2000), membrane bioreactors (Sourirajan, 1977; Ujang and Anderson, 1996; Ujang and Anderson, 2000; Ujang *et al.*, 2007) and AGS technology (Beun *et al.*, 2000; Tay *et al.*, 2004; de Kreuk and van Loosdrecht, 2006; Zitomer *et al.*, 2007; Sunil *et al.*, 2008). The importance of this study are as follows:-

- i. This study provides technical input to develop a lab-scale compact domestic wastewater treatment system, known as CAgSBio, in which, it is specifically designed as a high, vertical and slender reactor.
- ii. This study provides appropriate procedures on AGS granulation in hot climate conditions, especially at 30°C.
- iii. This study also provides insight on the performance of stable AGS to remove organic matter and nutrients simultaneously in a single unit reactor.
- iv. This study also provides insight on the settling behaviour of AGS via comparing the settling profile study with other conventional sludge flocs and study on influence of both mechanical and aerated-mixing conditions to the AGS settling characteristics.
- v. Through the results obtained from the settling behaviour study, a mixing criteria for AGS reactors was also developed.
- vi. This study also provides procedures to evaluate the AGS strength based on the stability of AGS against shear stress. Determination of stability coefficient (S) was introduced as an indicator of AGS strength.

1.5 Organization of the Thesis

This thesis consists of six chapters. Chapter 1 gives a historical overview of domestic wastewater treatment and the need for more compact systems. An overview of the theoretical background of studies conducted on compact wastewater treatment system, especially AGS technology and theory of AGS granulation and performance were explained in Chapter 2. Chapter 3 presents a perspective and an outline of the study, materials and methods used as well as detailed procedures of each experiment conducted.

Chapters 4 and 5 present the results of the experimental studies that have been described in Chapter 3. Chapter 4 presents the results on AGS granulation and performance in hot climate conditions, especially at 30°C, while Chapter 5 specially discussed on AGS settling behaviour and physical strength. The last chapter, Chapter 6, presents the conclusions of this study. Recommendations for future studies are also outlined in this chapter.

REFERENCES

- Allsop, P.J., Chisti, Y., Moo-Young, M. and Sullivan, G.R. (1993). Dynamics of Phenol Degradation by *Pseudomonas Putida*. *Biotechnology Bioengineering*. 41, 572-80.
- Altschul, S. F., Gish, W., Miller, W., Myers, E. W., and Lipman, D. J. (1990). Basic Local Alignment Search Tool. *Molecular Biology*. 215, 403-410.
- Alvarado-Lassman, A., Rustrian, E., Garcia-Alvarado, M.A., Rodriguez-Jimenez, G.C, Houbroun, E. (2008). Brewery Wastewater Treatment Using Anaerobic Inverse Fluidized Bed Reactors. *Bioresource Technology*. 8 (99), 3009-3015.
- Alves, M. Cavaleiro, A.J., Ferreira, E.C., Amaral, A.L., Mota, M., da Motta, M., Vivier H., and Pons, M.N. (2000). Characterization by Image Analysis of Anaerobic Sludge under Shock Conditions. *Water Science and Technology*. 41, 207-214.
- American Public Health Association, APHA. (2005). *Standard Methods for the Examination of Water and Wastewater*. (21th ed.). Washington, D.C: APHA
- Arrojo, B., Mosquera-Corral, A., Garrido, J.M. and Mendez, R. (2004). Aerobic Granulation with Industrial Wastewater in Sequencing Batch Reactors. *Water Research*. 38 (14-15), 3389-3399.
- Atlas, R.M., Brown, A. E., Dobra, K. W. and Miller, L. (1988). *Experimental Microbiology: Fundamentals and Applications*. 2nd ed. Macmillan Publishing Company, New York.
- Badreddine, H. (2008). *Small Footprint for Sewage Processing*. Unpublished note, Neptune Technology Group.
- Barnard, J.L., Stevens, G.M., Leslie, P.L. (1985). Design Strategies for Nutrient Removal Plants. *Water Science and Technology*. 17, 233-242.
- Belyaev, S.S., Charackchian, I.A. and Kuznetsova, V.G. (1991). Strict Anaerobic Bacteria and Their Possible Contribution to the Enhancement of Oil Recovery. *Microbial Enhancement of Oil Recovery – Recent Advances*. 31, 163-172.
- Beun, J.J., Hendriks A., van Loosdrecht, M.C.M., Morgenroth, M., Wilderer, P.A. and Heijnen, J.J. (1999). Aerobic Granulation in a Sequencing Batch Reactor. *Water Research*. 33 (10), 2283-2290.

- Beun, J.J., van Loosdrecht, M.C.M and Heijnen, J.J. (2000). Aerobic Granulation. *Water Science and Technology*. 41, 41-48.
- Beun, J.J. (2001). *PHB metabolism and N-removal in Sequencing Batch Granular Sludge*. PhD Thesis. Delft University of Technology, the Netherlands.
- Beun, J.J., van Loosdrecht, M.C.M., and Heijnen, J.J. (2001). N-Removal in a Granular Sludge Sequencing Batch Airlift Reactor. *Biotechnology Bioengineering*. 75 (1), 82 - 92.
- Beun, J.J., Dircks, K., van Loosdrecht, M.C.M., and Heijnen, J.J. (2002a). Poly-B-Hydroxybutyrate Metabolism in Dynamically Fed Mixed Microbial Cultures. *Water Research*. 36 (5), 1167-1180.
- Beun, J.J., van Loosdrecht, M.C.M., and Heijnen, J.J. (2002b). Aerobic Granulation in a Sequencing Batch Airlift Reactor. *Water Research*. 36 (3), 702 -712.
- Bitton, G. (1999). *Wastewater Microbiology*. New York : Wiley-Liss.
- Blackall, L.L., Crocetti, G., Saunders, A.M. and Bond, P.L., (2002). A Review and Update of the Microbiology of Enhanced Biological Phosphorus Removal in Wastewater Treatment Plants. *Antonie Van Leeuwenhoek International Journal of General and Molecular Microbiology*. 81(14), 681-691.
- Boonyarit, N., Wuthichok, K., Naret, V., Thoranin, S. and Chantaraporn, P. (2008). Comparison of Sludge Granule and UASB Performance by Adding Chitosan in Different Forms. *Science*. 35 (1), 92-102.
- Bossier, P. and Verstraete, W. (1996). Triggers for Microbial Aggregation in Activated Sludge? *Applied Microbiology Biotechnology*. 45, 1-6.
- Bratby, J.R. (1977). Aspects of Sludge Thickening by Dissolved-Air Flotation. *Water Pollution Control*. 77, 421-432.
- Brdjanovic, D., van Loosdrecht, M.C.M., Hooijmans, C.M., Alaerts, G.J. and Heijnen, J.J. (1998). Minimal Aerobic Sludge Retention Time in Biological Phosphorus Removal Systems. *Biotechnology Bioengineering*. 60(3), 326-332.
- Brouwer, H., Temmink, H., Remy, M., and Geilvoet, S.(2005). MBR Technology: Future Research Directions. *H2O*. (4), 19-22.
- Calleja, G.B. (1984). *Microbial Aggregation*. Florida: CRC Press.
- Campos, C.M.M and Anderson, G.K. (1992). The Effect of the Liquid Upflow Velocity and the Substrate Concentration on the Startup and Steady State Period of Lab-scale UASB Reactors. *Water Science and Technology*. 25, 41-50.

- Cassidy, D.P. and Belia, E. (2005). Nitrogen and Phosphorus Removal from An Abattoir Wastewater in a SBR with Aerobic Granular Sludge. *Water Research*. 19 (39), 4817-4823.
- Chen, Y., Jiang, W., Liang, D.T, Tay, J.H. (2008) Aerobic Granulation Under the Combined Hydraulic and Loading Selection Pressures. *Bioresource Technology*. [in press].
- Chisti, Y. (1999). *Shear sensitivity*. In Flickinger M.C. and Drew S.W. *Encyclopedia of Bioprocess Technology: Fermentation, Biocatalysis and Bioseparation*. (pp. 2379-2406). New York:Wiley.
- Chiu, Z.C, Chen, M.Y., Lee, D.J., Tay, S.T.L. and Show, K.Y. (2006). Diffusivity of Oxygen in Aerobic Granules. *Biotechnology and Bioengineering*. 94 (3), 505-513.
- Chudoba, J. (1995). Control of Activated Sludge Filamentous Bulking. *Water Research*. 19, 10-17.
- Crocetti, G.R, Banfield, J.F., Keller, J., Bond, P.L. and Blackall, L., (2008). Glycogen-Accumulating Organisms in Laboratory-scale and Full-scale Wastewater Treatment Processes. *Microbiology*. 148, 3353-3364.
- Dangcong, P., Bernet, N., Delgenes, J.P. and Moletta, R. (1999). Aerobic Granular Sludge – a Case Report. *Water Research*. 33(3), 890-893.
- de Bruin, L.M.M., de Kreuk, M.K., van der Roest, H.F.R., van Loosdrecht, M.C.M. and Uijterlinde, C. (2004). Aerobic Granular Sludge Technology, Alternative for Activated Sludge Technology ? *Water Science and Technology*. 49 (11-12), 1-9.
- de Bruin, L.M.M., van der Roest ,H.F.R, de Kreuk, M.K., van Loosdrecht, M.C.M. and Uijterlinde, C. (2005). *Promising Results of Pilot Research:Aerobic Granular Sludge Technology at WWTP Ede*. In Bathe S, de Kreuk M.K., McSwain B.S. and Schwarzerbenck N. *Aerobic Granular Sludge*. (pp.135-142) London: IWA Publishing.
- de Kreuk, M.K. and van Loosdrecht, M.C.M. (2004). Selection of Slow Growing Organisms as a Means for Improving Aerobic Granular Sludge Stability. *Water Science and Technology*. 9 (11-12), 9-19.
- de Kreuk, M.K., Heijnen, J.J. and van Loosdrecht, M.C.M. (2005) Simultaneous COD, Nitrogen and Phosphate removal by Aerobic Granular Sludge. *Biotechnology Bioengineering*. 90 (6), 761-769.

- de Kreuk, M.K. (2006). *Aerobic Granular Sludge – Scaling up a New Technology*. PhD Thesis. Delft University of Technology, the Netherlands.
- de Kreuk, M.K. and van Loosdrecht, M.C.M. (2006). Formation of Aerobic Granules with Domestic Sewage. *Environmental Engineering, -ASCE*. 132 (6).
- di Iaconi, C., Ramadori, R., Lopez, A., and Passino, R. (2005). Hydraulic Shear Stress Calculation in a Sequencing Batch Biofilm Reactor with Granular Biomass. *Environmental Science and Technology*. 39, 889-894.
- Donaldson, W. (1923) Use of Activated Sludge Increasing. *Civil Engineering*. 2(3), 167-169.
- Drews, A., Evenblij, H., Rosenberger, S. (2005). Potential and Drawbacks of Microbiology-Membrane Interaction in Membrane Bioreactors. *Environmental Progress*. 24 (4), 426-433.
- Dulekgurgen, E., Ovez, S., Artan, N. and Orhon, D. (2003). Enhanced Biological Phosphate Removal by Granular Sludge in a Sequencing Batch Reactor. *Biotechnology Letters*. 25 (9), 687-693.
- Elenter, D., Milferstedt, K., Zhang, W., Hausner, M., and Morgenroth, E. (2007). Influence of Detachment on Substrate Removal and Microbial Ecology in a Heterotrophic/Autotrophic Biofilm. *Water Research*. 41 (20), 4657-4671.
- Etterer, T. and Wilderer, P.A. (2001). Generation and Properties of Aerobic Granular Sludge. *Water Science and Technology*. 43, 19-26.
- Fang, H.H.P. and Chui, H.K. (1993). Maximum COD Loading Capacity in UASB Reactors at 37 °C. *Environmental Engineering*. 119, 103-119.
- Fox, S.L., Brehm, M. A., Robertson, E. P., Jackson, J. D., Thomas, C. P. and Bala, G. A. (1993). Comparative Analysis of Microbially Mediated Oil Recovery by Surfactants Produced by *Bacillus licheniformis* and *Bacillus subtilis*. *Microbial Enhancement of Oil Recovery-Recent Advances*. 39, 143-150.
- Gander M., Jefferson B. and Judd S. (2000). Aerobic MBRs for Domestic Wastewater Treatment: A Review with Cost Considerations. *Separation and Purification Technology*. 18 (2), 119-130.
- Ghangrekar, M.M., Asolekar, S.R, Ranganathan, K.R. and Joshi, S.G. (1996). Experience with UASB Reactor Start-Up Under Different Operating Conditions. *Water Science and Technology*. 34 (5-6), 421-428.

- Ghangrekar, M.M., Asolekar, S.R. and Joshi, S.G. (2005). Characteristics of Sludge Developed Under Different Loading Conditions during UASB Reactor Start-up and Granulation. *Water Research*. 39, 1123-1133.
- Gjaltema, A., Tijhuis L., van Loosdrecht, M.C.M. and Heijnen J.J. (1997). Detachment of Biomass from Suspended Non-growing Spherical Biofilms in Airlift Reactors. *Biotechnology Bioengineering*. 45, 258-269.
- Grotenhuis, J.T.C, van Lier, J.B, Plugge, C.M, Stams, A.J.M and Zehnder, A.J.B. (1991). Effect of Ethylene Glycol-bis (h-aminoethylether)-N, N-tetraacetic acid (EGTA) on Stability and Activity of Methanogenic Granular Sludge. *Applied Microbiology Biotechnology*. 36, 109-114.
- Guo, J., Yang, Q., Wang, S., Yang, A. and Bo, F. (2007).Advanced Nitrogen Removal using Pilot-Scale SBR with Intelligent Control System built in Three Layer Network. *Frontiers of Environmental Science and Engineering in China*. 1 (1), 33-38.
- Hastings, J.J., Rhodes, D., Fellerman, A.S., Mckendrick, D. and Dixon, C. (2007). New Approaches for Sludge Management. *Powder Technology*. 1-2 (174), 18-24.
- Hong, C.C., Chin, S-K, and Shim, H. (2007). Effect of Chloride on Biological Nutrient Removal from Wastewater. *Applied Sciences in Environmental Sanitation*. 3 (2), 85-92.
- Inizan, M., Freval, A., Cigana, J. and Meinhold, J. (2004). Aerobic Granulation in Sequencing Batch Reactor for Industrial Wastewater Treatment, IWA *World Water Congress & Exhibition 2004*. 19-25 September. Marrakech, Morocco.
- Irvine, R.L. and Ketchum, L.H. (1989). Sequencing Batch Reactors for Biological Wastewater Treatment. *Critical Reviews in Environmental Control*. 18 (4), 255-294.
- Jenkins, D., Richard M.G. and Daigger, G.T. (1993). *Manual on the Causes and Control of Activated Sludge Bulking and Foaming*. (2nd ed.) Boca Raton, FL: Lewis Publishers.
- Jang, A., Yoon, Y.H., Kim, I.S., Kim, K.S. and Bishop, P.L. (2003) Characterization and Evaluation of Aerobic Granules in Sequencing Batch Reactor. *Biotechnology*. 105, 71-82.

- Jeyanayagam, S. and Venner, I. (2007). Wastewater Process Design with Energy Savings in Mind. *Florida Water Resources*. January 2007, 30-33.
- Jiang, H.L., Tay, J.H. and Tay, S.T.L. (2002). Aggregation of Immobilized Activated Sludge Cells into Aerobically Grown Microbial Granules for the Aerobic Biodegradation of Phenol. *Letters in Applied Microbiology*. 35 (5), 439-445.
- Jiang, H.L., Tay, J.H., Liu, Y. and Tay, S.T.L. (2003). Ca²⁺ Augmentation for Enhancement of Aerobically Grown Microbial Granules in Sludge Blanket Reactors. *Biotechnology Letter*. 25, 95-99.
- Jiang, H.L., Tay, J.H. and Tay, S.T.L. (2004) Changes in Structure, Activity and Metabolism of Aerobic Granules as Microbial Response to High Phenol Loading. *Applied Microbial Biotechnology*. 63, 602-608.
- John, G.H., Noel, R.K., Peter, H.A.S, James, T.S. and Stanley, T.W. (1994). *Bergey's Manual of Determinative Bacteriology*. (9th Edition). USA : Williams & Wilkins.
- Kaewpipat, K., and Grady, Jr C.P.L. (2002). Population Dynamics in Laboratory-Scale Activated Sludge Reactors. *Water Science and Technology*. 46 (1-2), 19-27.
- Kambourova, M., Tangney, M. and Priest, F. G. (2001). Regulation of Polyglutamic Acid Synthesis by Glutamate in *Bacillus licheniformis* and *Bacillus subtilis*. *Applied and Environmental Microbiology*, 67, 1004-1007.
- Kappeler, J. and Gujer, W. (1994). Verification and Application of a Mathematical Model for "Aerobic Bulking". *Water Research*. 28 (2), 311-322.
- Katja, H. and Mika, S. (2007). Flocculation in Paper and Pulp Mill Sludge Process. *Research Journal of Chemistry and Environment*. 11 (3), 96-103.
- Khrutkova, O., Ruzickova, I., and Wanner, J. (2002). Microbial Evaluation of Activated Sludge and Filamentous Population at Eight Czech Nutrient Removal Activated Sludge Plants during Year 2000. *Water Science and Technology*. 46 (1/2), 471-478.
- Krishna, C. and van Loosdrecht, MCM. (1999). Effect of Temperature on Storage Polymers and Settability of Activated Sludge. *Water Research*. 33 (1), 2374-2382.
- Lester J.N. and Birkett J.W. (1999). *Microbiology and Chemistry for Environmental Scientists and Engineers* (2nded.). London : E & FN Spon.

- Lettinga, G., van Velsen, A.F.M., Hobma, S.W., de Zeeuw, W. and Klapwijk A. (1980). Use of the Upflow Sludge Blanket (USB) Reactor Concept for Biological Wastewater Treatment, Especially for Anaerobic Treatment. *Biotechnology Bioengineering*. 22, 699-734.
- Li, X.M., Yang, Q., Zeng, G.M., Liao, M.F., and Wu Y.M., (2005). Simultaneous Phosphorus and Nitrogen Removal by Aerobic Granular Sludge in Single SBR system. In Bathe S, de Kreuk M.K., McSwain B.S. and Schwarzerbenck N. *Aerobic Granular Sludge*. (pp 71-78). London: IWA Publishing.
- Lin, Y.M., Liu, Y. and Tay, J.H. (2003). Development and Characteristics of Phosphate Accumulating Microbial Granules in Sequencing Batch Reactors. *Applied Microbiology Biotechnology*. 62, 430-435.
- Liu, Y. and Tay, J.H. (2002). The Essential Role of Hydrodynamic Shear Force in the Formation of Biofilm and Granular Sludge - Review. *Water Research*. 36 (7), 1653-1665.
- Liu, Y. and Tay, J.H. (2004). State of the Art of Biogranulation Technology for Wastewater Treatment. *Biotechnology Advances*. 22 (7), 533-563.
- Liu, Q.S., Tay, J.H. and Liu, Y. (2003a). Substrate Concentration-Independent Aerobic Granulation in Sequential Aerobic Sludge Blanket Reactor. *Environmental Technology*. 24, 1235-43.
- Liu, Y., Lin, Y.M., Yang, S.F. and Tay, J.H. (2003b). A Balanced Model for Biofilms Developed at Different Growth and Detachment Forces. *Process Biochemistry*. 38, 1761-1765.
- Liu Y., Yang S.F. and Tay J.H. (2003c). Elemental Compositions and Characteristics of Aerobic Granules Cultivated at Different Substrate N/C Ratios. *Applied Microbiology Biotechnology*. 61, 556-561.
- Liu, Q.S., Yang S.F. and Tay J.H. (2004). Improved Stability of Aerobic Granules by Selecting Slow Growing Nitrifying Bacteria. *Biotechnology*. 108 (2), 161-169.
- Lodi, A., Solisoio, C., Converti, A. and Del Borghi, M. (1998). Cadmium, Zinc, Copper, Silver and Chromium (III) Removal From Wastewaters by *Sphaerotilus Natans*. *Bioprocess Engineering*. 19, 197-203.
- Marilyn, N. (2003). Explaining the Activated Sludge Process. *PIPELINE*. 14, 1-7.

- Margarita, L.M., Stackebrandt, H.H.E., Nadezhda, A.K, Nikolai, A.C, Christian, J.T.N., Belyanov, S.S., Bonch-Osmolovskaya, E.A. (2001). Isolation and Characterization of *Thermococcus sibiricus* sp. nov. From a Western Siberia High-Temperature Oil Reservoir. *Extremophiles*. 5, 85-91.
- Martins, A.M.P., Pagilla, K., Heijnen, J.J., van Loosdrecht, M.C.M (2004). Filamentous Bulking Sludge – A Critical Review. *Water Research*. 38 (4), 793-817.
- McSwain, B.S., Irvine, R.L. and Wilderer, P.A. (2004). The Effect of Intermittent Feeding on Aerobic Granule Structure. *Water Science and Technology*. 49(11), 19-25.
- McSwain, B. S., Irvine, R.L., Hausner, M. and Wilderer, P.A. (2005). Composition and Distribution of Extracellular Polymeric Substances in Aerobic Flocs and Granular Sludge. *Applied Environmental Microbiology*. 71, 1051-1057.
- Metcalf and Eddy (2003). *Wastewater Engineering: Treatment and Reuse*. (4th ed.). New York : McGraw-Hill.
- Mino, T., van Loosdrecht, M.C.M. and Heijnen, J.J., (1998). Microbiology and Biochemistry of the Enhanced Biological Phosphate Removal Process. *Water Research*. 32 (11), 3191 – 3207.
- Mishima, K. and Nakamura M. (1991). Self Immobilization of Aerobic Activated Sludge – a Pilot Study of the Aerobic Upflow Sludge Blanket Process in Municipal Sewage Treatment. *Water Science and Technology*. 23, 981-990.
- Morgenroth, E., Sherden, T., van Loosdrecht, M.C.M., Heijnen, J.J. and Wilderer, P.A. (1997). Aerobic Granular Sludge in a Sequencing Batch Reactor. *Water Research*. 31 (12), 3191-3194.
- Morgenroth, E. and Wilderer P.A. (2000). Controlled Biomass Removal – The Key Parameter to Achieve Enhanced Biological Phosphorus Removal in Biofilm Systems. *Microbial Ecology of Biomass: Concepts, Tools and Applications*, 15-18 September. Lake Bluff, Illinois, USA, IAWQ,365-375.
- Morvai, L., Mihaltz, P. and Czako, L.(1992). The Kinetic Basis of a New Start-up Method to Ensure the Rapid Granulation of Anaerobic Sludge. *Water Science and Technology*. 25,113-22.

- Mosquera-Corral, A., Vazquez-Padin, J.R., Arrojo, B., Campos, J.L. and Mendez, R. (2005). *Nitrifying Granular Sludge in a Sequencing Batch Reactor*. In Bathe S, de Kreuk, M.K., McSwain, B.S. and Schwarzerbenck, N. *Aerobic Granular Sludge*. (pp. 63-70). London: IWA Publishing.
- Moy, B.Y.P., Tay J.H., Toh S.K., Liu Y. and Tay S.T.L. (2002). High Organic Loading Influences the Physical Characteristics of Aerobic Sludge Granules. *Letters in Applied Microbiology*. 34, 407-412.
- Mulder, R., Vereijken, T., Frijters, C., and Vellinga, S.H.J. (2001). Future Perspectives in Bioreactor Development. *Water Science and Technology*. 44 (8), 27-32.
- Nancharaiah, Y.V., Joshi, H.M, Krishna Mohan T.V, Venugopalan, V.P, Sevilimedu, V. and Narasimhan, S.V.(2008). Formation of Aerobic Granules in the Presence of a Synthetic Chelating Agent. *Environmental Pollution*. 153, 37-43.
- Nicollela, C., van Loosdrecht, M.C.M. and Heijnen, J.J. (2000). Particle-Based Biofilm Reactor Technology. *TIBTECH*. July 18, 312 -320.
- Ohashi, A. and Harada, H. (1994). Adhesion Strength of Biofilm Developed in an Attached-Growth Reactor. *Water Science and Technology*. 29, 10-18.
- Osborn, D.W., Lotter L.H., Pitman, A.R. and Nicholls, H.A. (1986) Enhancement of Biological Phosphate Removal by Altering Process Feed Composition. *Water Research Commission Report*. No. 137/1/86. Pretoria, South Africa
- Palm, J.C., Jenkins, D. and Parker, D.S (1980). Relationship Between Organic Loading, Dissolved Oxygen Concentration and Sludge Settleability in the Completely Mixed Activated Sludge Process. *Journal Water Pollution Control Federal*. 52, 2484-2506.
- Pastor, L., Marti, N., Bouzas, A. and Seco, A. (2008). Sewage Sludge Management for Phosphorus Recovery as Struvite in EBPR Wastewater Treatment Plants. *Bioresource Technology*. 11 (99), 4817-4824.
- Peng, D., Bernet, N., Delgenes, J.P. and Moletta, R. (1999). Aerobic Granular Sludge-A Case Report. *Water Research*. 33, 890-893.
- Pitt, P. and Jenkins, D. (1990). Causes and Control of *Nocardia* in Activated Sludge. *Journal Water Pollution Control Federation*. 62 (2), 143-150.

- Pochana, K. and Keller, J. (1999) Study of Factors Affecting Simultaneous Nitrification and Denitrification (SND). *Water Science and Technology*. 39 (6), 61-68.
- Poon, C.P.C. (1972). Control Factors in Bubble Aeration. *Water, Air and Soil Pollution*. 1, 275-285.
- Pratt, S., Michael, T., Daniel, G. and Shilton, A. (2007). Development and Examination of a Granular Nitrogen-Fixing Wastewater Treatment System. *Process Biochemistry*. 42, 863-872.
- Qin, L., Liu Y. and Tay J.H. (2004a). Effect of Settling Time on Aerobic Granulation in Sequencing Batch Reactor. *Biochemical Engineering*. 21(1), 47-52.
- Qin, L., Tay, J.H. and Liu, Y. (2004b). Selection Pressure is a Driving Force of Aerobic Granulation in Sequencing Batch Reactors. *Process Biochemistry*. 39, 579-84.
- Quarmby, J. and Forster, C.F. (1995). An Examination of the Structure of UASB Granules. *Water Research*. 29, 2449-2454.
- Ramakrishnan, A. and Gupta, S.K., (2006). Anaerobic Biogranulation in a Hybrid Reactor Treating Phenolic Waste. *Hazardous Material*. 3 (137), 1488-1495.
- Richard, M. (2003). Activated Sludge Microbiology Problems and Their Control. *The 20th Annual USEPA National Operator Trainers Conference*. 8 June. Buffalo, NY, 1-21.
- Satoh, H., Nakamura, Y., Ono, H. and Okabe, S. (2003). Effect of Oxygen Concentration on Nitrification and Denitrification in Single Activated Sludge Flocs, *Biotechnology Bioengineering*. 58 (1), 101-116.
- Schmidt J.E. and Ahring, B.K. (1996). Granular Sludge Formation in Upflow Anaerobic Sludge Blanket (UASB) Reactors. *Biotechnology Bioengineering*. 49, 229-46.
- Schwarzenbeck, N., Erley R. and Wilderer P.A. (2004). Aerobic Granular Sludge in an SBR System Treating Wastewater Rich in Particulate Matter. *Water Science and Technology*. 49 (11-12), 41-46.
- Shin, H.S., Lim, K.H. and Park, H.S. (1992). Effect of Shear Stress on Granulation in Oxygen Aerobic Upflow Sludge Reactors. *Water Science and Technology*. 26, 601-605.
- Sourirajan, S. (1977). Reverse Osmosis and Synthetic Membranes: Theory, Technology, Engineering. National Research Council of Canada, Ottawa.

- Sun, F.Y., Yang C.Y., Li, J.Y. and Yang, Y.J. (2006). Influence of different substrates on the formation and characteristics of aerobic granules in sequencing batch reactors. *Journal of Environmental Sciences*, 18 (5), 864-871.
- Sunil, S.A., Cheng, H.C. and Duu, J.L., (2008). Hydraulic Characteristics of Aerobic Granules using Size Exclusion Chromatography. *Biotechnology Bioengineering*. 99 (4), 791-799.
- Taniguchi, J., Hemmi, H., Tanahashi, K., Amano, N., Nakayama, T. and Nishim, T. (2000). Zinc Biosorption by a Zinc-Resistant Bacterium, *Brevibacterium* sp. Strain, HZM-1. *Applied Microbiology Biotechnology*. 54, 581-588.
- Tay, J.H., Liu, Q.S. and Liu, Y. (2001a). Microscopic Observation of Aerobic Granulation in Sequential Aerobic Sludge Blanket Reactor. *Applied Microbiology*. 91, 168-175.
- Tay, J.H., Liu, Q.S. and Liu, Y. (2001b). The Effects of Shear Force on the Formation, Structure and Metabolism of Aerobic Granules. *Applied Microbiology Biotechnology*. 57, 227-233.
- Tay, J.H., Liu, Q.S. Liu, Y. (2001c). The Role of Cellular Polysaccharides in the Formation and Stability of Aerobic Granules. *Letter Applied Microbiology*. 33, 222-226.
- Tay, J.H., Liu, Q.S. and Liu, Y. (2002a). Aerobic Granulation in Sequential Sludge Blanket Reactor. *Water Science and Technology*. 46, 13-8.
- Tay, J.H., Yang, S.F. and Liu, Y. (2002b). Hydraulic Selection Pressure-Induced Nitrifying Granulation in Sequencing Batch Reactor. *Applied Microbiology Biotechnology*. 9, 332-337.
- Tay, J.H., Liu, Q.S., Liu, Y. (2002c). Characteristics of Aerobic Granules Grown on Glucose and Acetate in Sequential Aerobic Sludge Blanket Reactors. *Environmental Technology*. 23, 931-936.
- Tay, J.H., Tay, S.T.L., Ivanov, V., Pan, S., and Liu, Q.S., (2003a). Biomass and Porosity Profile in Microbial Granules Used for Aerobic Wastewater Treatment. *Letter Applied Microbiology*. 36, 297-301.
- Tay, J.H., Liu, Q.S, and Liu Y. (2003b). Shear Force Influences the Structure of Aerobic Granules Cultivated in Sequencing Batch Reactor. *5th International Conference on Biofilm Systems*, 14-19 September. Cape Town, South Africa.

- Tay, J.H., Liu, Q.S. and Liu, Y. (2004). Selection Pressure is a Driving Force of Aerobic Granulation in sequencing batch reactor. *Applied Microbiology*. 91, 168-175.
- Tay, J.H., Liu, Q.S., Liu, Y., Show, K.Y., Ivanov, V. and Tay, S.T.L. (2005). A Comparative Study of Aerobic Granulation in Pilot-and Laboratory-Scale SBAR. In Bathe S, de Kreuk M.K., McSwain B.S. and Schwarzerbenck N. *Aerobic Granular Sludge*. (pp. 125-133). London: IWA Publishing.
- Tay, J.H., Tay, S.T.L., Yu, L., Yeow, S.K. and Ivanov, V. (2006) *Biogranulation Technologies for Wastewater Treatment*. (1st ed.). Oxford, UK: Elsevier
- Tharek, M., Ibrahim, Z., Hamzah, S.H., Markum, N., Mohd-Aris, A., Daud, F.N., Md-Salleh, M., Yahya, A., Wai, L.C., Khairuddin, N., Illias, R., Omar, M.I., Foo, K.S., Ezrin Elias, J. and Bailey, S.. (2006). Isolation, Screening and Characterization of Soluble Exopolymer-Producing Bacteria For Enhanced Oil Recovery. *Proceeding of the 1st Regional Postgraduate Conference on Engineering and Science*, Universiti Teknologi Malaysia, 26th-27th July 2006.
- Third, K.A., Burnett, N. and Cord, R.R. (2003). Simultaneous Nitrification and Denitrification Using Stored Substrate (PHB) as the Electron Donor in an SBR. *Biotechnology Bioengineering*. 44 (5), 595-608.
- Tijhuis, L., Rekswinkel, E, van Loosdrecht, M.C.M and Heijnen, J.J. (1994). Dynamics of Population and Biofilm Structure in the Biofilm Airlift Suspension Reactor for Carbon and Nitrogen Removal. *Water Science and Technology*. 29 (10-11), 377-384.
- Toh, S.K., Tay, J.H., Moy, B.Y.P, Ivanov, V. and Tay, S.T.L. (2003). Size-Effect on the Physical Characteristics of the Aerobic Granule in a SBR. *Applied Microbiology Biotechnology*. 60, 687-695.
- Trussell, R.S., Adham, S, and Trussel, R.R. (2005). Process Limits of Municipal Wastewater Treatment with the Submerged Membrane Bioreactor. *Environmental Engineering*. 131 (3), 410 -416.
- Tsuneda, S., Nagano, T., Hoshino, T., Ejiri, Y., Noda, N. and Hirata, A. (2003) Characterization of Nitrifying Granules Produced in An Aerobic Upflow Fluidized Bed Reactor. *Water Research*. 37, 4965-4973.

- Tsuneda, S., Ejiri, Y., Ogiwara, M., Nagano, T. and Hirata, A. (2005) Characteristics and Applicability of Nitrifying Granules Produced in an Aerobic Upflow Fluidized Bed Reactor. In Bathe S, de Kreuk, M.K., McSwain, B.S. and Schwarzerbenck, N. *Aerobic Granular Sludge*. (pp.15-24) London: IWA Publishing.
- Tuah, P.M. (2006). *The Performance of Phenol Biodegradation by Candida tropicalis RETL-CrL using Batch and Fed-Batch Fermentation Techniques*. Phd Thesis. Unversiti Teknologi Malaysia.
- Ujang, Z. and Anderson, G.K. (1996). Application of Low-Pressure Reverse Osmosis for Zn^{2+} and Cu^{2+} Removal from Wastewater. *Water Science and Technology*. 38(4-5), 521-528.
- Ujang, Z. and Anderson G.K. (2000). Effect of the Operating Parameters on the Separation of Metal Chelates Using Low Pressure Reverse Osmosis Membrane (LPROM). *Water Science and Technology*. 41(10-11), 135-142.
- Ujang, Z., Ng, S.S. and Nagaoka, H. (2005a) Package Plant of Extended Aeration Membrane Reactors: A study on Aeration Intensity and Biofouling Control. *Water Science and Technology*. 51 (10), 97-104.
- Ujang, Z., Hamdzah, M. and Ozaki, H. (2005b) Reverse Osmosis for Micropollutant Rejection: The Effects of Low Pressure System. *Water Malaysia*. 10 (August 2005), 33-36.
- Ujang, Z. (2005c) Applications of Continuous Submerged MF followed by RO Membrane for Wastewater Reclamation. *Water Malaysia*. 10 (August 2005), 21-31.
- Ujang, Z., Ng, K.S., Tg Hazmin, T.H., Roger, P., Ismail, M.R., Shahabudin, S.M. and Abdul Hamid, M.H. (2007). Application of Immersed MF (IMF) Followed by Reverse Osmosis (RO) Membrane for Wastewater Reclamation: A Case Study in Malaysia. *Water Science and Technology*. 56 (9), 103–110
- Valdman, E. and Leite, S.G.F. (2000). Biosorption of Cd, Zn and Cu by *Saragssum* sp. Waste Biomass. *Bioprocess Engineering*. 22, 171-173.
- van Aalst-Van Leeuwen, M.A., Pot, M.A., van Loosdrecht, M.C.M. and Heijnen, J.J.(1997). Kinetic Modeling of Poly-B- hydroxybutyrate : Production and Consumption by *Paracoccus Pantotrophus* under Dynamic Substrate Supply. *Biotechnology Bioengineering*. 55 (5), 773-782.

- van Benthum, W.A.J., van Loosdrecht, M.C.M. and Heijnen, J.J. (1996). Control of Heterotrophic Layer Formation on Nitrifying Biofilms in a Biofilm Airlift Suspension Reactor. *Biotechnology Bioengineering*. 53 (4), 397-405.
- van Loosdrecht, M.C.M. and Heijnen J.J. (1993). Biofilm Bioreactors for Wastewater Treatment. *Trends Biotechnology*. 11, 117-121.
- van Loosdrecht, M.C.M., Eikelboom, D.H., Gijzelma A., Mulder, A., Tijhuis, L. and Heijnen J.J. (1995). Biofilm Structures. *Water Science and Technology*. 32 (8), 35-43.
- van Loosdrecht, M.C.M., Hooijmans C.M., Brdjanovic D. and Heijnen J.J. (1997). Biological Phosphate Removal Processes. *Applied Microbiology Biotechnology*, 48 (3), 289 - 296.
- Van 't Riet, K. and Tramper, J. (1991). *Basic Reactor Design*. New York : Marcel Dekker, Incorporation.
- Villasenor, J.C., van Loosdrecht, M.C.M., Picioreanu, C. and Heijnen, J.J. (2000). Influence of Different Substrates on the Formation of Biofilms in a Biofilm Airlift Suspension Reactor. *Water Science and Technology*. 41(4 - 5), 323-330.
- Vishniac, W. and Santer, M. (1975). The Thiobacili. *Bacteriology Revision*. 21,195 - 213.
- Verschuren, P.G. and van den Heuvel, J.C. (2002). Substrate Controlled Development of Anaerobic Acidifying Aggregates at Different Shear Rates in a Gas Lift Reactor. *Biotechnology Bioengineering*. 77 (3), 306-315.
- Wang, W., Jung, Y.J., Kiso Y., Yamada, T. and Min K.S. (2006). Excess Sludge Reduction Performance of an Aerobic SBR process Equipped with a Submerged Mesh Filter Unit. *Process Biochemistry*. 4 (41), 745-751.
- Wilderer, P.A., Irvine R.L. and Goronszy, M.C. (2000). *A Sequencing Batch Reactor Technology*. Colchester, UK : IWA Publishing.
- Willey, J.W., Sherwood, L.M., and Woolverton, J.C. (2008). *Microbiology*. (7th ed.) New York : McGraw-Hill.
- Xie, S. (2003). *Metabolic Response of Aerobic Granules to Chromium (III)*. Final year report of Bachelor of Engineering Singapore, Nanyang Technological University.
- Yang, S.F., Tay, J.H. and Liu Y. (2003a) Effect of Substrate N/COD Ratio on the Formation of Aerobic Granules. *Journal Biotechnology*. 106, 87-97.

- Yang, S.F., Liu, Y. and Tay, J.H. (2003b). A Novel Granular Sludge Sequencing Batch Reactor for Removal of Organic and Nitrogen from Wastewater. *Journal Biotechnology*. 106, 77-86.
- Yang ,S.F., Liu Q.S., Tay, J.H. and Liu, Y. (2004). Growth Kinetics of Aerobic Granules Developed in Sequencing Batch Reactors. *Letter Applied Microbiology*. 38, 106-112.
- Zeng, P., Zhuang, W.Q., Tay, S.T.L. and Tay, J.H. (2007). The Influence of Storage on the Morphology and Physiology of Phthalic Acid-Degrading Aerobic Granules. *Chemosphere*. 69, 1751-1757.
- Zheng, Y.M., Yu, H.Q., and Sheng, G.P. (2005). Physical and Chemical Characteristics of Granular Activated Sludge from a Sequencing Batch Airlift Reactor. *Process Biochemistry*. 40, 645-650.
- Zheng, Y.M. and Yu, H.Q. (2007). Determination of the Pore Size Distribution and Porosity of Aerobic Granules using Size-Exclusion Chromatography. *Water Research*. 41, 39-46.
- Zhu, J. and Wilderer, P.A. (2003). Effect of Extended Idle Conditions on Structure and Activity of Granular Activated Sludge. *Water Research*. 37, 2013-2018.
- Zitomer, D.H., Duran, M., Albert, R. and Guven, E. (2007). Thermophilic Aerobic Granular Biomass for Enhanced Settleability. *Water Research*. 41, 819-825.