STUDIES ON PERFORMANCE OF STANDARD AND NON-STANDARD CONFIGURATIONS OF FRANKLIN AIR TERMINALS

ONG LAI MUN

A thesis submitted in fulfilment of the requirements for the award of the degree of Master of Engineering (Electrical)

> Faculty of Electrical Engineering Universiti Teknologi Malaysia

> > FEBRUARY 2006

To The LORD Jesus, whose grace and mercy is unfailing. My late mother, who loved me as who I am. My father, who taught me discipline.

ACKNOWLEDGEMENT

My greatest gratitude goes out to my supervisor and mentor, Prof. Dr. Hussein Ahmad for offering me the opportunity to pursue my Master Degree in the field that I love- lightning. Also want to thank him for the invaluable advice, guidance and support given to me throughout the progress of this research.

I also want to take this opportunity to thank Encik Anuar, IVAT's laboratory technician for spending his precious time in teaching me about laboratory equipments and for helping me a great deal in accomplishing my laboratory work. Not forgetting is also my appreciation to Encik Mohd. Irfan Jambak and Encik Abu Bakar for giving me a hand whenever I need it. My appreciation also goes out to IVAT's staff for their support and help.

In addition, I would like to acknowledge my parents' support, encouragement and care. If not for their sacrifice and understanding, especially my late mother, I would not be able to pursue this degree wholeheartedly.

Last but not least, I would like to thank all those who are involved directly or indirectly in helping me to complete this research.

THANK YOU.

ABSTRACT

Buildings installed with 200-year-old Franklin rods were reportedly damaged when struck by lightning. When intercepted by lightning, air terminals may also be damaged or physically changed in its tip configurations. In such cases, it is crucial to determine whether the damaged lightning air terminal can still perform as an effective lightning protection system. This research aims to investigate the performance of different tip configuration of air terminals after being struck by lightning. Six different rod tip configurations-sharp, blunt, standard, concave, flat and conical shape rod tip were tested in the laboratory. Two stages of tests were carried out. The first stage of tests was carried out under the application of impulse voltages only and without the pre-ionization condition to simulate the approach of a downward leader. The second stage involved the application of DC and UV radiations to ionize the tip prior to applying impulse voltages. In both conditions, two sets of individual tests and competitive tests were carried out for all air terminals. The individual test is for obtaining the breakdown voltage and the timeto-breakdown. The number of strikes per air terminal were recorded when pairs of air terminals were subjected to competitive tests. During competitive tests in preionization condition, corona was observed at the tips. The flat and concave rods were found to have high formation of corona which results in higher breakdown voltage. The result also shows that the blunt rod is the best performance rod over the others, having the most consistent breakdown voltage and time-to-breakdown in both non-ionized and pre-ionized tips. It is learnt that pre-ionization condition should be adopted when testing air terminals in laboratory to obtain more reliable results as it is able to simulate the condition almost similar to the real lightning condition.

ABSTRAK

Bangunan yang dipasang Franklin rod yang mempunyai sejarah 200 tahun dilaporkan mengalami kerosakan selepas dipanah kilat. Apabila rod pelindung kilat menyambut kilat, rod berkenaan mungkin mengalami kerosakan dan berubah dari segi rupa bentuk. Maka, adalah mustahak untuk menentukan jika rod tersebut masih dapat berfungsi sebagai sistem perlindungan kilat yang efektif. Penyelidikan ini adalah untuk menyiasat prestasi rod pelindung kilat yang mempunyai konfigurasi bucu yang berbeza selepas dipanah kilat. Enam konfigurasi berbeza iaitu tajam, bulat, piawai, pelbagai bucu, rata dan kon diuji di makmal voltan tinggi. Ujian peringkat pertama dijalankan dengan menggunakan hanya voltan impuls tanpa ionisasi untuk mengimitasi keadaan apabila kilat semakin hampir. Ujian peringkat kedua menggunakan aplikasi voltan DC dan radiasi UV untuk mengionisasi bucu rod pelindung kilat sebelum voltan impuls diaplikasikan. Untuk kedua peringkat tersebut, dua set ujian individu dan ujian persaingan dilaksanakan untuk semua rod. Ujian individu adalah untuk memperoleh voltan pecahtebat dan masa untuk pecahtebat. Ujian persaingan adalah untuk merekod jumlah panahan yang disambar oleh setiap rod dengan mengubah posisi setiap pasangan rod. Semasa ujian persaingan dalam keadaan pre-ionisasi, aktiviti korona diperhatikan di sekitar bucu rod. Rod rata dan rod pelbagai bucu mengalami paling banyak aktiviti korona mengakibatkan voltan pecahtebat yang lebih tinggi. Keputusan juga menunjukkan bahawa rod bulat mempunyai prestasi yang terbaik di antara semua rod dengan voltan pecahtebat dan masa untuk pecahtebat yang konsisten untuk kedua-dua keadaan ujian. Adalah difahamkan bahawa keadaan pre-ionisasi patut diaplikasikan semasa menguji rod di makmal untuk memperoleh keputusan yang lebih kukuh kerana dapat mengimitasi keadaan kejadian kilat yang sebenar. Kesimpulannya, ujian makmal ini telah membuktikan bahawa prestasi rod pelindung kilat sememangnya dipengaruhi oleh geometri bucunya dari segi ciri-ciri pecahtebat dan formasi korona.

TABLE OF CONTENTS

CHAPTER	TITLE	PAGE
	TITLE	i
	DECLARATION	ii
	DEDICATION	iii
	ACKNOWLEDGEMENT	iv
	ABSTRACT	v
	ABSTRAK	vi
	TABLE OF CONTENTS	vii
	LIST OF TABLES	xii
	LIST OF FIGURES	xiii
	LIST OF SYMBOLS	XV
	LIST OF APPENDINCES	xvi

1 INTRODUCTION

1.1	Background of study	1
1.2	Objective	5
1.3	Contributions of this thesis	6
1.4	Organization of work	8

2 REVIEW ON CURRENT PRACTICES FOR LIGHTNING PROTECTION SYSTEM

2.1	Lightr	ning Attachment Process	9
2.2	Lightr	ning Air Terminals	11
	2.2.1	Franklin Rod	12
		2.2.1.1 History of Franklin Rod	12
		2.2.1.2 Theories of Franklin Rod	14
		2.2.1.3 Conditions Necessary for the Initiation	
		of a Connecting Leader from the	
		Franklin Rod	15
		2.2.1.4 Ineffectiveness of Sharp Franklin Rod	16
	2.2.2	The Blunt Lightning Rod	18
		2.2.2.1 Introduction	18
		2.2.2.2 Criteria for Improved Lightning Rod	
		Configuration	19
		2.2.2.3 Configurations of the Blunt Rod	20
		2.2.2.4 Breakdown Process at the Blunt Rod	20
		2.2.2.5 Reasons Blunt Rod Is Better (Comparison	
		Between Sharp and Blunt)	21
	2.2.3	Early Streamer Emission (ESE) Devices	22
		2.2.3.1 Theories of ESE	22
		2.2.3.2 Reasons ESE Is Not More Distinguished	25
	2.2.4	Charge Transfer System (CTS) or Dissipation	
		Array System (DAS).	26
2.3	Summ	nary	27

3 RESEARCH METHODOLOGY

3.1	Introd	uction	28
3.2	Design	n of Air Terminals	30
	3.2.1	Justification of Designing Different Configuration	
		Dimensions	32

		3.2.1.1 Blunt	32
		3.2.1.2 Sharp	32
		3.2.1.3 Standard	33
		3.2.1.4 Conical	34
		3.2.1.5 Concave	35
		3.2.1.6 Flat	35
3.3	Labor	atory Tests	36
	3.3.1	Test of Air Terminals Without Pre-Ionization	
		(passive rods)	37
		3.3.1.1 Experimental Setup and Procedures	
		for Individual Test	38
		3.3.1.2 Experimental Setup and Procedures	
		for Competitive Test	39
	3.3.2	Test of Air Terminals With Pre-Ionization 41	
		3.3.2.1 Usage of D.C	42
		3.3.2.2 Usage of Ultra Violet (U.V)	43
		3.3.2.3 Usage of Impulse	44
		3.3.2.4 Experimental Setup and Procedures	
		for Individual Test	44
		3.3.2.5 Experimental Setup and Procedures	
		for Competitive Test and	
		Corona Observation	46
3.4	Summ	hary	48

4 **RESULTS AND DISCUSSION**

4.1	Introd	uction	49
4.2	Test o	f Air Terminals Without Pre-Ionization	51
	4.2.1	Results for Individual Test	51
		4.2.1.1 Set 1: Breakdown Voltage and	
		Time-to-Breakdown	51
		4.2.1.2 Set 2: Breakdown Voltage and	
		Time-to-Breakdown	52

	4.2.2	Discussion for Individual Test	54
		4.2.2.1 Comparison of Breakdown Voltage for	
		Set 1 and Set 2	54
		4.2.2.2 Comparison of Time-to-Breakdown for	
		Set 1 and Set 2	55
		4.2.2.3 Summary of Discussion for Individual	
		Test	56
	4.2.3	Results and Discussion for Competitive Test	57
4.3	Test o	f Air Terminals With Pre-Ionization	58
	4.3.1	Results of Individual Test	
		4.3.1.1 Set 1: Breakdown Voltage and	
		Time-to-Breakdown	58
		4.3.1.2 Set 2: Breakdown Voltage and	
		Time-to-Breakdown	59
	4.3.2	Discussion for Individual Test	60
		4.3.2.1 Comparison of Breakdown Voltage for	
		Set 1 and Set 2	60
		4.3.2.2 Comparison of Time-to-Breakdown for	
		Set 1 and Set 2	62
	4.3.3	Results and Discussion of Corona Observation	
		during Competitive Test	63
		4.3.3.1 General Discussion on Corona	63
		4.3.3.2 Blunt	65
		4.3.3.3 Standard	66
		4.3.3.4 Sharp	66
		4.3.3.5 Conical	67
		4.3.3.6 Concave	68
		4.3.3.7 Flat	69
		4.3.3.8 Summary on Corona Observation	70
	4.3.4	Results and Discussion for Competitive Test	72
4.4	Comp	arison and Discussion of Results for With and	
	Witho	out Pre-Ionization Test	73
	4.4.1	Comparison of Individual Test	74
	4.4.2	Comparison of Competitive Test	75

	4.4.3 Comparison of Corona Observation	75
4.5	Summary	76

5 CONCLUSION AND SUGGESTION

5.1	Conclusion	78
5.2	Suggestion	79

REFERENCES	81
Appendices A-E	84-186

xi

LIST OF TABLES

TITLE

TABLE NO

4.1	Breakdown voltage and time-to-breakdown for Set 1 without	
	pre-ionization	51
4.2	Breakdown voltage and time-to-breakdown for Set 2 without	
	pre-ionization	53
4.3	Comparison of breakdown voltage for Set 1 and 2 without	
	pre-ionization	54
4.4	Comparison of time-to-breakdown for Set 1 and 2 without	
	pre-ionization	55
4.5	Number and percentage of strikes for without pre-ionization	57
4.6	Breakdown voltage and time-to-breakdown for Set 1	
	with pre-ionization	58
4.7	Breakdown voltage and time-to-breakdown for Set 2 with	
	pre-ionization	59
4.8	Comparison of breakdown voltage for Set 1 and 2 with	
	pre-ionization	61
4.9	Comparison of time-to-breakdown for Set 1 and 2 with	
	pre-ionization	62
4.10	Summary of corona formation around tip of rod and its connection	
	with breakdown voltage	71
4.11	Results for competitive test with pre-ionization	72
4.12	Summary of individual test of air terminals under both	

4.13 Summary of the results and discussion for both conditions 76

conditions

PAGE

74

LIST OF FIGURES

FIGURES NO	D. TITLE	PAGE
1.1	Rainfall acidity in Malaysia for the year 2003	3
2.1	Conventional Franklin rod installed on buildings.	
	Inset: Close view of the rod.	14
2.2	Blunt rods used by C.B. Moore in real lightning condition	
	research	18
2.3	Different types of ESE devices	23
2.4	Example of DAS installed at telecommunication tower	26
3.1	Step-by-step approach to carry out research	29
3.2	Sketch of different configurations of air terminals. From left to	
	right: standard, sharp, blunt, flat, conical and concave.	31
3.3	Actual air terminals used in testing	31
3.4	Dimensions of blunt rod (quoted in mm)	32
3.5	Dimensions of sharp rod (quoted in mm)	33
3.6	Dimensions of standard rod (quoted in mm)	34
3.7	Dimensions of conical rod (quoted in mm)	34
3.8	Dimensions of concave rod (quoted in mm)	35
3.9	Dimensions of flat rod (quoted in mm)	36
3.10	Setup for individual test (without pre-ionization)	39
3.11	Competitive method of testing via interchanging air terminals to)
	obtain number of strikes per air terminal (without pre-ionization	a) 40
3.12	Setup for individual test (with pre-ionization)	45
3.13	Setup for competitive test (with pre-ionization)	47

4.1	Step-by-step approach to present and discuss results according		
	to tests	50	
4.2	Analysis of breakdown voltage and time-to-breakdown for		
	Set 1 without pre-ionization	52	
4.3	Analysis of breakdown voltage and time-to-breakdown for		
	Set 2 without pre-ionization	53	
4.4	Analysis of comparison of breakdown voltage for Set 1		
	and Set 2 without pre-ionization	54	
4.5	Analysis of average time-to-breakdown for Set 1		
	and Set 2 without pre-ionization	56	
4.6	Analysis of breakdown voltage and time-to-breakdown for Set 1		
	with pre-ionization	59	
4.7	Analysis of breakdown voltage and time-to-breakdown for Set 2		
	with pre-ionization	60	
4.8	Analysis of comparison of breakdown voltage for Set 1 and		
	Set 2 with pre-ionization	61	
4.9	Analysis of average time-to-breakdown for Set 1 and		
	Set 2 with pre-ionization	62	
4.10	Negative corona mode	64	
4.11	Ring discharge around the tip of standard rod. Inset: Standard rod	66	
4.12	Tip discharge at sharp rod. Inset: Sharp rod	67	
4.13	Strong concentrated point discharge at conical rod.		
	Inset: Conical rod	68	
4.14	4 points of discharge and strong streams of discharges from		
	concave tip. Inset: Concave rod	69	
4.15	5 points of discharge from flat tip. Strong streams of discharges.		
	Inset: Flat rod	70	

LIST OF SYMBOLS

CG	-	cloud-to-ground lightning
CTS	-	Charge Transfer System
DAS	-	Dissipation Array System
DIA.	-	diameter
DIAS	-	Digital Impulse Analyzing System
ESE	-	Early Streamer Emission
kV/m	-	electric field strength on ground
LAT	-	Lightning air terminal
LPS	-	Lightning protection system
mb	-	milibar (pressure)
MMS	-	Malaysian Meteorological Service
MV/m	-	electric field strength at extremities
n	-	total impulse application
n _b	-	total number of breakdowns
n _w	-	total number of withstands
pН	-	measurement of acidity
U.V	-	ultra-violet
V ₅₀	-	50% flashover voltage
$V_{actual breakdown}$	-	actual voltage breakdown
V _{DIAS}	-	voltage recorded in DIAS
Vj	-	starting voltage of Up and Down Method
ΔL	-	length of triggered discharge from ESE
$L+\Delta L$	-	protected zone of ESE
$\Delta t / \Delta T$	-	time difference (also known as time advantage) of ESE
V	-	speed of upward connecting leader of ESE $(10^6 ms^{-1})$
$\sigma_{_{pu}}$	-	per unit standard deviation

LIST OF APPENDICES

APPENDIX	TITLE	PAGE
A	Photos of damaged structures and lightning	
	air terminals after struck by lightning	84
В	Equipment and methods used in laboratory	
	test	87
С	Determination of Digital Impulse Analyzing	
	System (DIAS) measurement accuracy based on	
	BS358:1960	95
D	Up and Down Method to obtain voltage	
	flashover (V_{50}) and conversion to voltage	
	actual breakdown via the equations obtained	
	through calibration	99
E	Waveforms from DIAS readings used to	
	calculate time-to-breakdown	123

CHAPTER 1

INTRODUCTION

1.1 Background of study

Malaysia is located near the equator line $(1^{0}-7^{0} \text{ N})$ latitude and $(100^{0}-119^{0} \text{ E})$ longitude. It has high isokeraunic level of approximately 200 thunderstorm days a year. The lightning ground flash density is about 15 to 20 strikes per km² per year. This implies high lightning flash to ground, i.e., approximately there are 15 to 20 lightning strikes to each square km of land in a year [1].

For the last 10 years, Malaysia has experienced more lightning activities than before, from 200 thunderstorm days a year to about 300 thunderstorm days a year. The number of average annual lightning flashes per square km in Malaysia now is about 25 compared to 15-20 ten years ago. Due to the increasing lightning activities in Malaysia, more building structures are struck and damaged by lightning leaders particularly high-rise buildings in highly industrialized areas like Klang Valley and Johor (refer to Appendix A for some pictures of damaged structures caused by lightning).

Not only are lightning activities a threat to buildings, acid rain is another environmental issue in this rapid developing country. A Malaysian Meteorological Service (MMS) study shows that Malaysia is beginning to experience effects of acid rain similar to those in such industrialized countries as the United Kingdom, Japan and the United States [2]. Acid rain is caused when coal or oil is burned, which in turn generate vast amounts of polluting gases. Airborne by-products of certain industrial processes add to the pollution. Acid rain is corrosive of metals such as iron and zinc roof, marble and limestone. Low pH values have been attributed to increased industrial activity and large numbers of motor vehicles emitting considerable amounts of sulphur and nitrogen compounds into the atmosphere, causing the increase in rainwater acidity. Rainwater of pH less than 5.6 is considered acidic.

Rain acidity in Peninsular Malaysia is on the rise and the number of areas affected by acid rain is growing. Areas most seriously affected by acid rain are Kuala Lumpur, Johor, Kedah and Selangor, while rain acidity in Petaling Jaya and Senai has gone up four times from 1985 to 1988. The average pH of rainwater in the Klang Valley Region and South Johor in 2003 is below 4.4, indicating that it's very acidic [3]. Rainfall acidity is shown in Figure 1.1.



Figure 1.1 Rainfall acidity in Malaysia for the year 2003

Buildings installed with conventional lightning protection system (LPS) using 200-year-old technology Franklin rod, are exposed to the effect of these acid rains. Not all of the conventional LPS installed can withstand against the corrosive effect of acid rains. This is because some of the materials used for the installation of LPS are non-resistant to corrosion which is brought about by the electrochemical reaction on galvanized steel rods (coated with very thin copper material).

Judging on the lightning air terminal (LAT) physical arrangement placed on top of building structures, inundation of acid rains is likely to occur at the base and tip of Franklin rod. This phenomenon encourages the metallic corrosion of the rod itself. By coincidence when this concerned LAT is struck by a powerful lightning leader, the rod which intercepts the leader can be forced out of its base, sometimes broken into two parts and changed in its physical configuration (refer to Appendix A for pictures of damaged lightning air terminals).

Thus, in this research, a few non-standard configuration LAT were designed due to the possible damage that may change the tip configuration of a standard rod when struck by lightning. The question to be asked here is whether the damaged LAT can still perform as a LPS or otherwise, assuming replacement of LPS is not done on time which allows sufficient time for subsequent lightning strike to happen on the same point of the concerned building. Therefore, it is crucial to determine the performance of the damaged LAT which consist of different shapes.

Many researches have been carried out to discover better improved methods for lightning protection. One such research is by C.B. Moore. He carried out an assessment on Benjamin Franklin's lightning rods and found that Franklin's ideas about the functioning of his sharp-tipped rods neither prevent lightning nor are they the preferred strike receptors when conductors with less curvature in their tips are nearby [4]. Nevertheless, Franklin rod can continue to provide protection against lightning as long as they have no nearby competitors for strike reception.

A few other researches by C.B. Moore [5]- [7] also found that the blunt-tipped lightning rods are better strike receptors than the conventional sharp-tipped ones. In these papers, he carried out field tests in real lightning condition on top of a mountain to examine the competition between sharp and blunt rods. He also carried out laboratory demonstrations with the Van de Graff generator to study the discharges from exposed electrodes by investigating the current emission [8]. The experimental field results and the laboratory demonstrations with the Van de Graff generator are consistent with the preceding analysis; they all indicate that blunt rods are better candidates for strike reception than the sharp ones.

This research is an extension based on C.B. Moore's research but with a different approach and parameters of study. In this research, the rods tested were not limited to sharp and blunt only but it also included other tip configurations like the concave, flat and conical type. The performance of the air terminals were examined through laboratory studies based on the breakdown characteristics, i.e. breakdown voltage and time to breakdown instead of current emission as done by C.B. Moore. Whilst C.B. Moore carried out competitive test in real lightning condition to examine which rod is a better receptor, competitive tests were also carried out in this research but in the laboratory to determine the probability of strikes to air terminals.

For his laboratory tests, C.B. Moore used the Van de Graff generator in reference [8] to create strong electric fields to study the responses of various electrodes to strong electric fields. However, due to the unavailability of Van de Graaf generator in Institute of High Voltage and High Current (IVAT), the Marx generator, U.V radiation and D.C ionization method were used in replacement of the Van de Graff generator to observe and study the discharges from the rods (U.V and D.C ionization method will be explained in Chapter 3. Please refer to Appendix B for explanation on the operations of Van de Graff and Marx generator). Therefore, this research attempts to discover the possible alternatives to improve the conventional Franklin rod by investigating the breakdown performance of different tip configuration of air terminals, considering the damage caused on rods after being struck by lightning.

1.2 **Objective**

The objectives of research are:

 To review and discuss the published studies on performance of conventional lightning air terminals based upon C.B. Moore's past researches and tests on the performance of blunt and sharp rods. The results obtained in this research is to be compared with C.B. Moore's research results.

- 2) To obtain a good understanding of the types of testing methods and approaches used in laboratory and real lightning condition to test lightning air terminals.
- To design, construct and improve the tip configurations of Franklin lightning air terminal for laboratory test.
- To test different design configurations of Franklin air terminals in laboratory.
- 5) To study the performance and behaviour of different design configurations of Franklin air terminals through the voltage breakdown, number of strikes and time-to-breakdown under high impulse voltage and high DC tests, with and without ionization activity around the tip of the rod.
- 6) To study the corona formation around the tip of the air terminals that would affect the breakdown phenomenon.
- 7) To contribute to a better understanding of the effects of different lightning air terminals tip configurations by providing a substantial/logical explanation to the ionisation and breakdown phenomenon.

1.3 Contributions of the Thesis

This research has contributed the followings:

 An extensive review of published literature on the performance of lightning rods was achieved.

- 2) A series of lightning rod configurations were creatively designed. Previous researches have focused on Early Streamer Emission (ESE) devices and on limited designs of lightning rod, e.g. sharp, blunt, multipointed. For this research however, new designs such as the concave, flat and conical tip configurations were modified from the existing conventional Franklin rod.
- 3) Different configurations are considered to affect breakdown performance through different discharge mechanisms. The performance of different configurations of lightning rod was determined through experimental methods in laboratory. Past researchers have been using the method of DC superimposed on impulse to test lightning rods in laboratory [9]. In this research though, a different approach was used to test the lightning rod by using DC and impulse separately yet obtaining almost similar results with previous researches.
- 4) Previous researches carried out in laboratory by C.B. Moore investigated the performance of lightning air terminals through observations of current measurements but this research focused on laboratory measurements of voltage breakdown and time-to-breakdown. Good agreement was obtained between the voltage breakdown experimental results in this research with the current measurement results in C.B. Moore's research.
- 5) This work has contributed to the frontier of lightning protection studies by comparing the performance of various air terminal tip configurations with and without ionization. A comparison between the two conditions revealed significant differences in the breakdown characteristics, number of strikes and corona formation. Results from condition with ionization in laboratory shows that laboratory condition could also be used to represent condition almost similar to real lightning.

1.4 Organization of work

The main purpose of Chapter 2 is to look into the history of Franklin rod and the improvement on lightning rods throughout the decade, with the existence of blunt rod and early streamer emission (ESE). The review provides a better insight into the different designs and configurations of lightning rods that have been used in past researches. This chapter also reviews on the lightning attachment process.

Chapter 3 is the research methodology chapter. It describes in detail the design of air terminals, the experimental setup, the methods of testing and the equipment used in the course of this research. Results obtained in this research are being discussed in Chapter 4. Theories described in Chapter 2 are put into practice to discuss the performance of the designated air terminals. Chapter 5 which is the final chapter, is to conclude on the whole research and to give suggestions for further improvements on the results in future research. deeper understanding on various mechanisms of blunt rod that has yet to be discovered, i.e. the striking distance and the protection zone of the blunt rod. In the future, the different tip configuration of air terminals used in this laboratory test could also be installed on real buildings in real lightning condition for field tests to reconfirm the results obtained in laboratory condition. If the results are non-contradicting, then the blunt rod could be commercialized to replace the Franklin rod in the market.

REFERENCE

- Mohd. Nazri Puteh. Kaji Selidik Mengenai Kejadian Kilat Di Semenanjung Malaysia Berdasarkan Faktor Geografi. Bachelor of Electrical Engineering Thesis. Universiti Teknologi Malaysia: 2001.
- 2. <u>http://www.surforever.com/sam/a2z/content1.html</u>. November 2004.
- 3. <u>http://www.kjc.gov.my/english/service/environ/rainacid.html</u>. November 2004.
- 4. Moore, C.B., Aulich, G. D., and Rison, W. An Assessment of Benjamin Franklin's Lightning Rods. *Paper presented at the Bakken Conference On The History And Cultural Meaning Of The Lightning Rod.* November 5, 2002.
- 5. Moore, C.B. Improved Configurations of Lightning Rods and Air Terminals. *Journal of The Franklin Institute*. 1983. 315(1): 61-85.
- 6. Moore, C.B., Rison, W., Mathis J., and Aulich, G. D. Lightning Rod Improvement Studies. *Journal of Applied Meteorology*. 2000. 39: 593-609.
- Moore, C.B., Aulich, G. D., and Rison, W. Measurements of Lightning Rod Responses to Nearby Strikes. *Geophysical Research Letters*. 2000. 27(10): 1487-1490.
- Moore, C.B., Aulich, G. D., and Rison, W. The Case for Using Blunt-Tipped Lightning Rods as Strike Receptors. *Journal of Applied Meteorology*. 2003. 42: 984-993.
- 9. Chalmers, I.D., Evans, J.C., Siew, W.H., Allen, N.L., Greaves, D.A., and Cotton, I. Laboratory Testing Of Early Streamer Emission Air Terminals.

Proceedings of the International Conference on Lightning Protection. September 14-18, 1998. Birmingham, U.K: ICLP. 1998. 412-417.

- Rison, W., Moore, C.B., and Aulich, G. D. Lightning Air Terminals- Is Shape Important? *Proceedings of the 2004 IEEE International Symposium on Electromagnetic Compatibility*. August 9-13, 2004. 1: 300 – 305.
- 11. Uman, M.A. The Lightning Discharge. Orlando: Academic Press. 1987.
- Moore, C.B. Comparative Tests of Sharp and Blunt Lightning Rods. *Report prepared for the 24th International Conference on Lightning Protection*. September 14-18, 1998. Birmingham, England: ICLP. 1998. 6 pages.
- 13. Uman, M.A. Lightning. USA: McGraw-Hill Inc. 1969.
- Allen, N.L., Cornick, K.J., Faircloth, D.C., and Kouzis, C.M. Test of The Early Streamer Emission Principle for Protection Against Lightning. *IEE Proc.-Sci. Meas. Technol.* 1998. 145(5): 200-206.
- Akyuz, M. and Cooray, V. The Franklin Lightning Conductor: Conditions Necessary for The Initiation of A Connecting Leader. *Journal of Electrostatics*. 2001. 51-52: 319-325.
- Carpenter, R. and Drabkin, M. Improvement of Lightning Protection Against Direct Strokes. *Proceedings of the IEEE International Symposium on Electromagnetic Compatibility*. August 18-22, 1997. 403 – 405.
- Abdel-Salam, M. and Al-Abdul-Latif, U. Lightning Protection Using Energized Franklin Rods. *Conference record of the 1995 IEEE Industry Applications Conference*. 1995. 2: 1409-1414.
- Allen, N.L., Evans, J.C., Faircloth, D.C., Siew, W.H., and Chalmers, I.D. Simulation of An Early Streamer Emission Air Terminal For Application to Lightning Protection. *Conference publication of IEE High Voltage Engineering Symposium*. August 22-27, 1999. 467: 2.208S11-2.211S11.
- Moore, C.B., Rison, W., Mathis J. and Patterson, L. Report On A Competition Between Sharp and Blunt Lightning Rods. Submitted for publication in the IEEE Transactions on Electromagnetic Compatibility.1997. 27 pages.
- 20. www.altfabrication.com. 2004.

- 21. www.lightningrod.com/manual1_steps.html. 2004.
- Uman, M.A. and Rakov, V.A. A Critical Review of Nonconventional Approaches to Lightning Protection. *Journal of American Meteorological Society*. 2002. 10.1175: 1809-1819.
- Mackerras, D., Darveniza, M., and Liew, A.C. Review of Claimed Enhanced Lightning Protection of Buildings by Early Streamer Emission Air Terminals. *IEE Proc.-Sci. Meas. Technol.* 1997. 144(1): 1-9.
- Chalmers, I.D., Evans, J.C., Siew, W.H. Considerations for The Assessment of Early Streamer Emission Lightning Protection. *IEE Proc.-Sci. Meas. Technol.* 1999. 146(2): 57-63.
- 25. <u>www.lightningeliminators.com</u>. July 2005.
- 26. British Standard Institution. *Protection of Structures Against Lightning*. London, BS 6651. 1999.
- Australian/New Zealand Standard Institution. Lightning Protection. Australia/New Zealand, NZS/AS 1768-1991. 1991.
- 28. Kuffel, E., Zaengl W.S., and J.Kuffel. *High Voltage Engineering: Fundamentals.* 2nd. ed. Great Britain: Butterworth-Heinemann. 2000.
- 29. Cooray, V. *The Lightning Flash*. London, United Kingdom: The Institution of Electrical Engineers. 2003.
- Greenwood, A. *Electrical Transients in Power Systems*. New York: John Wiley and Sons, Inc. 1991.
- 31. Malik, N.H., Al-Arainy, A.A., and Qureshi, M.I. *Electrical Insulation in Power Systems*, U.S.A: Marcel Dekker, Inc. 1998.
- Cooray, V. and Zitnik, M. On Attempts to Protect A Structure From Lightning Strikes By Enhanced Space Charge Generation. *International Conference On Lightning Protection (ICLP)*. 2004.