# APPLICATION OF MAGNETIC FIELD FOR REDUCTION OF SLUDGE BULKING IN ACTIVATED SLUDGE SYSTEM

NUR SYAMIMI ZAIDI

A thesis submitted in fulfilment of the requirements for the award of the degree of Doctor of Philosophy (Civil Engineering)

> Faculty of Civil Engineering Universiti Teknologi Malaysia

> > AUGUST 2016

Dedicated to my precious love

### ABANG, KHAYLA ZAHRA, MAK & AYAH

### ACKNOWLEDGEMENT

In the name of Allah the Most Gracious, the Most Merciful. First and foremost, I am truly grateful for the blessings of Allah that gives me the strength to complete this thesis. I would like to convey my highest gratitude to all my supervisors; Associate Profesor Dr. Johan Sohaili and Associate Profesor Dr. Khalida Muda for their excellent supervision, encouragement, understanding and patience throughout my study. May Allah bless and reward all of them.

A special thanks to Associate Profesor Dr. Zaharah Ibrahim for allowing me to use several equipment and facilities at the Faculty of Bioscience and Bioengineering laboratories. To Dr. Robiah of the Mathematics Department, Faculty of Science, thank you very much for assisting me on the statistical analysis. I would also like to express my appreciation to all the laboratory staff; Encik Razale, Rahimah, Encik Shamsudin and Encik Jemahari. I would also like to extend my thanks to all my seniors, my colleagues and dear friends for the continuous support, advice and motivation during my study.

I am sincerely indebted to my mother, father and other family members for all the love, support and du'a. Lastly to my precious husband, Ahmad Syuwari, thank you very much for all the unconditional love, support, sacrifice and du'a during the hard times. All of you are my reasons to continue striving and overcome all obstacles.

Special thanks to the Ministry of Science Technology and Innovation (MOSTI) and UTM for funding this research under a project number 4S032.

#### ABSTRACT

Activated sludge treatment process is the most commonly used technology in treating municipal wastewater. Nevertheless, its stable operation is always plagued by occurrence of sludge bulking. Existing control approaches have led to various drawbacks and caused more problematic issues in the treatment system. Therefore, this study investigated the use of magnetic field on activated sludge in controlling the occurrence of sludge bulking and to further enhance wastewater treatment process. The initial stage of the study involved batch tests where statistical experimental design was implemented. Factorial design was carried out first, followed by central composite design experiment. The studies showed that turbidity reduction, aggregation and settling velocity of the activated sludge were affected by factors of magnetic field, exposure time, biomass concentration and mixing intensity. Interaction effects between the factors were also observed. Statistical models describing relationship between the variables were developed. From the study, the highest turbidity reduction (89.1%), aggregation (97.8%) and settling velocity (0.68 cm/min) were achieved under optimal condition of 88.0 mT magnetic field, 16.5 hrs exposure time, 2800 mg/L biomass concentration and 300 rpm mixing intensity. The following stages of the study were conducted in 6 L column reactors. The reactors were operated under long period of sludge retention time of 20 days and in deficient dissolved oxygen of less than 2 mg/L in order to induce the sludge bulking phenomenon. After reaching its stable state, the activated sludge under the magnetic field exposure showed significant results as compared to without the exposure. The average aggregation and settling velocity for the magnetically exposed activated sludge were 89% and 0.59 m/hr as compared to 68% and 0.50 m/hr for the unexposed sludge. Such properties resulted in significant enhancement of sludge volume index at 23.7 mL/g for magnetically exposed activated sludge as compared to 72.2 mL/g for the unexposed sludge. This enhancement benefited the treatment performances whereby the average chemical oxygen demand, ammonia and total phosphorus removal were 87%, 88% and 72% under the magnetic field exposure as compared to 67%, 75% and 44%, respectively without the exposure. Magnetically exposed activated sludge also contained high content of tightly bound extra-cellular polymeric substances (95.6 mg/g VSS) compared to unexposed sludge (61.8 mg/g VSS). Finally, Next Generation Sequencing analysis indicated that magnetically exposed activated sludge showed less possibility of filamentous microorganisms presence compared to the unexposed activated sludge. Overall, analysis confirmed that magnetic field could enhance the settling property of activated sludge through improvement on its aggregation and bioflocculation capability. These imply that magnetic field is reliable for accelerating activated sludge settleability, hence enhancing performance efficiency of the treatment systems. The applied magnetic field was also proven to inhibit proliferation of filamentous microorganisms, thus has potential to inhibit occurrence of sludge bulking.

#### ABSTRAK

Proses rawatan enapcemar teraktif adalah teknologi yang lazim digunakan dalam merawat sisa air kumbahan perbandaran. Namun begitu, operasinya yang stabil kerap terganggu oleh masalah pukal enapcemar. Pendekatan kawalan sedia ada membawa kepada pelbagai kelemahan dan mengakibatkan lebih banyak masalah kepada sistem rawatan. Justeru itu, kajian ini menyiasat penggunaan medan magnet terhadap enapcemar teraktif dalam mengawal masalah pukal enapcemar dan meningkatkan keberkesanan proses rawatan sisa air. Di awal kajian, kaedah reka bentuk eksperimen statistik dilaksanakan. Kaedah reka bentuk berfaktor dijalankan terlebih dahulu, diikuti dengan kaedah reka bentuk komposit pusat. Kajian ini menunjukkan bahawa pengurangan kekeruhan, pengagregatan dan halaju pengenapan enapcemar teraktif dipengaruhi oleh faktor medan magnet, masa pendedahan, kepekatan biojisim dan intensiti pembauran. Kesan interaksi yang wujud antara faktor juga diperhatikan. Beberapa model statistik dibina bagi menghubungkan faktor-faktor yang dikaji. Daripada kajian ini, pengurangan tertinggi kekeruhan (89.1%), pengagregatan (97.8%) dan halaju pengenapan (0.68 cm/min) telah dicapai pada keadaan optimum medan magnet 88.0 mT, masa pendedahan 16.5 jam, kepekatan biojisim 2800 mg/L dan intensiti pembauran 300 rpm. Kajian seterusnya dijalankan dalam reaktor berisipadu 6 L. Reaktor tersebut beroperasi dalam tempoh masa tahanan enapcemar yang panjang iaitu selama 20 hari dan dengan oksigen terlarut rendah pada kepekatan kurang daripada 2 mg/L bagi menghasilkan fenomena pukal enapcemar. Selepas mencapai keadaan stabil, enapcemar teraktif di bawah pendedahan medan magnet menunjukkan hasil yang ketara berbanding tanpa pendedahan. Purata pengagregatan dan halaju pengenapan bagi enapcemar teraktif di bawah dedahan medan magnet adalah 89% dan 0.59 m/h berbanding 68% dan 0.50 m/h bagi enapcemar tanpa dedahan. Hal ini menghasilkan peningkatan besar dalam indeks isipadu enapcemar iaitu 23.7 mL/g bagi enapcemar teraktif di bawah dedahan medan magnet berbanding 72.2 mL/g bagi enapcemar tanpa dedahan. Peningkatan ini memberi manfaat kepada penyingkiran permintaan oksigen kimia, ammonia dan jumlah fosforus iaitu 87%, 88% dan 72% di bawah dedahan medan magnet berbanding 67%, 75% dan 44% dengan tanpa pendedahan. Enapcemar teraktif di bawah dedahan medan magnet juga mengandungi tinggi kandungan bahan polimer tambahan sel yang kuat terikat (95.6 mg/g VSS) berbanding enapcemar tanpa dedahan (61.8 mg/g VSS). Analisis Penjujukan Generasi Terkini juga menunjukkan bahawa enapcemar teraktif di bawah dedahan medan magnet mempunyai kurang kehadiran mikroorganisma berserabut berbanding enapcemar yang tidak terdedah. Secara keseluruhan, analisis mengesahkan bahawa medan magnet boleh meningkatkan halaju pengenapan enapcemar teraktif melalui peningkatan pada keupayaan penggumpalan. Ini menunjukkan bahawa medan magnet mampu meningkatkan keupayaan enapan enapcemar teraktif sekaligus, meningkatkan kecekapan prestasi sistem rawatan. Keupayaan kesan medan magnet juga terbukti dalam menghalang pembiakan mikroorganisma berserabut, dan seterusnya berpotensi untuk menghalang berlakunya masalah pukal enapcemar.

# TABLE OF CONTENTS

TITLE

CHAPTER

	DECLARATION	ii
	DEDICATION	iii
	ACKNOWLEDGEMENT	iv
	ABSTRACT	V
	ABSTRAK	vi
	TABLE OF CONTENTS	vii
	LIST OF TABLES	XV
	LIST OF FIGURES	xix
	LIST OF ABBREVIATIONS	xxvi
	LIST OF SYMBOLS	xxix
	LIST OF APPENDICES	XXX
1	INTRODUCTION	1
	1.1 Preamble	1
	1.2 Objectives of the Study	3
	1.3 Scope of the Study	4
	1.4 Significance of the Study	5
	1.5 Organization of Thesis	6
2	LITERATURE REVIEWS	9

PAGE

2.1	Introdu	uction	tion 9				
2.2	Sludge	Bulking	Bulking				
2.3	Factors	s Causing	g Sludge Bulking	12			
	2.3.1	Concen	tration of Dissolved Oxygen	13			
	2.3.2	Food-to	o-Microorganisms (F/M) Ratio	14			
	2.3.3	Nutrien	ıts	16			
	2.3.4	Soluble	e Substrate Concentration	17			
	2.3.5	Sulfide	Concentration	18			
2.4	Existin	ng Contro	ol Strategies of Sludge Bulking	19			
	2.4.1	Specifi	c Approach	19			
		2.4.1.1	Minimization of Sludge Retention				
			Time	20			
		2.4.1.2	Maintain Higher Level of				
			Dissolved Oxygen Concentration	21			
		2.4.1.3	Selector Installation in Activated				
			Sludge Reactor	23			
	2.4.2	Non-sp	ecific Approach	25			
		2.4.2.1	Chlorination	25			
		2.4.2.2	Metal Salts Addition	28			
		2.4.2.3	Synthetic Polymer Addition	30			
	2.4.3	Biologi	cal Approach	32			
2.5	Drawb	acks / Li	mitations on Existing Control				
	Strategi	es of Slu	dge Bulking	33			
	2.5.1	Drawba	acks on Specific Approach	35			
	2.5.2	Drawba	acks on Non-specific Approach	36			
	2.5.3	Limitat	ions on Biological Approach	38			
2.6	Applic	ation of I	Magnetic Field in Wastewater				
	Treatme	ent Syste	ms	39			
	2.6.1	Organie	c Dyes and Color Removal	40			
	2.6.2	High St	trength Organic Wastewater	42			
	2.6.3	Nitroge	en Removal	44			
	2.6.4	Turbidi	ty and Suspended Solids Removal	46			
	2.6.5	Remov	al of Heavy Metals	47			

2.7	Mecha	nisms of Magnetic Field Application	48
	2.7.1	Magnetization and Exhibition of Magnetic	
		Field	48
	2.7.2	Magnetic Gradient	50
	2.7.3	Lorentz Force	52
	2.7.4	Magnetic Memory	53
	2.7.5	Magnetohydrodynamic	54
2.8	Effects	of Magnetic Field on Particle Stability	54
	2.8.1	Coagulation and Aggregation	55
	2.8.2	Crystallization	57
	2.8.3	Purification	60
2.9	Effect	of Magnetic Field on Microorganisms	62
	2.9.1	Growth and Morphology	62
	2.9.2	Storage Capacity	65
	2.9.3	Surface Hydrophobicity	66
	2.9.4	Extra-cellular Polymeric Substances	67
2.10	Poten	tial Implementation of Magnetic Field in	
	Inhibi	ing Sludge Bulking	68
EFF	ECTS	OF MAGNETIC FIELD TOWARDS	
РНУ	SICAL	PROPERTIES OF ACTIVATED	
SLU	DGE		72
3.1	Introd	uction	72
~ ~		als	73
3.2	Mater		
3.2	Mater: 3.2.1	Reactor Set-Up	74
3.2 3.3	Mater 3.2.1 Analy	Reactor Set-Up tical Methods	74 76
3.2 3.3	Mater 3.2.1 Analy 3.3.1	Reactor Set-Up tical Methods Turbidity Reduction	74 76 76
3.2 3.3	Mater: 3.2.1 Analy 3.3.1 3.3.2	Reactor Set-Up tical Methods Turbidity Reduction Aggregation	74 76 76 76
3.2	Mater: 3.2.1 Analy 3.3.1 3.3.2 3.3.3	Reactor Set-Up tical Methods Turbidity Reduction Aggregation Settling Velocity	74 76 76 76 77
<ul><li>3.2</li><li>3.3</li><li>3.4</li></ul>	Mater: 3.2.1 Analy 3.3.1 3.3.2 3.3.3 Experi	Reactor Set-Up tical Methods Turbidity Reduction Aggregation Settling Velocity mental Procedures	74 76 76 76 77 77
<ul><li>3.2</li><li>3.3</li><li>3.4</li></ul>	Mater: 3.2.1 Analy 3.3.1 3.3.2 3.3.3 Experi 3.4.1	Reactor Set-Up tical Methods Turbidity Reduction Aggregation Settling Velocity mental Procedures 2-Level Factorial Experimental Design	74 76 76 76 77 77 77

3.5	Result	s and Discussions	82
	3.5.1	Effect of Magnetic Field, Exposure Time,	
		Biomass Concentration and Mixing	
		Intensity on Turbidity Reduction,	
		Aggregation and Settling Velocity	82
	3.5.2	Factorial Analysis: Turbidity Reduction	87
		3.5.2.1 Main Effect	87
		3.5.2.2 Interaction Effects	89
	3.5.3	Factorial Analysis: Aggregation	92
		3.5.3.1 Main Effect	92
		3.5.3.2 Interaction Effects	94
	3.5.4	Factorial Analysis: Settling Velocity	96
		3.5.4.1 Main Effect	96
		3.5.4.2 Interaction Effect	99
	3.5.5	Response Surface Analysis	100
	3.5.6	Experimental Condition Optimization	113
3.6	Conclu	isions	113
EFF	тест с	OF MAGNETIC FIELD EXPOSURE ON	
TH	E ACT	<b>EVATED SLUDGE SUBJECTED TO</b>	
LON	NG SLU	<b>JDGE RETENTION TIME</b>	116
4.1	Introdu	action	116
4.2	Materi	als	117
	4.2.1	Wastewater and Activated Sludge	118
	4.2.2	Magnetic Device	119

	11140011	ais			
	4.2.1	Wastew	ater and Activated Sludge		118
	4.2.2	Magnet		119	
	4.2.3	Reactor	Set-up		120
4.3	Analyt	ical Meth	ods		122
	4.3.1	Physica	Physical Characteristics		
		4.3.1.1	Aggregation		123
		4.3.1.2	<b>Biomass Concentration</b>		124
		4.3.1.3	Settling Velocity		124

4.3.1.4 Sludge Volume Index

Х

		4.3.1.5	Relative Hydrophobicity	125
		4.3.1.6	Surface Charge	126
	4.3.2	Remova	al Performances	127
		4.3.2.1	Chemical Oxygen Demand	127
		4.3.2.2	Suspended Solids	127
		4.3.2.3	Ammonia	128
		4.3.2.4	Nitrogen	129
		4.3.2.5	Phosphorus	130
	4.3.3	Microbi	al Activity	130
4.4	Experi	mental Pr	rocedures	131
4.5	Result	s and Dise	cussions	133
	4.5.1	Physica	l Profile of the Reactor System	133
	4.5.2	Effect o	f Magnetic Field under Long Sludge	
		Retentio	on Time on Physical Properties of	
		the Acti	vated Sludge	136
		4.5.2.1	Sludge Volume Index and Settling	
			Velocity	136
		4.5.2.2	Aggregation, Relative	
			Hydrophobicity and Surface	
			Charge	138
	4.5.3	Effect o	f Magnetic Field Exposure under	
		Long Sl	udge Retention Time on Chemical	
		Oxygen	Demand Removal	142
	4.5.4	Effect o	f Magnetic Field Exposure under	
		Long Sl	udge Retention Time on Ammonia	
		Remova	ıl	145
	4.5.5	Effect o	f Magnetic Field Exposure under	
		Long Sl	udge Retention Time on Nitrogen	
		Remova	ıl	147
	4.5.6	Effect o	f Magnetic Field Exposure under	
		Long Sl	udge Retention Time on Phosphorus	
		Remova	l	150
	4.5.7	Microbi	al Activity and Biokinetic	

		Properties of the Activated Sludge	153
4.6	Conclu	isions	157
		NE MACHETIC EIELD EVDOCUDE ON	
	ECI C	JF MAGNETIC FIELD EXPOSURE ON	
	LIVAII VCEN	ZD SLUDGE UNDER LOW DISSOLVED	150
<b>UA</b>	IGEN		139
5.1	Introdu	uction	159
5.2	Materi	als	160
5.3	Analyt	ical Methods	161
	5.3.1	Physical Characteristics	162
	5.3.2	Floc Characteristics	162
	5.3.3	Removal Performances	163
5.4	Experi	mental Procedures	163
5.5	Result	s and Discussions	164
	5.5.1	Physical Profile of the Reactor System	165
	5.5.2	Effect of Magnetic Field under Low	
		Dissolved Oxygen on Physical Properties of	
		Activated Sludge	168
	5.5.3	Characterization of the Activated Sludge	
		Flocs	173
		5.5.3.1 Morphology of Activated Sludge	
		Flocs	173
		5.5.3.2 Cellular Characterization of	
		Activated Sludge Floc	177
	5.5.4	Effect of Magnetic Field under Low	
		Dissolved Oxygen on Removal of Chemical	
		Oxygen Demand	179
	5.5.5	Effect of Magnetic Field under Low	
		Dissolved Oxygen on Removal of Ammonia	181
	5.5.6	Effect of Magnetic Field under Low	
		Dissolved Oxygen on Removal of Nitrogen	183
	5.5.7	Effect of Magnetic Field under Low	

		Dissolve	ed Oxygen	on Rem	oval of	
		Phospho	orus			187
5.6	Conclu	isions				190
SUS	SCEPTI	BILITY	OF	F	ILAMENTOUS	
MI	CROOR	GANISM	IS IN	THE	ACTIVATED	
SLU	J <b>DGE E</b>	BULKING	G SUBJEC	CTED I	O MAGNETIC	
FIE	LD					192
6.1	Introdu	uction				192
6.2	Materi	als				194
	6.2.1	Reactor	Set-up			195
6.3	Analyt	tical Meth	ods			196
	6.3.1	Filamen	tous Chara	cterizati	on	197
		6.3.1.1	Culture an	d Isolati	on of	
			Filamento	us Micro	oorganisms	197
		6.3.1.2	Gram and	Neisser	Staining	198
	6.3.2	Next Ge	eneration Se	equencir	ıg	199
	6.3.3	Extra-ce	ellular Poly	meric Sı	ubstances	200
		6.3.3.1	Extraction	by Heat	Method	200
		6.3.3.2	Determina	tion of <b>(</b>	Carbohydrate	
			Componen	nt		201
		6.3.3.3	Determina	tion of H	Polysaccharides	
			Componen	nt		202
		6.3.3.4	Determina	tion of I	Protein	
			Componen	nt		202
6.4	Experi	mental Pr	ocedures			204
6.5	Result	s and Disc	cussion			204
	6.5.1	Morpho	logical and	Cellula	r	
		Characte	erization of	Filame	ntous Isolates	
		from Ac	tivated Slu	dge		205
	6.5.2	Abunda	nces of the	Overall	Microorganisms	211
	6.5.3	Commu	nity Structu	ures of F	ïlamentous	

		Microor	ganisms	216
	6.5.4	6.5.4 Total Extra-cellular Polymeric Substances		
		Content		221
		6.5.4.1	Content of Loosely-bound EPS	
			and Tightly-bound EPS	221
		6.5.4.2	Chemical Components of Extra-	
			cellular Polymeric Substances	224
6.6	Conclu	isions		227
7 CO	NCLUS	IONS AN	ND RECOMMENDATIONS	248
7.1	Conclu	isions		230
7.2	Recom	mendatio	ons	232
REFERENCES				235
Appendices A-G				263-319

# LIST OF TABLES

TABLE NO.	TITLE	PAGE
2.1	Summary of the specific approaches towards inhibiting the filamentous sludge bulking	20
2.2	Summary of the non-specific approaches in controlling filamentous sludge bulking	26
2.3	Overview of the drawbacks/limitations due to the implementation of existing control strategies	34
2.4	Removal of various colors and dyes by magnetic separation	41
2.5	Removal of pollutants in high strength organic wastewater by magnetic field application	43
2.6	Effects of the magnetic field on the crystallization of CaCO <sub>3</sub> (Zaidi <i>et al.</i> , 2014)	58
2.7	Comparisons of removal performances between magnetic and non-magnetic (conventional) wastewater treatment systems	69

3.1	List of reagents used in the experiment	73
3.2	List of equipments used in the experiment	74
3.3	The variables and its range values used in the batch experiments	78
3.4	2-level fractional factorial design with four variables	79
3.5	CCD experimental runs in coded units	81
3.6	Characteristics of wastewater during the experimental study	82
3.7	Experimental results for 2-level factorial design analysis	83
3.8	<i>p</i> -values of the estimated main and interaction effects of variables magnetic field, exposure time, biomass concentration and mixing intensity on the turbidity reduction, aggregation and settling velocity of the activated sludge	85
3.9	Experimental results for CCD analysis	101
3.10	Summary of the <i>p</i> -values for the ANOVA analysis	102
4.1	List of reagents used in the experiment	117
4.2	List of equipments used in the experiment	118
4.3	Characteristics of wastewater during experimental study	133
4.4	ANOVA of effluent suspended solids between Reactor	

4.5	Physicalproperties(aggregation,relativehydrophobicityandsurfacecharge)ofthesludgethroughouttheexperimentsurface	139
4.6	ANOVA of COD removals between Reactor A and Reactor B	143
4.7	ANOVA of ammonia removals between Reactor A and Reactor B	146
4.8	ANOVA of nitrite removals between Reactor A and Reactor B	147
4.9	ANOVA of total phosphorus removals between Reactor A and Reactor B	152
4.10	Coefficient of biokinetic parameters	155
4.11	Kinetic coefficients of activated sludge in Reactor A and Reactor B	155
5.1	Characteristics of wastewater during experimental study	165
5.2	Average values of the biomass concentration and effluent suspended solids for Reactor A and Reactor B	166
5.3	ANOVA for the physical properties of activated sludge between reactors	168
5.4	ANOVA of COD removals between Reactor A and Reactor B	180

5.5	ANOVA of ammonia removals between Reactor A and Reactor B	182
5.6	ANOVA for the removal of orthophosphate and total phosphorus between Reactor A and Reactor B	187
6.1	List of reagents used in the experiment	194
6.2	List of equipments/instruments used in the experiment	195
6.3	Composition of Solution A and Solution B for Gram stain preparation	198
6.4	Composition of Solution C and Solution D for Neisser stain preparation	199
6.5	Composition of Solution X, Solution Y and Solution Z for preparation of Lowry solution	203
6.6	Morphological and cellular characterization of the ten isolated filamentous microorganisms from activated sludge	206
6.7	Percentage of total reads classified to taxonomic level	212
6.8	List of phylums and respective filamentous microorganisms' species (Guo and Zhang, 2012)	216
6.9	Related groups of filamentous microorganisms database	220
6.10	The content of EPS during sludge bulking in Reactor A and Reactor B	222

## LIST OF FIGURES

FIGURES NO.	TITLE	PAGE
1.1	Outline of the experimental research works	8
2.1	Characteristics of activated sludge under present and absent of filamentous microorganisms (Gray, 2004)	11
2.2	Effect of magnetic field on polar and non-polar molecules (Vick, 1991)	50
2.3	The Laplace-Lorentz force on a moving charged ion is at right angle of both the ion flowing direction and the magnetic field direction (Bruk <i>et al.</i> , 1987)	52
3.1	Experimental setup of which glass flask is fixed in the middle of magnetic cage where all four surfaces were covered with magnets	75
3.2	Magnetic field lines (top view) exhibited from the magnets' pairs	75
3.3	Pareto chart of the (a) turbidity reduction, (b) aggregation and (c) settling velocity of activated sludge	86

3.4	Main effects for the response of turbidity reduction	88
3.5	Interaction plot for the turbidity reduction	90
3.6	Main effects plot for the aggregation of activated sludge	93
3.7	Interaction plot for aggregation	94
3.8	Main effects for the response of settling velocity	97
3.9	Interaction plot for the settling velocity	99
3.10	Residual plots for (a) Turbidity reduction and (b) Aggregation	103
3.11	Outlier T plots for (a) Turbidity reduction and (b) Aggregation	104
3.12	<ul> <li>(a) Contour and (b) 3D response surface plots representing relationship between magnetic field, exposure time and turbidity reduction (Hold value: Biomass concentration = 3000 mg/L; Mixing intensity = 300 rpm)</li> </ul>	106
3.13	(a) Contour and (b) 3D response surface plots representing relationship between exposure time, biomass concentration and turbidity reduction (Hold value: Magnetic field = 51.5 mT; Mixing intensity = 300 rpm)	107
3.14	(a) Contour and (b) 3D response surface plots	

representing relationship between magnetic field, exposure time and aggregation (Hold value: Biomass concentration = 3000 mg/L; Mixing intensity = 300 rpm)

- 3.15 (a) Contour and (b) 3D response surface plots representing relationship between magnetic field, biomass concentration and aggregation (Hold value: Exposure time = 24.25 hrs; Mixing intensity = 300 rpm)
- 3.16 (a) Contour and (b) 3D response surface plots representing relationship between exposure time, biomass concentration and aggregation (Hold value: Magnetic field = 51.5 mT; Mixing intensity = 300 rpm)
- 4.1 Arrangement of permanent magnets in the fabricated holder (unit in mm) 119
- 4.2 Schematic layout of the magnetic activated sludge bioreactor (unit in mm) with Column A located at the middle of four fabricated holder consisted of permanent magnets
   120
- 4.3 6-L laboratory scale of magnetic activated sludge bioreactor 121
- 4.4 Experimental analysis on the effect of magnetic field exposure under long SRT on activated sludge 122
- 4.5 Profile of biomass concentration throughout the experiment 134

109

4.6	Effluent suspended solids concentration for both reactors throughout the experiment	134
4.7	Profile of SVI and settling velocity (SV) of activated sludge in Reactor A and Reactor B	137
4.8	Profile of relative hydrophobicity and surface charge of the activated sludge throughout the experiment	140
4.9	Profile of COD for both reactor systems throughout the experiment	143
4.10	Profile of ammonia for both reactors throughout the experiment	145
4.11	Influent – Effluent profile and removal performance of nitrite and nitrate for Reactor A	148
4.12	Influent – Effluent profile and removal performance of nitrite and nitrate for Reactor B	148
4.13	Profile of the effluent total organic nitrogen for both reactors throughout the experiment	150
4.14	Profile of orthophosphate for both reactor systems throughout the experiment	151
4.15	Profile of total phosphorus for both reactor systems throughout the experiment	152
4.16	OUR profile in one complete cycle of aeration phase for Reactor A and Reactor B	153

5.1	Experimental analyses on the effect of magnetic field under low DO on the activated sludge in treating municipal wastewater	161
5.2	Profile of DO concentration for Reactor A and Reactor B	165
5.3	Profile of biomass concentrations for Reactor A and Reactor B	167
5.4	Aggregation and SVI profiles of activated sludge for Reactor A and Reactor B	169
5.5	Relative hydrophobicity and surface charge profiles of activated sludge for Reactor A and Reactor B	171
5.6	Morphological development of the activated sludge flocs under magnification of 45x. (a), (b), (c) Flocs developed at early, middle and end stage of the experiment in Reactor A; (d), (e), (f) Flocs developed at early, middle and end stage of the experiment in Reactor B	174
5.7	FESEM microstructure observations on activated sludge under the magnification of 10,000x. (a) Filamentous microorganisms were seen to intertwine among the sludge surfaces; (b) Fat-rod and coccal- types of bacterial morphotypes in sludge Reactor A; (c) Presence of filaments that were still seen in sludge Reactor B	178
	stude Reactor D	170

5.8 Profile of COD removal for Reactor A and Reactor B 179

5.9	Profile of ammonia removal between Reactor A and Reactor B	181
5.10	Profile of influent-effluent concentration and removal efficiency of nitrite for Reactor A and Reactor B	184
5.11	Influent-effluent concentration of nitrate for Reactor A and Reactor B	185
5.12	Profile of influent-effluent concentration and removal efficiency of total nitrogen for Reactor A and Reactor B	186
5.13	Profile of influent-effluent concentration and removal efficiency of orthophosphate for Reactor A and Reactor B	187
5.14	Profile of influent-effluent concentration and removal efficiency of total phosphorus for Reactor A and Reactor B	189
6.1	Experimental workflow on the study of filamentous' susceptibility under the effect of magnetic field	196
6.2	Phase-contrast image of filamentous isolates $(FM1_{raw})$ at 1000x magnification	209
6.3	Phase-contrast image of filamentous isolates ( $FM8_{RB}$ ) at 1000x magnification	209
6.4	Phase-contrast image of filamentous isolates ( $FM6_{RA}$ ) at 1000x magnification	210

6.5	Phase-contrast image of filamentous isolates $(FM2_{raw})$ at 1000x magnification	210
6.6	Top 8 abundances of various microorganisms in $S_{initial}$ (other species referring to sum of all classification with less than 1.3%)	214
6.7	Top 8 abundances of various microorganisms in $S_A$ (other species referring to sum of all classification with less than 1.0%)	214
6.8	Top 8 abundances of various microorganisms in $S_B$ (other species referring to sum of all classification with less than 1.1%)	215
6.9	Heat gradient map of the phylums' classifications. The scale bar corresponds to 1% sequence divergence.	217
6.10	Abundances of filamentous microorganisms for (a) $S_{initial}$ ; (b) $S_A$ ; (c) $S_B$	218
6.11	Composition of chemical components in each LB- EPS and TB-EPS for Reactor A and Reactor B	224
6.12	Changes of PN/PS ratio in EPS for Reactor A and Reactor B throughout the experimental period	226

# LIST OF ABBREVIATIONS

ASP	-	Activated sludge process
SRT	-	Sludge retention time
DO	-	Dissolved oxygen (mg/L)
SBR	-	Sequential/Sequencing batch reactor
CCD	-	Central Composite Design
EPS	-	Extra-cellular polymeric substances
RSM	-	Response surface methodology
MLSS	-	Mixed liquor suspended solids (mg/L or g/L)
MLVSS	-	Mixed liquor volatile suspended solids (mg/L or g/L)
SVI	-	Sludge volume index (mL/g)
COD	-	Chemical oxygen demand (mg/L)
ESS	-	Effluent suspended solids (mg/L or g/L)
VSS	-	Volatile suspended solids (mg/L or g/L)
NGS	-	Next Generation Sequencing
HGMS	-	High gradient magnetic separation
EMF	-	Electromotive force
MTD	-	Magnetic treatment device
PHAs	-	Polyhydroxyalkanoates
PHB	-	Poly-3-hydroxybutyrate
PHV	-	Poly-3-hydroxyvalerate
HB	-	Hydroxybutyrate
HV	-	Hydroxyvalerate
DNA	-	Deoxyribonucleic acid
PB	-	Prussian blue
FA	-	Formaldehyde (mg/L)

NdFeB	-	Neodymium-Iron-Boron
FISH	-	Fluorescence in situ hybridization
F/M	-	Food-microorganisms ratio
BOD	-	Biochemical oxygen demand
WWTP	-	Wastewater treatment plant
RAS	-	Return activated sludge
FI	-	Filamentous index
RBCOD	-	Readily biodegradable substrates
PAX-14	-	Polyaluminium chloride
SSVI	-	Stirred specific volume index
SRF	-	Specific resistance to filtration
EPS <sub>s</sub>	-	Soluble Extra-cellular polymeric substances
EPS <sub>b</sub>	-	Bound Extra-cellular polymeric substances
<b>SV</b> <sub>30</sub>	-	Sludge volume
AOP	-	Advanced oxidation process
TN	-	Total nitrogen (mg/L)
IWK	-	Indah Water Konsortium
ANOVA	-	Analysis of variance
TP	-	Total phosphorus
OUR	-	Oxygen uptake rate
SOUR	-	Specific oxygen uptake rate
Ag	-	Aggregation (%)
PVSK	-	Polyvinylsulfuric acid potassium salt
HRT	-	Hydraulic retention time
VER	-	Volumetric exchange rate
RH	-	Relative hydrophobicity (%)
SC	-	Surface charge (meq/g MLSS)
DLVO	-	Derjaguin and Landau, Verwey and Overbeek theory
OLR	-	Organic loading rate
AOB	-	Ammonium oxidizing bacteria
PAOs	-	Phosphorus accumulating organisms
VFAs	-	Volatile fatty acids
FESEM	-	Field Emission Scanning Electron Microscopy
TSS	-	Total suspended solids (mg/L or g/L)

AN	-	Ammonia-nitrogen (mg/L)
BSA	-	Bovine serum albumin
FC	-	Folin-Ciocalteu
16S rRNA	-	16 subunit ribosomal ribonucleic acid
LB-EPS	-	Loosely-bound Extra-cellular polymeric substances
TB-EPS	-	Tightly-bound Extra-cellular polymeric substances
PCR	-	Polymerase chain reaction
EPS <sub>T</sub>	-	Total Extra-cellular polymeric substances
PN/PS	-	Protein-to-Polysaccharides ratio

### LIST OF SYMBOLS

Μ	-	Magnetization of a particle
$\chi_{\rm v}$	-	Magnetic susceptibility of the molecules' electrons
Н	-	Applied magnetic field (emu/cm <sup>3</sup> )
E	-	Energy of magnetic gradient
V	-	Volume of the material
F	-	Magnetic interaction force
χο	-	Magnetic susceptibility of the magnetized material
dH/dx	-	Difference of the magnetic field strength with distance
T <sub>i</sub>	-	Turbidity influent (FNU)
$T_{\rm f}$	-	Turbidity effluent (final) (FNU)
$T_0$	-	Turbidity at 0 min (FNU)
$\mu_{overall}$	-	Overall specific biomass growth rate (day <sup>-1</sup> )
k <sub>d</sub>	-	Endogenous decay rate (hour <sup>-1</sup> )
Y <sub>obs</sub>	-	Observed biomass yield (mg VSS/mg COD)
Y	-	Theoretical biomass yield (mg VSS/mg COD)
θ	-	Sludge retention time (d)
$dO_2/dt$	-	Oxygen uptake rate
O <sub>x</sub>	-	Theoretical COD (1.42 mg O <sub>2</sub> /mg biomass)
Μ	-	Biomass concentration (mg VSS/L)
X <sub>e</sub>	-	Effluent volatile suspended solids (mg/L)
Ci	-	COD concentration in the influent (mg/L)
Ce	-	COD concentration in the effluent (mg/L)
X <sub>r</sub>	-	Mixed liquor volatile suspended solid in reactor (mg/L)
V <sub>T</sub>	-	Total working volume in reactor (L)
Qe	-	Effluent flow rate (L/d)

### LIST OF APPENDICES

APPENDIX	TITLE	PAGE
A	Classification of Filamentous Microorganisms Based On Gram and Neisser Staining Reactions	263
В	Factorial Design and Response Surface Methodology Data Analysis for Turbidity Reduction	264
С	Factorial Design and Response Surface Methodology Data Analysis for Aggregation	267
D	Factorial Design and Response Surface Methodology Data Analysis for Settling Velocity	270
Ε	Data and Calculations	274
F	Next Generation Sequencing Data Analysis	303
G	Extra-cellular Polymeric Substances Data Analysis	310

### **CHAPTER 1**

#### **INTRODUCTION**

#### 1.1 Preamble

Activated sludge system was developed in the early 1900s. Since then, it has been the most frequently used process in various wastewater treatment technologies. In general, activated sludge process (ASP) is comprised of two stages which are biological degradation that occurs in an aeration tank, and the physical stage, which takes place in a secondary clarifier. The key feature of the biological degradation process is the responsible bacteria in converting the incoming organic pollutants into the purified water that later, has to be separated from the liquid portion by gravity. The performance of ASP is therefore, relies on bacterial activity and efficient solidliquid separation as to guarantee good effluent quality being discharged from the system (Clauss *et al.*, 1998).

Even though ASP has been the most commonly used technology in treating municipal and industrial wastewaters, its stable operation is still plagued by the solid-liquid separation problem (Martins *et al.*, 2011) caused by the occurrence of sludge bulking. The primary factor that was reported to induce the bulking is the excessive proliferations of the filamentous microorganisms. The abundances of the filaments

have physically prevent the close packing of activated sludge flocs thus cause severe interferences to the separation and settling activities in the treatment process (Lou and De los Reyes, 2008). Such interferences lead to the deterioration of the effluent quality and sludge wash out in the final treated effluent. The sludge bulking occurrence can also become more critical as it can fail the overall treatment system performances particularly in terms of removal ability of the pollutants (Martins *et al.*, 2004a).

For the purpose of enhancing the wastewater treatment processes, various approaches have been used including magnetic field application. This approach has been applied for removal of turbidity and suspended solids (Johan, 2003; Chin *et al.*, 2006), organic compounds (Yavuz and Çelebi, 2000; Ji *et al.*, 2010; Łebkowska *et al.*, 2011), nutrients consists of nitrogen and phosphorus compounds (Liu *et al.*, 2008; Merino-martos *et al.*, 2011) and toxic chemicals (Jung *et al.*, 1993). As to ensure higher effectiveness of these removals, microorganisms have to act efficiently in order to degrade the organic pollutants, resulted in good solid-liquid separation and settling processes. However, provocation by the filamentous sludge bulking can disturb these processes thus cause reduction in removal performances of the wastewater treatment. Through the application of magnetic field, the treatment processes have been proven to be enhanced. These enhancements are resulted from the significant influence of the magnetic field towards the bacterial activity, thus indirectly indicates that it may also potential to control the filamentous sludge bulking problem.

To the recent knowledge, none of the research has been carried out to investigate the effect of magnetic field application towards the sludge bulking especially in terms of filamentous microorganisms' proliferations in the ASP. The existing approaches used to control the sludge bulking were evidenced to exhibit various drawbacks that relatively caused more problems to the ASP. The approaches such as chlorine addition were not sustainable as it only transferring one problem (sludge bulking) to another problem (i.e. increase of sludge wastage), which at the end cause various adverse effects to the environment. Additionally, effect of the approaches is only instantaneously functioned. Once the control effect is halted, the sludge settleability will worsen, and the recovery of the treatment system will consumed lots of time and costs.

Therefore, this study is aimed to investigate the potential approach of the magnetic field in controlling the sludge bulking occurrences, thus further improving the separation and settleability of the activated sludge. As to achieve the aim, physical properties of the activated sludge are first been studied with regards to the variation of magnetic field effects. Furthermore, parameters that are known to induce the sludge bulking; sludge retention time (SRT) and dissolved oxygen (DO) concentration are been further investigated in terms of the characterization of the physical, biological properties and removal ability of the activated sludge. Susceptibility of the filamentous microorganisms towards the magnetic field were also being investigated.

### **1.2** Objectives of the Study

The specific objectives of this study are:

- i. To investigate the potential effects of magnetic field in terms of its intensity and exposure time towards physical properties of the activated sludge.
- To determine the effect of magnetic field on the physical properties, removal ability and microbial activity of activated sludge subjected to long sludge retention time (SRT).

- iii. To investigate the effect of magnetic field on the characteristics of activated sludge bulking subjected to low dissolved oxygen (DO) concentration.
- iv. To investigate the susceptibility of filamentous microorganisms in the activated sludge bulking under magnetic field.

#### **1.3** Scope of the Study

This study focused on the activated sludge bulking under the effect of magnetic field. The range of magnetic field intensity used in this study was 15 mT and 88 mT. These magnets were attached to a laboratory-scale reactor system which its design was based on the sequential batch reactor (SBR) system. All of the experiments were conducted in Environmental Laboratory, Faculty of Civil Engineering, Universiti Teknologi Malaysia (UTM). The wastewater and activated sludge samples were both collected at Indah Water Konsortium (IWK) Treatment Plant, Pulai Emas, Johor. The type of wastewater used throughout the study were raw domestic wastewater.

This study involved batch tests experiments in small working volume of 250 mL. These experiments involved the use of statistical experimental design in order to investigate the significance between the variables of magnetic field, exposure time, biomass concentration and mixing intensity on the physical properties of activated sludge. Consequent experiments were conducted using reactor systems with working volume of 6 L. There were two reactors used throughout the study. Reactor A was an experimented reactor that comprised attached series of permanent magnets while Reactor B was acted as control reactor that have no magnets. For the purpose of studying the activated sludge bulking, the reactors were set in two conditions. For the

first condition, the sludge retention time (SRT) was set at longer period of about 20 days. Later, for the second condition, the dissolved oxygen (DO) was set at concentration of less than 2 mg/L. The final study was then focused on the characteristics of filamentous microorganisms, its abundances and production of extra-cellular polymeric substances (EPS).

#### **1.4** Significance of the Study

Activated sludge bulking is among the operational problems that commonly occurred in the treatment plants worldwide. Various control strategies such as increasing DO concentration, adding chlorine or metal salts have been reported by many researchers in inhibiting the occurrence of sludge bulking (Xie *et al.*, 2007; Li *et al.*, 2011; Guo *et al.*, 2012a). However, these control strategies led to various drawbacks that consequently exhibited more problematic issues to the treatment plants (Juang, 2005; Rossetti *et al.*, 2005; Xie *et al.*, 2007; Guo *et al.*, 2012a). Apparently, the application of magnetic field in inhibiting the sludge bulking has not been explored yet. Therefore, the significance of this study can be listed as follows.

- The study provides the design and procedural input of a laboratory scale SBR system, fabricated to allow attachment of magnetic devices which comprised series of permanent magnets.
- The study provides the effect of applying magnetic field with intensity
   88 mT in the sludge bulking conditions at long SRT of 20 days and
   low DO concentration of less than 2 mg/L.

- iii. The study provides the effect of magnetic field on the biokinetic properties of activated sludge including growth rate ( $\mu$ ), endogenous decay rate ( $k_d$ ), observed biomass yield ( $Y_{obs}$ ) and theoretical biomass yield (Y) under the condition of sludge bulking.
- iv. The study also provides the effect of magnetic field in inhibiting the proliferation of filamentous microorganisms and limiting the growth of its filaments, thus able to reduce the occurrence of sludge bulking.
- v. The study provides the effect of magnetic field in enhancing the production of EPS and its chemical constituents despite the condition of sludge bulking.

### 1.5 Organization of Thesis

The thesis is presented in seven chapters. Chapter 1 provides the overview of the problems generated in the activated sludge wastewater treatment and the conditions of the sludge bulking that concurrently hinder the efficiency of the treatment process. This chapter also points out the significant of the magnetic field in potentially inhibits the occurrence of the sludge bulking in ASP system. The literature review is presented in Chapter 2. This chapter highlights the occurrence of sludge bulking and the factors that cause its occurrence. The approaches used to control this sludge bulking problem and consequent drawbacks are also been emphasized in this chapter. Additionally, this chapter also covers the application of magnetic field in water and wastewater treatment systems. The mechanisms of magnetic field contributed to the various processes in the treatment systems are also been deliberated. At the end of this chapter, a knowledge gap is highlighted showing the potential of magnetic field in inhibiting the sludge bulking.

Chapter 3, 4, 5, and 6 present the works that have been conducted in this study. Chapter 3 presents the study on the preliminary investigation involving the magnetic factors towards the physical properties of the activated sludge. Chapter 4 and Chapter 5 are both focusing on the performances of magnetically-modified ASP bioreactor system that were run under the factor of SRT and DO concentration, respectively as to induce the filamentous sludge bulking condition. Chapter 6 presents the detail study on the filamentous microorganisms particularly on its abundances, micro-structures and EPS. Figure 1.1 presents the overall outline of the experimental works involved. Finally, Chapter 7 presents the conclusions of the study. This chapter also provides recommendation for future research exploration in relation to the findings of the study.

APPLICATION OF MAGNETIC FIELD FOR REDUCTION OF SLUDGE BULKING IN ACTIVATED SLUDGE SYSTEM



Figure 1.1 Outline of the experimental research works

### REFERENCES

- Adav, S.S., and Lee, D.J. (2009). Intrageneric and intergeneric co-aggregation with Acinetobacter calcoaceticus I6. Journal of the Taiwan Institute of Chemical Engineers. 40, 344-347.
- Adav, S.S., Lee, D.J., and Tay, J.H. (2008). Extracellular polymeric substances and structural stability of aerobic granules. *Water Research*. 42, 1644-1650.
- Agridiotis, V., Forster, C.F., and Carliell-Marquet, C. (2007). Addition of Al and Fe salts during treatment of paper mill effluents to improve activated sludge settlement characteristics. *Bioresource Technology*. 98(15), 2926 – 2934.
- Alimi, F., Tlili, M.M., Amor, M.B., Maurin, G., and Gabrielli, C. (2009). Effect of magnetic water treatment on calcium carbonate precipitation: Influence of the pipe material. *Chemical Engineering and Processing: Process Intensification*. 48(8), 1327–1332.
- Ali-Zade, P., Ustun, O., Vardarli, F., and Sobolev, K. (2008). Development of an electromagnetic hydrocyclone separator for purification of wastewater. *Water and Environment Journal*. 22(1), 11–16.
- Al-Mutairi, N.Z. (2009). Aerobic selectors in slaughterhouse activated sludge systems: A preliminary investigation. *Bioresource Technology*. 100 (1), 50 58.
- Ambashta, R.A., Repo, E., and Sillanpää, M. (2011). Degradation of tributyl phosphate using nanopowders of iron and iron-nickel under influence of static magnetic field. *Industrial and Engineering Chemistry Research*. 50, 11771– 11777.
- Ambashta, R.D., and Sillanpää, M. (2010). Water purification using magnetic assistance: A review. *Journal of Hazardous Materials*. 180(1–3), 38–49.
- American Public Health Association (2005). *Standard Methods for the Examination of Water and Wastewater*. (21th ed.). Washington DC, USA.

- Aquino, S.F., and Stuckey, D.C. (2004). Soluble microbial products formation in anaerobic chemostats in the presence of toxic compounds. *Water Research*. 38, 255–266.
- Arami, M., Limaee, N.Y., Mahmoodi, N.M., and Tabrizi, N.S. (2005). Removal of dyes from colored textile wastewater by orange peel adsorbent: Equilibrium and kinetic studies. *Journal of Colloid and Interface Science*. 288, 371–376.
- Augusto, P.A., Castelo-Grande, T., and Augusto, P. (2005). Magnetic classification in health sciences and in chemical engineering. *Chemical Engineering Journal*. 111(2–3), 85–90.
- Azeredo, J., and Oliveira, R. (2000). The role of exopolymer in the attachment of *Sphingomonas paucimobilis. Biofouling*. 16, 59-67.
- Aziz, S.Q., Aziz, H.A., Yusoff, M.S., and Bashir, M.J.K. (2011). Landfill leachate treatment using powdered activated carbon augmented sequencing batch reactor (SBR) process: Optimization by response surface methodology. *Journal of Hazardous Material*. 189, 404-413.
- Azuma, N., Tajima, K., Ishizu, K., Yokoi, I., and Mori, A. (2000). Detection and a possible mechanism of magnetic field effect on the crystal growth of sedimentary calcium carbonate. *Pathophysiology*. 7(2), 83–89.
- Badireddy, A.R., Chellam, S., Gassman, P.L., Engelhard, M.H., Lea, A.S., and Rosso, K.M. (2010). Role of extracellular polymeric substances in bioflocculation of activated sludge microorganisms under glucose-controlled conditions. *Water Research.* 44, 4505-4516.
- Baker, J.S., and Judd, S.J. (1996). Magnetic amelioration of scale formation. Water Research. 30(2), 247–260.
- Baker, J.S., Judd, S.J., and Parsons, S.A. (1997). Anti-scale magnetic pre treatment of reverse osmosis feed water. *Desalination*. 110, 151–166.
- Barrett, R.A., and Parsons, S.A. (1998). Influence of magnetic field on calcium carbonate precipitation. *Water Research*. 32(3), 609–612.
- Barrett, R.A., Parsons, S.A., and Hillis, P. (1999). A review of some of the analytical methods used to assess the influence of magnetic treatment. *Proceedings of the 3<sup>rd</sup> International Conference on Antiscale Magnetic Treatment and Physical Conditions*. Cranfield University, Cranfield, UK.

- Bashir, M.J.K., Aziz, H.A., Yusoff, M.S., Aziz, S.Q., and Mohajeri, S. (2010). Stabilized sanitary landfill leachate treatment using anionic resin: Treatment optimization by response surface methodology. *Journal of Hazardous Materials*. 182, 115-122.
- Bée, A., Talbot, D., Abramson, S., and Dupuis, V. (2011). Magnetic alginate beads for Pb(II) ions removal from wastewater. *Journal of Colloid and Interface Science*. 362(2), 486–492.
- Bengtssn, S., Werker, A., Christensson, M., and Welander, T. (2008). Production of polyhydroxyalkanoates by activated sludge treating a paper mill wastewater. *Bioresource Technology*. 99(3), 509–516.
- Bernardin, J.D., and Chan, S.H. (1991). Magnetic effect on simulated brine properties pertaining to magnetic water treatment. *Journal of Crystal Growth*. 108, 792.
- Beukes, J.P., Giesekke, E.W., and Elliott, W. (2000). Nickel retention by goethite and hematite. *Minerals Engineering*. 13(14–15), 1573–1579.
- Blackall, L.L. (1994). Molecular-identification of activated-sludge foaming bacteria. Water Science and Technology. 29, 35-42.
- Bogatin, J., Bondarenko, N.P., Gak, E.Z., Rokhinson, E.F., and Ananyev, I.P. (1999).
   Magnetic treatment of irrigation water: Experimental results and application conditions. *Environmental Science and Technology*. 33, 1280–1285.
- Bolto, B.A. (1990). Magnetic particle technology for wastewater treatment. *Waste Management*. 10, 11-21.
- Bott, C.B. and Love, N.G. (2002). Investigating on mechanistic cause for activated sludge deflocculation in response to shock loads of toxic electrophilic chemicals. *Water Environment Research*. 74, 306 – 315.
- Bruk, O.B., Klassen, V.I., and Krylov, O.T. (1987). Mechanism of magnetic treatment of disperse system. Soviet Surface Engineering and Applied Electrochemistry. 6, 45–50.
- Busch, K.W., and Busch, M.A. (1997). Laboratory studies on magnetic water treatment and their relationship to a possible mechanism for scale reduction. *Desalination*. 109(2), 131–148.

- Busch, K.W., Busch, M.A., Parker, D.H., Darling, R.E., and McAtee Jr., J.L. (1986). Studies of a water treatment device that uses magnetic fields. *Corrosion*. 42(4), 211–221.
- Busch, K.W., Opalakrishnan, S., Busch, M.A., and Tombácz, E. (1996). Magnetohydrodynamic aggregation of cholesterol and polystyrene latex suspensions. *Journal of Colloid and Interface Science*. 183, 528–538.
- Chakraborty, S., Purkait, M.K., Dasgupta, S., De, S., and Basu, J.K. (2003). Nanofiltration of textile plant effluent for colour removal and reduction in COD. *Separation and Purification Technology*. 31, 141–151.
- Chang, I.-S., and Lee, C.-H. (1998). Membrane filtration characteristics in membrane-coupled activated sludge system - the effect of physiological states of activated sludge on membrane fouling. *Desalination*. 120, 221-233.
- Chang, M.-C., and Tai, C.Y. (2010). Effect of the magnetic field on the growth rate of aragonite and the precipitation of CaCO<sub>3</sub>. *Chemical Engineering Journal*. 164(1), 1–9.
- Chen, H., and Li, X. (2008). Effect of static magnetic field on synthesis of polyhydroxyalkanoates from different short-chain fatty acids by activated sludge. *Bioresource Technology*. 99(13), 5538–5544.
- Chen, H., Zhou, S., and Li, T. (2013). Impact of extracellular polymeric substances on the settlement ability of aerobic granular sludge. *Environmental Technology*. 31(14), 1601-1612.
- Chen, K., Lei, H., Li, Y., Li, H., Zhang, X., and Yao, C. (2011). Physical and chemical characteristics of waste activated sludge treated with electric field. *Process Safety and Environmental Protection*. 89 (5), 327 – 333.
- Chen, Y., Jiang, W., and Liang, D.T. (2008b). Biodegradation and kinetics of aerobic granules under high organic loading rates in sequencing batch reactor. *Applied Microbiology and Biotechnology*. 79, 301 – 308.
- Chen, Y., Jiang, W., Liang, D.T., and Tay, J.H. (2008a). Aerobic granulation under the combined hydraulic and loading selection pressures. *Bioresource Technology*. 99, 7444-7449.
- Chibowski, E., Holysz, L., and Aleksandra, S. (2003). Adhesion of in situ precipitated calcium carbonate in the presence and absence of magnetic field in

quiescent conditions on different solid surfaces. *Water Research*. 37(19), 4685–4692.

- Chiesa, S.C., Irvine, R.L., and Manning, J.F. (1985). Feast/famine growth environments and activated sludge population selection. *Biotechnology and Bioengineering*. 27, 562 568.
- Chin, C.-J.M., Chen, P.-W., and Wang, L.-J. (2006). Removal of nanoparticles from CMP wastewater by magnetic seeding aggregation. *Chemosphere*. 63(10), 1809-1813.
- Chudoba, J., Grau, P., and Ottová, V. (1973). Control of activated sludge filamentous bulking- II. Selection of microorganisms by means of a selector. *Water Research*. 7(10), 1389 – 1398.
- Clauss, F., Balavoine, C., Hélaine, D., and Martin, G. (1999). Controlling the settling of activated sludge in pulp and paper wastewater treatment plants. *Water Science and Technology*. 40, 223 – 229.
- Clauss, F., Hélaine, D., Balavoine, C., and Bidault, A. (1998). Improving activated sludge floc structure and aggregation for enhanced settling and thickening performances. *Water Science and Technology*. 38, 35-44.
- Clayton, A.J., Wentzel, M.C., Ekama, G.A., and Marais. G.V.R. (1991). Denitrification kinetics in biological nitrogen and phosphorus removal systems treating municipal wastewaters. *Water Science and Technology*. 23(4 – 6), 567 – 576.
- Coey, J.M.D., and Cass, S. (2000). Magnetic water treatment. *Journal of Magnetism and Magnetic Materials*. 209, 71–74.
- Colic, M., and Morse D. (1999) The elusive mechanism of the magnetic 'memory' of water. Colloids and Surfaces A: Physicochemical and Engineering Aspects. 154(1-2), 167–174.
- Colic, M., and Morse, D. (1998). Effects of amplitude of the radiofrequency electromagnetic radiation on aqueous suspensions and solutions. *Journal of Colloid and Interface Science*. 200, 265–272.
- Comas, J., Rodríguez-Roda, I., Gernaey, K.V., Rosen, C., Jeppsson, U., and Poch, M. (2008). Risk assessment modeling of microbiology related solids separation problems in activated sludge systems. *Environmental and Modelling Software*. 23, 1250 – 1261.

- Corredig, M., Sharafbafi, N., and Kristo, E. (2011). Polysaccharide-protein interactions in dairy matrices, control and design of structures. *Food Hydrocolloids*. 25, 1833-1841.
- Cydzik-Kwiatkowska, A., and Zielińska, M. (2016). Bacterial communities in full scale wastewater treatment systems. *World Journal of Microbiology and Biotechnology*. 32(66), 1 8.
- Davies, P.S. (2005). *The Biological Basis of Wastewater Treatment*. Glasgow, UK: Strathkelvin Instruments Ltd.
- De Gregorio, C., Caravelli, A.H., and Zaritzky, N.E. (2010). Performance and biological indicators of a laboratory scale activated sludge reactor with phosphate simultaneous precipitation as affected by ferric chloride addition. *Chemical Engineering Journal*. 165(2), 607 – 616.
- De los Reyes, F.L. (2010). Foaming. In: Seviour, R.J., and Nielsen, P.H. (Eds.) *Microbial Ecology of Activated Sludge* (pp. 215-258). London, UK: IWA Publishing.
- Dignac, M.F., Urbain, V., Rybacki, D., Bruchet, A., Snidaro, D., and Scribe, P. (1998). Chemical description of extracellular polymeric substances: implication on activated sludge floc structure. *Water Science and Technology*. 38(8–9), 45– 53.
- Dionisi, D., Carucci, G., Petrangeli, P.M., Riccardi, C., Majone, M., and Carrasco, F. (2005). Olive oil mill effluents as a feedstock for production of biodegradable polymers. *Water Research*. 39(10), 2076–2084.
- Donaldson, J.D. (1988). Scale prevention and descaling. Tube Int. January, 39-49.
- Drzewicki, A., Klimiuk, E., and Kulikowska, D. (2007). The influence of hydraulic retention time and sludge age on activated sludge biocenosis formation in SBRs treating landfill leachates. *Polish Journal of Natural Sciences*. 22(3), 425 446.
- Duan, J., and Gregory, J. (2003). Coagulation by hydrolysing metal salts. *Advances in Colloid and Interface Science*. 100–102, 475 502.
- Dubber, D., and Gray, N.F. (2011). The effect of anoxia and anaerobia on ciliate community in biological nutrient removal systems using laboratory-scale sequencing batch reactors (SBRs). *Water Research*. 45, 2213 – 2226.

- Dubois, M., Gilles, K.A., Hamilton, J.K., Rebers, P.A., and Smith, F. (1956). Colorimetric method for determination of sugars and related substances. *Analytical Chemistry*. 28, 350–356.
- Eikelboom, D.H., and Grovenstein J. (1998). Control of bulking in a full-scale plant by addition of talc. *Water Science and Technology*. 37, 297 301.
- Eckenfelder, W. W. and Grau, P. (1992). Activated Sludge Process Design: Theory and Practice (eds.) Lancaster, PA: Technomic Publishing.
- Eikelboom, D.H. (2000). *Process control of activated sludge plants by microscopic investigation*. London: IWA Publishing.
- Eikelboom, D.H., Andreadakis, A., and Andreasen, K. (1998). Survey of filamentous populations in nutrient removal plants in four European countries. *Water Science and Technology*. 37 (4/5), 281 289.
- Ellingsen, F.T., and Vik, E.A. (1982). A review of scale formation with emphasis on magnetic water treatment. *Proceeding 14th World Congress International Water Supply Association*. Zurich SS8, 12–25.
- Fang, M., Mishima, F., Akiyama, Y., and Nishijima, S. (2010). Fundamental study on magnetic separation of organic dyes in wastewater. *Physica C*. 470(20), 1827-1830.
- Fathi, A., Mohamed, T., Claude, G., Maurin, G., and Mohamed, B.A. (2006). Effect of a magnetic water treatment on homogeneous and heterogeneous precipitation of calcium carbonate. *Water Research*. 40(10), 1941–1950.
- Ferreira, V., Martins, C., Pereira, M.O., and Nicolau, A. (2014). Use of an aerobic selector to overcome filamentous bulking in an activated sludge wastewater treatment plant. *Environmental Technology*. 35(12), 1525-1531.
- Fiałkowska, E., and Pajdak-Stós, A. (2008). The role of Lecane rotifers in activated sludge bulking control. *Water Research*. 42, 2483-2490.
- Filipič, J., Kraigher, B., Tepuš, B., Kokol, V., and Mandic-Mulec, I. (2012). Effects of low-density static magnetic fields on the growth and activities of wastewater bacteria *Escherichia coli* and *Pseudomonas putida*. *Bioresource Technology*. 120, 225-232.
- Franzreb, M., and Holl, W.H. (2000). Phosphate removal by high gradient magnetic filtration using permanent magnets. *IEEE Transactions on Applied Superconductivity*. 10(1), 923–926.

- Frølund, B., Palmgren, R., Keiding, K., and Nielsen, P.H. (1996). Extraction of extracellular polymers from activated sludge using a cation exchange resin. *Water Research*. 30(8), 1749–1758.
- Fyda, J., Babko, R., Fiałkowska, E., Pajdak-Stós, A., Kocerba-Soroka, W., Sobczyk, M. and Sobczyk, Ł. (2015). Effect of high levels of the rotifer *Lecane inermis* on the ciliate community in laboratory-scale sequencing batch bioreactors (SBRs). *European Journal of Protistology*. 51, 470-479.
- Garnier, C., Görner, T., Lartiges, B.S., Abdelouhab, S., and de Donato, P. (2005). Characterization of activated sludge exopolymers from various origins: A combined size-exclusion chromatography and infrared microscopy study. *Water Research.* 39:3044 – 3054.
- Gaval, G., and Pernelle, J.-J. (2003). Impact of the repetition of oxygen deficiencies on the filamentous bacteria proliferation in activated sludge. *Water Research*. 37, 1991 – 2000.
- Gehr, R., Zhai, Z.A., Finch, J.A., and Rao, R. (1995). Reduction of soluble mineral concentrations in CaSO<sub>4</sub> saturated water using a magnetic field. *Water Research*. 29, 933–940.
- Gerencser, V.F., Barnothy, M.F., and Barnothy, J.M. (1962). Inhibition of bacterial growth by magnetic field. *Nature*. 196, 539–541.
- Girginova, P.I., Daniel-da-Silva, A.L., Lopes, C.B., Figueira, P., Otero, M., Amaral, V.S., Pereira, E., and Trindade, T. (2010). Silica coated magnetite particles for magnetic removal of Hg<sup>2+</sup> from water. *Journal of Colloid and Interface Science*. 345(2), 234–240.
- Gogol-Döring, A., and Chen, W. (2012). An overview of the analysis of next generation sequencing data. In Wang, J., Tan, A.C., and Tian, T. (Eds.) Next Generation Microarray Bioinformatics: Methods and Protocols, Methods in Molecular Biology. (pp. 249-257). Springer New York Dordrecht Heidelberg London: Humana Press.
- Gonet, B. (1985). Influence of constant magnetic fields on certain physiochemical properties of water. *Bioelectromagnetics*. 6, 169–175.
- Gray, N.F. (2004). *Biology of wastewater treatment*. (2<sup>nd</sup> ed.). London: Imperial College Press.

- Gregory, J. (2009). Monitoring particle aggregation processes. *Advances in Colloid* and Interface Science. 147 – 148, 109 – 123.
- Guo, F., and Zhang, T. (2012). Profiling bulking and foaming bacteria in activated sludge by high throughput sequencing. *Water Research*. 46, 2772 2782.
- Guo, J., Peng, Y., Wang, S., Yang, X., Wang, Z., and Zhu, A. (2012a). Stable limited filamentous bulking through keeping the competition between the floc-formers and filaments in balance. *Bioresource Technology*. 103, 7-15.
- Guo, J., Peng, Y., Wang, Z., Yuan, Z., Yang, X., and Wang, S. (2012b). Control filamentous bulking caused by chlorine-resistant Type 021N bacteria through adding a biocide CTAB. *Water Research*. 46, 6531-6542.
- Guo, J., Wang, S., Wang, Z., and Peng, Y. (2014). Effects of feeding pattern and dissolved oxygen concentration on microbial morphology and community structure: The competition between floc-forming bacteria and filamentous bacteria. *Journal of Water process Engineering*. 1, 108-114.
- Ha, D.W., Kwon, J.M., Baik, S.K., Lee, Y.J., Han, K.S., Ko, R.K., Sohn, M.H., and Seong, K.C. (2011). Purification of condenser water in thermal power station by superconducting magnetic separation. *Physica C*. 471(21–22), 1530–1532.
- Hao, X.L., Zou, L.Y., Zhang, G.S., and Zhang, Y.B. (2009). Magnetic field assisted Fenton reactions for the enhanced degradation of methyl blue. *Chinese Chemical Letters*. 20(1), 99-101.
- Harasko, G., Pfützner, H., Rapp, E., Futschik, K., and Schüler, D. (1993). Determination of the concentration of magnetotactic bacteria by means of susceptibility measurements. *Japan Journal of Applied Physics*. 32, 252-260.
- Hattori, S., Watanabe, M., Osono, H., Togii, H., and Sasaki, K. (2001). Effects of an external magnetic field on the flock size and sedimentation of activated sludge. *World Journal of Microbiology and Biotechnology*. 17, 833 – 838.
- Hattori, S., Watanabe, M., Sasaki, K., and Yasuharu, H. (2002). Magnetization of activated sludge by an external magnetic field. *Biotechnology Letters*. 24, 65-69.
- Henze, M., Dupont, R., Grau, P., and De la Sota, A. (1993). Rising sludge in secondary settlers due to denitrification. *Water Research*. 27 (2), 231 – 236.
- Herzog, R.E., Shi, Q.H., Patil, J.N., and Katz, J.L. (1989). Magnetic water treatment: The effect of iron on calcium carbonate nucleation and growth. *Langmuir*. 5(3), 861-867.

- Hibben, S.G. (1973). *Magnetic Treatment of Water*. Arlington, VA: Air Force Office of Scientific Research, Advance Research Projects Agency.
- Higashitani, K., and Oshitani, J. (1998). Magnetic effects on thickness of adsorbed layer in aqueous solutions evaluated directly by atomic force microscope. *Journal of Colloid and Interface Science*. 204, 363–368.
- Higashitani, K., Iseri, H., Okuhara, K., Kage, A., and Hatade, S. (1995). Magnetic effects on zeta potential and diffusivity of nonmagnetic colloidal particles. *Journal of Colloid and Interface Science*. 172(1), 383–388.
- Higashitani, K., Kage, A., Katamura, S., Imai, K., and Hatade, S. (1993). Effects of magnetic field on formation of CaCO<sub>3</sub> particles. *Journal of Colloid and Interface Science*. 156, 90–95.
- Higashitani, K., Okuhara, K., and Hatade, S. (1992). Effects of magnetic fields on stability of non-magnetic ultrafine colloidal particles. *Journal of Colloid and Interface Science*. 152, 125–131.
- Higgins, M.J., and Novak, J.T. (1997). Characterization of exocellular protein and its role in bioflocculation. *Journal of Environmental Engineering*. 123(5), 479-485.
- Hirschbein, B.L., Brown, D.W., and Whitesides, G.M. (1982). Magnetic separations in Chemistry and Biochemistry. *Chem. Technol.* 12(3), 172–179.
- Hong, C., HaiBo, L., and YunFeng, X. (2010). Acclimating PHA storage capacity of activated sludge with static magnetic fields. *Enzyme and Microbial Technology*. 46, 594–597.
- Hong, C., Hao, H., and Haiyun, W. (2009). Process optimization for PHA production by activated sludge using response surface methodology. *Biomass Bioenergy*. 33(4), 721–727.
- Hu, X., Dong, H.-Y., Qiu, Z.-N., Qian, G.-R., Ye, L., Zhu, H.-C., and Ren, Z.-M. (2007). The effect of high magnetic field characterized by kinetics: Enhancing the biodegradation of acid red 1 with a strain of *Bacillus sp. International Biodeterioration and Biodegradation*. 60(4), 293–298.
- Hu, X., Yang, J., and Zhang, J. (2011). Magnetic loading of TiO<sub>2</sub>/SiO<sub>2</sub>/Fe<sub>3</sub>O<sub>4</sub> nanoparticles on electrode surface for photoelectrocatalytic degradation of diclofenac. *Journal of Hazadous Materials*. 196, 220-227.

- Huang, X., Gui, P., and Qian, Y. (2001). Effect of sludge retention time on microbial behaviour in a submerged membrane bioreactor. *Process Biochemistry*. 36, 1001– 1006.
- Hwang, Y., and Tanaka, T. (1998). Control of *Microthrix parvicella* foaming in activated sludge. *Water Research*. 32, 1678 1686.
- Hwang, Y., Kim, C., and Choo, I. (2005). Simultaneous Nitrification/Denitrification in a Single Reactor using Ciliated Columns Packed with Granular Sulfur. *Water Quality Research Journal of Canada*. 40, 91–96.
- Inamori, Y., Kuniyasu, Y., Sudo, R., and Koga, M. (1991). Control of the growth of filamentous microorganisms using predacious ciliated protozoa. *Water Science* and Technology. 23, 963 – 971.
- Ishiwata, T., Miura, O., Hosomi, K., Shimizu, K., Ito, D. and Yoda, Y. (2010). Removal and recovery of phosphorus in wastewater by superconducting high gradient magnetic separation with ferromagnetic adsorbent. *Physica C*. 470, 1818–1821.
- Iwasaka, M., and Ueno, S. (1997). Effects of gradient magnetic field on diffusion process of glycine in water. *IEEE Transactions on Magnetics*. MAG. 33(5), 4254– 4256.
- Iwasaka, M., and Ueno, S. (1998). Structure of water molecules under 14T magnetic field. *Journal of Applied Physics*. 83(11), 6459-6461.
- Jain, R., and Sikarwar, S. (2008). Removal of hazardous dye Congo red from waste material. *Journal of Hazardous Materials*. 152, 942–948.
- Jenkins, D. (1992). Towards a comprehensive model of activated sludge bulking and foaming. *Water Science and Technology*. 25 (6), 215 230.
- Jenkins, D., Richard, M.G., and Daigger, G.T. (1993). *Manual on the causes and control of activated sludge bulking and foaming*. (2<sup>nd</sup> ed.). Chelsea: Lewis Publishers.
- Jenkins, D., Richard, M.G., and Daigger, G.T. (2004). *Manual on the cause and control of activated sludge bulking, foaming and other solids separation problems.* (3<sup>rd</sup> ed.). Chelsea: Lewis Publishers.
- Jennison, M.W. (1937). The growth of bacteria, yeasts and molds in a strong magnetic field. *Journal of Bacteria*. 33, 15-16.

- Ji, Y., Wang, Y., Sun, J., Yan, T., Li, J., Zhao, T., Yin, X., and Sun, C. (2010). Enhancement of biological treatment of wastewater by magnetic field. *Bioresource Technology*. 101, 8535-8540.
- Jin, B., Wilén, B.-M. and Lant, P. (2003). A comprehensive insight into floc characteristics and their impact on compressibility and settleability of activated sludge. *Chemical Engineering Journal*. 95, 221–234.
- Jin, B., Wilén, B.-M., and Lant, P. (2004). Impacts of morphological, physical and chemical properties of sludge flocs on dewaterability of activated sludge. *Chemical Engineering Journal.* 98, 115-126.
- Johan, S. (2003). Effect of Magnetic Field on the Sedimentation of Suspended Solids of Sewage. Thesis of Philosophy of Doctorate, Universiti Teknologi Malaysia, Skudai.
- Joshi, K.M., and Kamat, P.V. (1966). Effect of magnetic field on the physical properties of water. *Journal of Indian Chemical Society*. 43(9), 620-622.
- Juang, D.–F. (2005). Effects of synthetic polymer on the filamentous bacteria in activated sludge. *Bioresource Technology*. 96, 31 40.
- Jung, J., Sanji, B., Godbole, S., and Sofer, S. (1993). Biodegradation of phenol: A comparative study with and without applying magnetic fields. *Journal of Chemical Technology and Biotechnology*. 556, 73-76.
- Jung, J.T., and Sofer, S. (1997). Enhancement of phenol biodegradation by south magnetic field exposure. *Journal of Chemical Technology and Biotechnology*. 70, 299–303.
- Kamariah, M.S. (2006). Subsurface flow and free water surface flow constructed wetland with magnetic field for leachate treatment. Thesis of Master of Engineering (Civil-Wastewater), Universiti Teknologi Malaysia, Skudai.
- Kämpfer, P. (1997). Detection and cultivation of filamentous bacteria from activated sludge. *FEMS Microbiology Ecology*. 23, 169 – 181.
- Kappeler, J., and Gujer, W. (1994). Influences of wastewater composition and operating conditions on activated sludge bulking and scum formation. *Water Science and Technology*. 30, 181 – 189.
- Karapinar, N. (2003). Magnetic separation of ferrihydrite from wastewater by magnetic seeding and high-gradient magnetic separation. *International Journal of Mineral Processing*. 71(1-4), 45–54.

- Khan, A.R., Kocianova, E., and Forster, C.F. (1991). Activated sludge characteristics in relation to stable foam formation. *Journal of Chemical Technology and Biotechnology*. 52, 383 – 392.
- Kim, D.-S., Jung, N.-S. and Park, Y.-S. (2008). Characteristics of nitrogen and phosphorus removal in SBR and SBBR with different ammonium loading rates. *Korean Journal of Chemical Engineering*. 25(4), 793 – 800.
- Kney, A.D., and Parsons, S.A. (2006). A spectrophotometer-based study of magnetic water treatment: Assessment of ionic vs. surface mechanisms. *Water Research*. 40(3), 517–524.
- Kobe, S., Drazic, G., Cefalas, A.C., Sarantopoulou, E., and Strasizar, J. (2002). Nucleation and crystallization of CaCO<sub>3</sub> in applied magnetic fields. *Crystal Engineering*. 5(3–4), 243–253.
- Kraber, S. (2002). Handbook for experimenters. Minneapolis, USA: Stat-Ease Inc.
- Kragelund, C., Thomsen, T.R., Mielczarek, A.T., and Nielsen, P.H. (2011). Eikelboom's morphotype 0803 in activated sludge belongs to the genus *Caldilinea* in the phylum Chloroflexi. *FEMS Microbiology Ecology*. 76 (3), 451-462.
- Křiklavová, L., Truhlář, M., Škodová, P., Lederer, T., and Jirků, V. (2014). Effects of a static magnetic field on phenol degradation effectiveness and *Rhodococcus erythropolis* growth and respiration in a fed-batch reactor. *Bioresource Technology*. 167, 510-513.
- Kristensen, G.H., Jorgensen, P.E., and Nielsen, P.H. (1994). Settling characteristics of activated sludge in Danish treatment plants with biological nutrient removal. *Water Science and Technology*. 29 (7), 157 – 165.
- Kronenberg, K.J. (1985). Experimental evidence for effects of magnetic fields on moving water. *IEEE Transactions on Magnetics*. MAG-21(5), 2059–2061.
- Kruit, J., Boley, F., Jacobs, L.J.A.M., and Wouda, T.W.M. (1994). Prediction of the O<sub>2</sub> conditions in the selector. *Water Science and Technology*. 29(7), 229 237.
- Kruit, J., Hulsbeek, J., and Visser, A. (2002). Bulking sludge solved. *Water Science and Technology*. 46, 457 464.
- Krzemieniewski, M. and Dębowski, M. (2005). The influence of a constant electromagnetic field on phosphorus removal from wastewater in metal packing systems. *Environment Protection Engineering*. 31 (1), 23 – 37.

- Laspidou, C.S., and Rittmann, B.E. (2002). A unified theory for extracellular polymeric substances, soluble microbial products, and active and inert biomass. *Water Research*. 36, 2711–2720.
- Łebkowska, M., Narożniak-Rutkowska, A., and Pajor, E. (2013). Effect of a static magnetic field of 7 mT on formaldehyde biodegradation in industrial wastewater from urea-formaldehyde resin production by activated sludge. *Bioresource Technology*. 132, 78-83.
- Łebkowska, M., Rutkowska-Narożniak, A., Pajor, E., and Pochanke, Z. (2011). Effect of a static magnetic field on formaldehyde biodegradation in wastewater by activated sludge. *Bioresource Technology*. 102(19), 8777-8782.
- Ledion, J., Leroy, P., Labbe, J.P., Durand, G., and Duigou, A.L. (1980). Scaling caused by natural water, and the action of electric anti-scaling devices. *Materials Technology*. 68, 139–144.
- Lednev, V.V. (1991). Possible mechanism for the influence of weak magnetic fields on biological systems. *Bioelectromagnetics*. 12, 71–75.
- Li, J., Li, Y., Ohandja, D.-G., Yang, F., Wong, F.-S., and Chua, H.-C. (2008b). Impact of filamentous bacteria on properties of activated sludge and membranefouling rate in a submerged MBR. *Separation Purification Technology*. 59, 238-243.
- Li, J., Liu, Y., Zhang, T., Wang, L., Liu, X., and Dai, R. (2011). The effect of Ni(II) on properties of bulking activated sludge and microbial analysis of sludge using 16S rDNA gene. *Bioresource Technology*. 102(4), 3783 – 3789.
- Li, S.Q., Wang, M.F., Zhu, Z.A., Wang, Q., Zhang, X., Song, H.Q., and Cang, D.Q. (2012). Application of superconducting HGMS technology on turbid wastewater treatment from converter. *Separation Purification Technology*. 84, 56-62.
- Li, Y., Liu, Y., and Xu, H. (2008a). Is sludge retention time a decisive factor for aerobic granulation in SBR? *Bioresource Technology*. 99, 7672-7677.
- Li, Z.H., Kuba, T., and Kusuda, T. (2006). The influence of starvation phase on the properties and the development of aerobic granules. *Enzyme Microbial Technology*. 38, 670 – 674.
- Liang, Z., Li, W., Yang, S., and Du, P. (2010). Extraction and structural characteristics of extracellular polymeric substances (EPS), pellets in autotrophic nitrifying biofilm and activated sludge. *Chemosphere*. 81, 626-632.

- Liao, B.Q., Allen, D.G., Droppo, I.G., Leppard, G.G., and Liss, S.N. (2001). Surface properties of sludge and their role in bioflocculation and settleability. *Water Research.* 35, 339 – 350.
- Liao, B.Q., Droppo, I.G., Leppard, G.G., and Liss, S.N. (2006). Effect of solids retention time on structure and characteristics of sludge flocs in sequencing batch reactors. *Water Research*. 40, 2583-2591.
- Liao, J., Lou, I., and De Los Reyes III, F.L. (2004). Relationship of species-specific filament levels to filamentous bulking in activated sludge. *Applied and Environmental Microbiology*. 70(4), 2420-2428.
- Linlin, H., Jianlong, W., Xianghua, W., and Yi, Q. (2005). The formation and characteristics of aerobic granules in sequencing batch reactor (SBR) by seeding anaerobic granules. *Process Biochemistry*. 40, 5-11.
- Lipus, L.C., Krope, J., and Crepinsek, L. (2001). Dispersion destabilization in magnetic water treatment. *Journal of Colloid and Interface Science*. 236, 60–66.
- Liu, B., Gao, B., Xu, X., Hong, W., Yue, Q., Wang, Y., and Su, Y. (2011). The combined use of magnetic field and iron-based complex in advanced treatment of pulp and paper wastewater. *Chemical Engineering Journal*. 178, 232–238.
- Liu, H., and Fang, H.H.P. (2002). Extraction of extracellular polymeric substances (EPS) of sludge. *Journal of Biotechnology*. 95, 249-256.
- Liu, S., Yang, F., Meng, F., Chen, H., and Gong, Z. (2008). Enhanced anammox consortium activity for nitrogen removal: Impacts of static magnetic field. *Journal* of Biotechnology. 138(3-4), 96-102.
- Liu, Y., and Fang, H.H.P. (2003). Influences of extracellular polymeric substances (EPS) on flocculation, settling and dewatering of activated sludge. *Critical Reviews in Environmental Science and Technology*. 33(3), 237 – 273.
- Liu, Y., and Tay, J.H. (2002). The essential role of hydrodynamic shear force in the formation of biofilm and granular sludge. *Water Research*. 36, 1653-1665.
- Liu, Y., Yang, S.F., Liu, Q.S., and Tay, J.H. (2003). The role of cell hydrophobicity in the formation of aerobic granules. *Current Microbiology*. 46, 270-274.
- Liu, Y., Yang, S.F., Tay, J.H., Liu, Q.S., Qin, L. and Li, Y. (2004b). Cell hydrophobicity is a triggering force of biogranulation. *Enzyme and Microbial Technology*. 34, 371 – 379.

- Liu, Y.Q., and Tay, J.H. (2007). Influence of cycle time on kinetic behaviours of steady state aerobic granules in sequencing batch reactors. *Enzyme and Microbial Technology*. 41, 516 – 522.
- Liu, Y.Q., Liu, Y., and Tay, J.H. (2004a). The effects of extracellular polymeric substances on the formation and stability of biogranules. *Applied Microbiology and Biotechnology*. 65, 143-148.
- Lombraña, J.I., Varona, F., and Mijangos, F. (1993). Biokinetic behaviour and settling characteristics in an activated sludge under the effect of toxic Ni(II) influents. *Water, Air, Soil Pollution.* 69, 57 68.
- Lou, I.C., and De los Reyes III, F.L. (2008). Clarifying the roles of kinetics and diffusion in activated sludge filamentous bulking. *Biotechnology and Bioengineering*. 101(2), 327-336.
- Lowry, O.H., Rosebrough, N.J., Farr, A.L., and Randall, R.J. (1951). Protein measurement with the folin phenol reagent. *Journal of Biological Chemistry*. 193, 265–275.
- Lychagin, N.I. (1974). Changing properties of magnetized water. *Russian Physics Journal*. 17(2), 229–233.
- Madoni, P., and Davoli, D. (1993). Control of Microthrix parvicella growth in activated sludge. *FEMS Microbiology Ecology*. 12, 277 284.
- Madoni, P., and Davoli, D. (1997). Testing the control of filamentous microorganisms responsible for foaming in a full-scale activated sludge plant running with initial aerobic or anoxic contact zones. *Bioresource Technology*. 60, 43-49.
- Madoni, P., Davoli, D., and Gibin, G. (2000). Survey of filamentous microorganisms from bulking and foaming activated sludge plants in Italy. *Water Research.* 34 (6), 1767 1772.
- Madsen, H.E.L. (2004). Crystallization of calcium carbonate in magnetic field ordinary and heavy water. *Journal of Crystal Growth*. 267, 251–255.
- Male, J. (1992). Biological effects of magnetic fields: A possible mechanism? *Biologist.* 39, 87-89.
- Marechal, M.L., Slokar, Y.M., and Taufer, T. (1997). Decolouration of chlorotriazine reactive azo dyes with H<sub>2</sub>O<sub>2</sub>/UV. *Dyes Pigment*. 33, 181–298.

- Mariani, G., Fabbri, M., Negrini, F., and Ribani, P.L. (2010). High-Gradient Magnetic Separation of pollutant from wastewaters using permanent magnets. *Separation Purification Technology*. 72, 147-155.
- Marten, W.L., and Daigger, G.T. (1997). Full scale evaluation of factors affecting the performance of anoxic selectors. *Water Environment Research*. 69 (7), 1271 1281.
- Martins, A.M.P., Karahan, Ö., and Van Loosdrecht, M.C.M. (2011). Effect of polymeric substrate on sludge settleability. *Water Research*. 45(1), 263-273.
- Martins, A.M.P., Pagilla, K., Heijnen, J.J., and Van Loosdrecht, M.C.M. (2004a). Filamentous bulking sludge – A review. *Water Research*. 38, 793-817.
- Martins, A.M.P., Picioreanu, C., Heijnen, J.J., and van Loosdrecht, M.C.M. (2004b). Three-dimensional dual morphotype species modeling of activated sludge flocs. *Environmental Science and Technology*. 38 (21), 5632 – 5641.
- Martins, A.M.P., Van Loosdrecht, M.C.M., and Heijnen, J.J. (2003). Effect of feeding pattern and storage on the sludge settleability under aerobic conditions. *Water Research*. 37(11), 2555 – 2570.
- Meng, F., Zhang, H., Yang, F., Li, Y., Xiao, J., and Zhang, X. (2006). Effect of filamentous bacteria on membrane fouling in submerged membrane bioreactor. *Journal of Membrane Science*. 272, 161–168.
- Mergen, M.R.D., Jefferson, B., Parsons, S.A., and Jarvis, P. (2008). Magnetic ion exchange resin treatment: Impact of water type and resin use. *Water Research*. 42(8–9), 1977–1988.
- Merino-Martos, A., de Vicente, J., Cruz-Pizarro, L., and De Vicente, I. (2011). Setting up High Gradient Magnetic Separation for combating eutrophication of inland waters. *Journal of Hazardous Materials*. 186(2-3), 2068-2074.
- Metcalf and Eddy (2003). *Wastewater Engineering: Treatment and Reuse*. (4th ed.). Boston: McGraw Hill Companies Inc.
- Metcalf and Eddy Inc. (2002). In: Tchobanoglous, G., Burton, F.L., Stensel, H.D. (Eds.). Wastewater Engineering: Treatment and Reuse. New York: McGraw Hill Companies Inc.
- Mikkelsen, L.H. and Keiding, K. (2002). Physico-chemical characteristics of full scale sewage sludges with implications to dewatering. *Water Research*. 36 (10), 2451–2462.

- Mikkelsen, L.H., Gotfredsen, A.K., Agerbk, M.A., Nielsen, P.H., and Keiding, K. (1996). Effects of colloidal stability on clarification and dewatering of activated sludge. *Water Science and Technology*. 34: 449 – 457.
- Morgan, J.W., Forster, C.F., and Evison, L. (1990). A comparative study of the nature of biopolymers extracted from anaerobic and activated sludge. *Water Res*earch. 24 (6), 743–750.
- Morgan-Sagastume, F., and Allen, D.G. (2005). Activated sludge deflocculation under temperature upshifts from 30 to 45 °C. *Water Research*. 39, 1061-1074.
- Morozov, A.N., and Skripkin, A.V. (2011). Spherical particle Brownian motion in viscous medium as non-Markovian random process. *Physics Letters A*. 375(46), 4113–4115.
- Muda, K. (2010). Facultative Anaerobic Granular Sludge For Textile Dyeing Wastewater Treatment. Thesis of Philosophy of Doctorate, Universiti Teknologi Malaysia, Skudai.
- Muda, K., Aris, A., Salim, M.R., Ibrahim, Z., van Loosdrecht, M.C.M., Ahmad, A., and Nawahwi, M.Z. (2011). The effect of hydraulic retention time on granular sludge biomass in treating textile wastewater. *Water Research*. 45, 4711-4721.
- Murthy, S.N. and Novak, J.T. (1998). Effects of potassium ion on sludge settling dewatering and effluent properties. *Water Science and Technology*. 37: 4-5, 317 324.
- Murthy, S.N., Novak, J.T., and De Haas, R.D. (1998). Monitoring cations to predict and improve activated sludge settling and dewatering properties of industrial wastewaters. *Water Science and Technology*. 38(3), 119 – 126.
- Nakagawa, J., Hirota, N., Kitazawa, K., and Shoda, M. (1999). Magnetic field enhancement of water vaporization. *Journal of Applied Physics*. 86(5), 2923-2925.
- Ng, W.J., Ong, S.L., and Hossain, F. (2000). An algorithmic approach for systemspecific modelling of activated sludge bulking in an SBR. *Environmental and Modelling Software*. 15, 199 – 210.
- Ni, B.J., and Yu, H.Q. (2010). Modelling and simulation of the formation and utilization of microbial products in aerobic granular sludge. *AIChE Journal*. 56, 546–559.

- Nielsen, P.H., and Jahn, A. (1999). Extraction of EPS. In: Wingender, J., Neu, T.R., Flemming, H.C. (Eds.), *Microbial Extracellular Polymeric Substances* (pp. 49– 72). Berlin: Spinger.
- Nielsen, P.H., Roslev, P., Dueholm, T., and Nielsen, J.L. (2002). *Microthrix parvicella*, a specialized lipid consumer in anaerobic-aerobic activated sludge plants. *Water Science and Technology*. 46, 73 80.
- Nielson, P.H., Thompson, T.R. and Nielson, J.L. (2004). Bacterial Composition of Activated Sludge – Importance for Floc and Sludge Properties. *Water Science* and Technology. 49, 51–58.
- Niu, C., Geng, J., Ren, H., Ding, L., Xu, K., and Liang, W. (2013). The strengthening effect of a static magnetic field on activated sludge activity at low temperature. *Bioresource Technology*. 150, 156–162.
- Novak, J.T., Love, N.G., Smith, M.L. and Wheeler, E.R. (1998). The effect of cationic salt addition on the settling and dewatering properties of an industrial activated sludge. *Water Environment Research*. 70, 984 996.
- Oka, T., Kanayama, H., Tanaka, K., Fukui, S., Ogawa, J., Sato, T., Ooizumi, M., Terasawa, T., Itoh, Y., and Yabuno, R. (2009). Waste water purification by magnetic separation technique using HTS bulk magnet system. *Physica C*. 469(15–20), 1849–1852.
- Okada, H., Mitsuhashi, K., Ohara, T., Whitby, E.R., and Wada, H. (2005). Computational fluid dynamics simulation of high gradient magnetic separation. *Separation Science and Technology*. 40(7), 1567–1584.
- Okada, I., Ozaki, M., and Matijevic, E. (1991). Magnetic interactions between platelet-type colloidal particles. *Journal of Colloid and Interface Science*. 142(1), 251–256.
- Ong, S., Toorisaka, E., Hirata, M., and Hano, T. (2004). Effects of nickel(II) addition on the activity of activated sludge microorganisms and activated sludge process. *Journal of Hazardous Materials*. 113, 111 – 121.
- Ong, S.A., Toorisaka, E., Hirata, M., and Hano, T. (2005). Treatment of azo dye Orange II in aerobic and anaerobic SBR systems. *Process Biochemistry*. 40, 2907 – 2914.
- Oshitani, J., Yamada, D., Miyahara, M., and Higashitani, K. (1999). Magnetic effects on ion exchange kinetics. *Journal of Colloid and Interface Science*. 210, 1–7.

- Pandolfo, L., Colale, R., and Paiaro, G. (1987). Magnetic field and tap water. *Chim Ind.* 69(11), 11–12.
- Park, C., Muller, C.D., Abu-Orf, M.M., and Novak, J.T. (2006). The effect of wastewater cations on activated sludge characteristics: Effects of aluminum and iron in floc. *Water Environment Research*. 78, 31–40.
- Parsons, S.A., Wang, B.-L., Judd, S.J., and Stephenson, T. (1997). Magnetic treatment of calcium carbonate scale—Effect of pH control. *Water Research*. 31(2), 339–342.
- Partidas, H. (1995). Magnetic Fluid Conditioning Tools: Removal and Inhibition of Production Reports. *Petromin Nov*. 66-72.
- Pei, H.-Y., Hu, W.-R., and Liu, Q.-H. (2010). Effect of protease and cellulase on the characteristic of activated sludge. *Journal of Hazardous Materials*. 178, 397-403.
- Peng, Y., Gao, C., Wang, S., Ozaki, M., and Takigawa, A. (2003). Non-filamentous sludge bulking caused by a deficiency of nitrogen in industrial wastewater treatment. *Water Science and Technology*. 47(11), 289 – 295.
- Philips, S., Rabaey, K., and Verstraete, W. (2003). Impact of iron salts on activated sludge and interaction with nitrite or nitrate. *Bioresource Technology*. 88, 229 – 239.
- Pitt, W.G., and Ross, S.A. (2003). Ultrasound increases the rate of bacterial cell growth. *Biotechnology Progress*. 19, 1038 – 1044.
- Prendl, L., and Kroiβ, H. (1998). Bulking sludge prevention by an aerobic selector. Water Science and Technology. 38(8/9), 19 – 27.
- Pujol, R., and Boutin, P. (1989). Control of activated sludge bulking: From lab to the plant. Water Science and Technology. 21 (6/7), 717 – 726.
- Pujol, R., and Canler, J.P. (1994). Contact zone: French practice with low F/M bulking control. *Water Science and Technology*. 29 (7), 221 – 228.
- Purkait, M.K., Maiti, A., DasGupta, S., and De, S. (2007). Removal of Congo red using activated carbon and its regeneration. *Journal of Hazardous Materials*. 145, 287–295.
- Rahimi, Y., Torabian, A., Mehrdadi, N., and Shahmoradi, B. (2011). Simultaneous nitrification–denitrification and phosphorus removal in a fixed bed sequencing batch reactor (FBSBR). *Journal of Hazardous Materials*. 185, 852-857.

- Rahman, M.M., Kim, W.S., Kumura, H., and Shimazaki, K. (2008). Autoaggregation and surface hydrophobicity of Bifidobacteria. *World Journal of Microbiology and Biotechnology*. 24, 1593-1598.
- Ramirez, G.W., Alonso, J.L., Villanueva, A., Guardino, R., Basiero, J.A., Bernecer, I., and Morenilla, J.J. (2000). A rapid, direct method for assessing chlorine effect on filamentous bacteria in activated sludge. *Water Research*. 34 (15), 3894 – 3898.
- Richard, M.G. (1997). Recent changes in the prevalence and causes of bulking filamentous bacteria in pulp and paper mill activated sludge systems. *Proceeding of TAPPI Environment Conference*.
- Roels, T., Dauwe, F., Van Damme, S., De Wilde, K., and Roelandt, F. (2002). The influence of PAX-14 on activated sludge systems and in particular on *Microthrix parvicella*. *Water Science and Technology*. 46, 487 – 490.
- Rossetti, S., Tomei, M.C., Nielsen, P.H., and Tandoi, V. (2005). "Microthrix parvicella", a filamentous bacterium causing bulking and foaming in activated sludge systems: A review of current knowledge. FEMS Microbiology Reviews. 29, 49-64.
- Rutkowska-Narożniak, A. (1997). An application of static magnetic field to intensify the biodegradation of pollutions in wastewater (in Polish). Thesis of Philosophy of Doctorate, Politechnika Warszawska, Warszawa.
- Sakai, Y., Nitta, Y., and Takahashi, F. (1994). A submerged filter system consisting of magnetic tubular support media covered with a biofilm fixed by magnetic force. *Water Resources*. 28(5), 1175-1179.
- Sakurazawa, S., Kubota, T., and Ataka, M. (1999). Orientation of protein crystals grown in a magnetic field. *Journal of Crystal Growth*. 196, 325–331.
- Sarikaya, M., Abbasov, T., and Erdemoglu, M. (2006). Some aspects of magnetic filtration theory for removal of fine particles from aqueous suspensions. *Journal* of Dispersion Science and Technology 27(2), 193–198.
- Satyawali, Y., and Balakrishnan, M. (2009). Effect of PAC addition on sludge properties in an MBR treating high strength wastewater. *Water Research*. 43, 1577 – 1588.
- Schuler, A.J., and Jassby, D. (2007). Filament content threshold for activated sludge bulking: Artifact or reality? *Water Research*. 41, 4349-4356.

- Scruggs, C.E., and Randall, C.W. (1998). Evaluation of filamentous growth factors in an industrial wastewater activated sludge system. *Water Science and Technology*. 37, 263 – 270.
- Sears, K., Alleman, J.E., Barnard, J.L., and Oleszkiewicz, J.A. (2006). Density and activity characterization of activated sludge flocs. *Journal of Environmental Engineering*. 132(10), 1235–1242.
- Seka, A.M., Van de Wiele, T., and Verstraete, W. (2001). Feasibility of a multicomponent additive for efficient control of activated sludge filamentous bulking. *Water Research.* 35 (12), 2995 – 3003.
- Sheng, G.P., Yu, H.Q., and Li, X.Y. (2006). Stability of sludge flocs under shear conditions: Roles of extracellular polymeric substances (EPS). *Biotechnology and Bioengineering*. 93, 1095–1102.
- Sheng, G.-P., Yu, H.-Q., and Li, X.-Y. (2010). Extracellular polymeric substances (EPS) of microbial aggregates in biological wastewater treatment systems: A review. *Biotechnology Advances*. 28, 882-894.
- Shi, H.S. (2014). Effect of magnetic field on scale removal in drinking water pipeline. Thesis of Master of Engineering (Civil-Wastewater), Universiti Teknologi Malaysia, Skudai.
- Smets, I.Y., Banadda, E.N., Deurinck, J., Renders, N., Jenné, R., and Van Impe, J.F. (2006). Dynamic modeling of filamentous bulking in lab-scale activated sludge processes. *Journal of Process Control.* 16, 313 – 319.
- Sobiecka, B.O., Janczukowicz, W., Sobiecki, S., Zieliński, M., and Dębowski, M. (2008). The view of usefulness the hydrogen peroxide (H<sub>2</sub>O<sub>2</sub>) and solid magnetic field (SMF) in the COD reduction value in meat industry wastewater. *Polish Journal of Natural Sciences*. 23(4), 825–836.
- Sokolśkii, Y.M. (1982). Mechanism of action of magnetic fields on suspensions. *Zhurnal Prikladnoi Khimii* (Translated). 57(5), 1005-1009.
- Song, L.J., Zhu, N.W., Yuan, H.P., Hong, Y., and Ding, J. (2010). Enhancement of waste activated sludge aerobic digestion by electrochemical pre-treatment. *Water Research.* 44 (15), 4371–4378.
- Sorensen, J.S., and Madsen, H.E.L. (2000). The influence of magnetism on precipitation of calcium phosphate. *Journal of Crystal Growth*. 216(1–4), 399–406.

- Spiegel, M.S. (1998). U.S. Patent No. RE35826. Method and apparatus for applying magnetic fields to fluids.
- Sponza, D.T. (2002). Extracellular polymer substances (EPS) and physicochemical properties of flocs in steady- and unsteady-state activated sludge systems. *Process Biochemistry*. 37, 983–998.
- Sponza, D.T. (2003). Investigation of extracellular polymer substances (EPS) and physicochemical properties of different activated sludge flocs under steady-state conditions. *Enzyme Microbial Technology*. 32, 375 385.
- Sponza, D.T., and Gok, O. (2011). Effects of sludge retention time (SRT) and biosurfactant on the removal of polyaromatic compounds and toxicity. *Journal of Hazardous Materials*. 197, 404 416.
- Srebrenik, S., Nadiv, S., and Lin, I.J. (1993). Magnetic treatment of water A theoretical quantum model magnetic and electrical separation. *Magn. Electri. Sep.* 5(2), 71–91.
- Stat-Ease (2014). Handbook for experimenters. Minneapolis, USA: Stat-Ease Inc.
- Suresh, K.M., Mudliar, S.N., Reddy, K.M.K., and Chakrabarti, T. (2004). Production of biodegradable plastics from activated sludge generated from a food processing industrial wastewater treatment plant. *Bioresource Technology*. 95(3), 327–330.
- Svoboda, J. (2001). A realistic description of the process of high-gradient magnetic separation. *Minerals Engineering*. 14(11), 1493–1503.
- Szkatula, A., Balandaa, M., and Kopec M. (2002). Magnetic treatment of industrial water. Silica activation. *The European Physical Journal Applied Physics*. 18, 41– 49.
- Tai, C.Y., Wu, C.-K., and Chang, M.-C. (2008). Effects of magnetic field on the crystallization of CaCO<sub>3</sub> using permanent magnets. *Chemical Engineering Science*. 63(23), 5606–5612.
- Takehiro, U., Yu-ichi, Y., Masanori, W., and Ken, S. (2003). Stimulation of prophyrin production by application of an external magnetic field to a photosynthetic bacterium, rhodobacter sphaeroides. *Journal of Bioscience and Bioengineering*. 95(4), 401–404.
- Tan, T.W., Ng, H.Y., and Ong, S.L. (2008). Effect of mean cell residence time on the performance and microbial diversity of predenitrification submerged membrane bioreactors. *Chemosphere*. 70 (3), 387–396.

- Tandoi, V., Jenkins, D., and Wanner, J. (2006). Activated sludge separation problems. Theory, control measures, practical experience. London: IWA Publishing.
- Tchobanoglous, G., Burton, F.L., and Stensel, H.D. (2004). Wastewater engineering: Treatment, Disposal and Reuse. (4<sup>th</sup> ed.). New York: McGraw Hill Companies Inc.
- Thompson, G., and Forster, C. (2003). Bulking in activated sludge plants treating paper mill wastewaters. *Water Research*. 37, 2636 2644.
- Tombácz, E., Ma, C., Busch, K.W., and Busch, M.A. (1991). Effect of a weak magnetic field on hematite sol in stationary and flowing systems. *Colloid and Polymer Science*. 269, 278–289.
- Tomska, A., and Wolny, L. (2008). Enhancement of biological wastewater treatment by magnetic field exposure. *Desalination*. 222, 368–373.
- Tsouris, C., and Scott, T.C. (1995). Flocculation of paramagnetic particles in a magnetic field. *Journal of Colloid and Interface Science*. 171, 319-330.
- Tsuneda, S., Aikawa, H., Hayashi, H., Yuasa, A. and Hirata, A. (2003). Extracellular polymeric substances responsible for bacterial adhesion onto solid surface. *FEMS Microbiology Letters*. 223, 287–292.
- Tu, R., Jin, W., Xi, T., Yang, Q., Han, S.-F., and Abomohra, A.E. (2015). Effect of static magnetic field on the oxygen production of *Scenedesmus obliquus* cultivated in municipal wastewater. *Water Research*. 86, 132-138.
- Tuutijärvi, T., Lu, J., Sillanpää, M., and Chen, G. (2009). As(V) adsorption on maghemite nanoparticles. *Journal of Hazardous Materials*. 166, 1415–1420.
- Urbain, V., Block, J.C., and Manem, J. (1993). Bioflocculation in activated sludge: An analytic approach. *Water Research*. 27(5), 829 – 838.
- Van den Akker, B., Beard, H., Kaeding, U., Giglio, S., and Short, M.D. (2010). Exploring the relationship between viscous bulking and ammonia-oxidiser abundance in activated sludge: A comparison on conventional and IFAS systems. *Water Research.* 44 (9), 2919 – 2929.
- Vanderhasselt, A., and Verstraete, W. (1999). Short term effects of additives on sludge sedimentation characteristics. *Water Research.* 33, 381 390.

- Vanrollehem, P.A., Kong, Z., Rombouts, G., and Verstraete, W. (1994). An on-line respirographic biosensor for the characterization of load and toxicity of wastewater. *Journal of Chemical Technology and Biotechnology*. 59(4), 321–333.
- Veiga, M.C., Jain, M.K., Wu, W.M., Hollingsworth, R.I., and Zeikus, J.G. (1997). Composition and role of extracellular polymers in methanogenic granules. *Applied Environmental Microbiology*. 63(2), 403-407.
- Vick, W.S. (1991). Magnetic fluid conditioning. Proceedings of the 1991 Speciality Conference on Environmental Engineering. Reston, VA: American Society of Civil Engineers.
- Wang, H., and Huang, Y. (2011). Prussian-blue-modified iron oxide magnetic nanoparticles as effective peroxidase-like catalysts to degrade methylene blue with H<sub>2</sub>O<sub>2</sub>. *Journal of Hazardous Materials*. 191(1-3), 163-169.
- Wang, L., Li, J., Wang, Y., and Zhao, L. (2011). Preparation of nanocrystalline Fe<sub>3</sub>xLa<sub>x</sub>O<sub>4</sub> ferrite and their adsorption capability for Congo red. *Journal of Hazardous Materials*. 196, 342-349.
- Wang, L., Liu, Y., Li, J., Liu, X., Dai, R., Zhang, Y., Zhang, S., and Li, J. (2010). Effects of Ni<sup>2+</sup> on the characteristics of bulking activated sludge. *Journal of Hazardous Materials*. 181(1-3), 460-467.
- Wang, X.-H., Diao, M.-H., Yang, Y., Shi, Y.-J., Gao, M.-M., and Wang, S.- G. (2012). Enhanced aerobic nitrifying granulation by static magnetic field. *Bioresource Technology*. 110, 105–110.
- Wang, X.S., and Chen, J.P. (2009). Biosorption of Congo red from aqueous solution using wheat bran and rice bran: Batch studies. *Separation Science and Technology*. 44, 1452–1466.
- Wang, Y., Babchin, A.J., Chernyi, L.T., Chow, R.S., and Sawatzky, R.P. (1997). Rapid onset of calcium carbonate crystallization under the influence of a magnetic field. *Water Research*. 31(2), 346–350.
- Wang, Y., Pugh, R.J., and Forssberg, E. (1994). The influence of interparticle surface forces on the coagulation of weakly magnetic mineral ultrafine in a magnetic field. *Colloids and Surfaces A: Physicochemical and Engineering Aspects*. 90(2– 3), 117–133.

- Wang, Z.P., Liu, L.L., Yao, J., and Cai, W.M. (2006). Effects of extracellular polymeric substances on aerobic granulation in sequencing batch reactors. *Chemosphere*. 63, 1728–1735.
- Wang, Z.W., Liu, Y., and Tay, J.H. (2005). Distribution of EPS and cell surface hydrophobicity in aerobic granules. *Applied Microbiology and Biotechnology*. 69, 469-473.
- Wanner, J., Kragelund, C., and Nielsen, P.H. (2010). *Microbiology of bulking*. In: *Microbial ecology of activated sludge*. London: IWA Publishing.
- Wanner, J., Ruzickova, I., Jetmarova, P., Krhutkova, O., and Paraniakova, J. (1998).
  A national survey of activated sludge separation problems in the Czech Republic:
  Filaments, floc characteristics and activated sludge metabolic properties. *Water Science and Technology*. 37 (4), 271 279.
- Watt, D.L., Rosenfelder, C., and Sutton, C.D. (1993). The effect of oral irrigation with a magnetic water treatment device on plaque and calculus. *Journal of Clinical Periodontology*. 20(5), 314–317.
- Weemaes, M.P.J., and Verstraete, W. (1998). Evaluation of current wet sludge disintegration techniques. *Journal of Chemical Technology and Biotechnology*. 73, 83 – 92.
- Wijffels, R.H. and Tramper, J. (1995). Nitrification by immobilized cells. *Enzyme* and Microbial Technology. 17, 482 492.
- Wilén, B. and Balmér, P. (1999). The effect of dissolved oxygen concentration on the structure, size and size distribution of activated sludge flocs. *Water Research*. 33(2), 391 – 400.
- Wilén, B.M., Jin, B., and Lant, P. (2003). The influence of key chemical constituents in activated sludge on surface and flocculation properties. *Water Research*. 37, 2127–2139.
- Wilén, B.-M., Onuki, M., Hermansson, M., Lumley, D., and Mino, T. (2008). Microbial community structure in activated sludge floc analysed by fluorescence in situ hybridization and its relation to floc stability. *Water Research*. 42, 2300-2308.
- Wimmer, R.F., and Love, N.G. (2004). Activated sludge deflocculation in response to chlorine addition: The potassium connection. *Water Environment Research*. 76(3), 213 – 219.

- Xie, B., Dai, X.-C., and Xu, Y.-T. (2007). Cause and pre-alarm control of bulking and foaming by *Microthrix parvicella* - A case study in triple oxidation ditch at a wastewater treatment plant. *Journal of Hazardous Materials*. 143, 184-191.
- Xie, Q., Liu, X., Wu, C., Wang, Y., and Zhu, G. (2010). Design and simulation of flow field for magnetic flocculation reactor. J. Jiangsu Uni. (Nat. Sci. Edi.). 31(4), 473–477.
- Xu, Y.B., and Sun, S.Y. (2008). Effect of stable weak magnetic field on Cr (VI) bioremoval in anaerobic SBR system. *Biodegradation*. 19(3), 455–462.
- Xu, Y.B., Duan, X.J., Yan, J.N., and Sun, S.Y. (2009). Influence of magnetic field on Cr (VI) adsorption capability of given anaerobic sludge. *Biodegradation*. 21(1), 1–10.
- Yang, S.F., and Li, X.Y. (2009). Influences of extracellular polymeric substances (EPS) on the characteristics of activated sludge under non-steady-state conditions. *Process Biochemistry*. 44, 91–96.
- Yavuz, H., and Çelebi, S.S. (2000). Effect of magnetic field on activity of activated sludge in wastewater treatment. *Enzyme Microbial Technology*. 26, 22-27.
- Yetis, U., and Gockay, C.F. (1989). Effect of nickel(II) on activated sludge. *Water Research.* 23 (8), 1003 – 1007.
- Yin, X., Qiao, S., and Zhou, J. (2015). Using electric field to enhance the activity of anammox bacteria. *Applied Microbiology and Biotechnology*. 99, 6921-6930.
- Ying, C., Umetsu, K., Ihara, I., Sakai, Y., and Yamashiro, T. (2010). Simultaneous removal of organic matter and nitrogen from milking parlor wastewater by a magnetic activated sludge (MAS) process. *Bioresource Technology*. 101, 4349– 4353.
- Yu, G.H., He, P.J., and Shao, L.M. (2009). Characteristics of extracellular polymeric substances (EPS) fractions from excess sludges and their effects on bioflocculability. *Bioresource Technology*. 100, 3193–3198.
- Zaidi, N.S., Sohaili, J., Muda, K., and Sillanpää, M. (2014). Magnetic field application and its potential in water and wastewater treatment systems: A review. *Separation Purification Reviews*. 43, 206 – 240.
- Zhang, H., Zhao, Z., Xu, X., and Li, L. (2011). Study on industrial wastewater treatment using superconducting magnetic separation. *Cryogenics*. 51(6), 225– 228.

- Zhang, L., Feng, X., Zhuc, N., and Chena, J. (2007). Role of extracellular protein in the formation and stability of aerobic granules. *Enzyme Microbial Technology*. 41, 551 – 557.
- Zhi-Yong, L., Si-Yuan, G., Lin, L., and Miao-Yan, C. (2007). Effects of electromagnetic field on the batch cultivation and nutritional composition of *Spirulina platensis* in an air-lift photobioreactor. *Bioresource Technology*. 98, 700–705.
- Zita, A., and Hermansson, M. (1994) Effect of ionic strength on bacterial adhesion and stability of flocs in a wastewater activated sludge system. *Applied and Environmental Microbiology*. 60(9), 3041 – 3048.
- Zita, A., and Hermansson, M. (1997). Effects of bacterial cell surface structures and hydrophobicity on attachment to activated sludge flocs. *Applied and Environmental Microbiology*. 63 (3), 1168–1170.
- Zularisam, A.W., Fadil. O., and Johan, S. (2001). Electromagnetic Technology on Sewage Treatment. *Jurnal Kejuruteraan Awam*. 13(1), 22-36.