

INTELLIGENT FAULT DETECTION AND DIAGNOSIS BASED ON
OPTIMIZED FUZZY MODEL FOR PROCESS CONTROL RIG

RIBHAN ZAFIRA BINTI ABDUL RAHMAN

A thesis submitted in fulfilment of the
requirements for the award of the degree of
Doctor of Philosophy (Electrical Engineering)

Faculty of Electrical Engineering
Universiti Teknologi Malaysia

JANUARY 2014

ACKNOWLEDGEMENTS

SYUKUR ALHAMDULILLAH to ALLAH SUBHANAWATA'ALA, who given me the strength and courage to carry on my graduate studies which full of 'adventures' and 'memories'.

I would like to express my gratitude to my supervisor, Prof Datin Dr Rubiyah Yusof, for her expertise and 'greatest' patient, added considerably to my postgraduate experience. I appreciate her vast knowledge and skills in the area and critical atmosphere during the many discussions we had. Appreciation also goes to my late co-supervisor, Allahyarham Prof. Datuk Dr. Marzuki Khalid for his guidance, advices and motivation in my research during his life.

A very special thank is dedicated to my dearest husband, Sajahan bin Bajure, with his love and bless on my dream and support me in getting a degree that I dream off. To my beloved children, Aida Syakirah, Asna Syahirah, Arif Syahmi and Alif Syafi, who are completed my life. Also thanks goes to my dearest Mak and Ayah, Fatimah binti Ali and Abdul Rahman bin Muda, with their prayer for me to completing the studies, and last but not least to all family members for their support.

My sincere appreciation also extends to all my colleagues in Centre for Artificial Intelligence and Robotics (CAIRO) Universiti Teknologi Malaysia (UTM) and Universiti Putra Malaysia (UPM), who have provided assistance at various occasions. Finally, many thanks also go to the UPM for awarding me the scholarship and financial support for my study.

ABSTRACT

This thesis focuses on the application of artificial intelligent techniques in fault detection and diagnosis. Fault detection and diagnosis scheme is a technique used in supervisory systems. The function of the supervisory system is to indicate unnecessary process states and to take the most appropriate actions to maintain continuous operation and to avoid damages. There are two main methods in fault detection and diagnosis: model free and model-based. In this thesis, model-based fault detection and diagnosis is used. One of the research challenges in model-based fault detection and diagnosis of a system is to find the accurate models. The objective of this thesis is to detect and diagnose the faults to a process control rig. A technique for the modeling of nonlinear control processes using fuzzy modeling approach based on the Takagi–Sugeno fuzzy model with a combination of genetic algorithm and recursive least square is proposed. This thesis discusses the identification of the parameters at the antecedent and consequent parts of the fuzzy model. For the antecedent fuzzy parameters, genetic algorithm is used to tune them while at the consequent part, recursive least squares approach is used to identify the system parameters. The proposed method is used to develop fault model and to detect the fault where this task is performed by using residual signals. When the residual signal is zero or nearly zero, the system is in normal condition, and when the fault occurs, residual signals should distinctively diverge from zero. Meanwhile, neural network is used for fault classification where this task is performed by identifying the fault in the system. This approach is applied to a process control rig with three subsystems: a heating element, a heat exchanger and a compartment tank. Experimental results show that the proposed approach provides better modeling when compared with Takagi Sugeno fuzzy modeling technique and the linear modeling approach. The overall accuracy for classification results also shows the best performance of around 93%.

ABSTRAK

Tesis ini memberi tumpuan kepada aplikasi teknik-teknik kepintaran buatan untuk pengesanan dan diagnosis kerosakan. Skim pengesanan dan diagnosis kerosakan adalah teknik yang digunakan dalam sistem penyeliaan. Fungsi sistem penyeliaan adalah untuk menunjukkan keadaan proses yang tidak perlu dan untuk mengambil tindakan yang paling sesuai untuk mengekalkan operasi yang berterusan dan untuk mengelakkan kerosakan. Terdapat dua kaedah utama dalam pengesanan dan diagnosis kerosakan: model-bebas dan berasaskan model. Dalam tesis ini berasaskan model pengesanan dan diagnosis kerosakan digunakan. Salah satu cabaran kajian kepada berasaskan model pengesanan dan diagnosis kerosakan sistem adalah mencari model yang tepat. Objektif tesis ini adalah untuk mengesan dan mendiagnosis kerosakan kepada pelantar kawalan proses. Satu teknik untuk pemodelan proses kawalan tak lurus berdasarkan model samar Takagi-Sugeno dengan gabungan algoritma genetik dan rekursi kuasa dua terkecil dicadangkan. Tesis ini membincangkan pengenalpastian parameter bahagian anteseden dan akibat langsung pada model samar. Bagi parameter anteseden samar, algoritma genetik digunakan untuk pelarasan parameter tersebut, manakala pada bahagian akibat langsung pendekatan rekursi kuasa dua terkecil digunakan untuk mengenalpasti parameter sistem. Kaedah yang dicadangkan digunakan untuk membangunkan model yang rosak untuk mengesan kerosakan di mana tugas ini dilakukan dengan menggunakan isyarat sisa. Apabila isyarat sisa adalah sifar atau hampir sifar, sistem ini dalam keadaan normal, dan apabila kerosakan berlaku, isyarat sisa akan menyimpang dari sifar. Sementara itu, rangkaian neural digunakan untuk pengelasan kerosakan di mana tugas ini dilakukan dengan mengenal pasti kerosakan dalam sistem. Pendekatan ini digunakan untuk pelantar kawalan proses dengan tiga subsistem: elemen pemanas, penukar haba dan ruang tangki. Keputusan eksperimen menunjukkan bahawa pendekatan yang dicadangkan menyediakan pemodelan yang lebih baik apabila dibandingkan dengan teknik pemodelan kabur Takagi Sugeno dan pendekatan pemodelan lurus. Keseluruhan keputusan ketepatan bagi pengelasan juga menunjukkan prestasi terbaik di sekitar 93%.

TABLES OF CONTENTS

CHAPTER	TITLE	PAGE
	DECLARATION	ii
	ACKNOWLEDGEMENTS	iii
	ABSTRACT	iv
	ABSTRAK	v
	TABLE OF CONTENTS	vi
	LIST OF TABLES	x
	LIST OF FIGURES	xi
	LIST OF SYMBOLS AND ABBREVIATIONS	xiv
	LIST OF APPENDICES	xvi
1	INTRODUCTION	1
	1.1 General	1
	1.2 Problem Statement and Importance of Research	2
	1.3 Research Scope and Objectives	3
	1.3.1 Objectives	3
	1.3.2 Research Scope	3
	1.4 Methodologies	4
	1.4.1 Part 1	4
	1.4.2 Part 2	4
	1.5 Contribution of Thesis	5
	1.6 Outline of Thesis	5
2	LITERATURE REVIEW	7
	2.1 Introduction	7

2.2	Definition of Fault Detection and Diagnosis	7
	Techniques	
2.2.1	Model-Free Fault Detection and Diagnosis	8
	Methods	
2.2.2	Model-based Fault Detection and Diagnosis	10
	Methods	
2.2.2.1	Residual Generation Methods	10
2.2.2.2	Residual Evaluations Methods	14
	2.2.2.2.1 Classification Method	15
	2.2.2.2.2 Artificial Neural Network	16
2.3	Process Modelling	19
2.3.1	Fuzzy Logic Theory	21
2.3.2	Takagi-Sugeno Fuzzy Model	23
	2.3.2.1 Identification of TS Fuzzy Model	27
2.4	Optimization	30
2.4.1	Genetic Algorithm	31
3	METHODOLOGY	36
3.1	Introduction	36
3.2	System Overview	36
3.3	Process Control Rig	38
3.4	Nonlinear Dynamic Model	39
	3.4.1 Heating Element Model	42
	3.4.2 Heat Exchanger Models	43
	3.4.3 Compartment Tank Model	46
3.5	Data Acquisition	47
	3.5.1 Level Sensor	49
	3.5.2 Flow Sensor	50
	3.5.3 Temperature Sensor	51
	3.5.4 Servo Valve Control	53
	3.5.5 Heater Control	54
	3.5.6 Solenoid Valve Control	55
3.6	Takagi-Sugeno Fuzzy Model	55

3.7	Parameter Identification	58
3.7.1	Tuning the Antecedent Part using GA	58
3.7.1.1	Genetic Algorithm	58
3.7.1.2	GA in Fuzzy Modelling	60
3.7.2	Tuning the Consequent Part using RLS	64
3.7.3	GA-RLS Algorithms for Fuzzy Model Parameter Tuning	66
3.8	Implementation of GA-RLS Fuzzy Modelling Technique to the Process Control Rig	67
3.8.1	System Model Identification Procedures	67
3.8.1.1	Linear Model	68
3.8.1.2	TS Fuzzy Model	69
3.8.1.3	Fuzzy Model with GA-RLS	70
3.8.2	Identification of Sub-models	70
3.8.2.1	Configuration of Fuzzy Model with GA-RLS of Sub-models	70
3.8.3	GA-RLS Configuration for Fuzzy Model Parameter Tuning	72
3.9	Fuzzy Modelling with GA-RLS for Fault Detection	73
3.10	Artificial Neural Networks for Fault Classification	75
4	RESULT AND DISCUSSION	77
4.1	Introduction	77
4.2	Software Description	77
4.2.1	Data Acquisition Software	78
4.2.2	Fuzzy Modelling Software	79
4.2.3	Fault Detection and Diagnosis Software	82
4.2.3.1	Fault Model Generation	82
4.2.3.1.1	Fault Type and Sensor Type Option	83
4.2.3.1.2	Fault Type Option	84
4.2.3.1.3	All Faults Option	85
4.2.3.2	Fault Diagnosis	86
4.2.3.2.1	Backpropagation Trainer	87

4.2.3.2.2	Backpropagation Evaluator	90
4.3	Experiments	93
4.3.1	Experiments for Fuzzy Modelling of Process Control rig	93
4.3.2	Experiments for Fault Detection and Diagnosis	102
4.3.2.1	Fault Detection	102
4.3.2.2	Fault Classification	105
5	CONCLUSIONS	108
5.1	Introduction	108
5.2	Summary of Contributions	108
7.3	Recommendations for Future Work	109
	REFERENCES	111
	Appendices A - B	117-118

LIST OF TABLES

TABLE NO.	TITLE	PAGE
3.1	The list of instruments and actuators	47
3.2	Signals assigned to the DAQ card	48
3.3	Configuration of fuzzy model with GA-RLS of process control rig system	72
3.4	Fault type and fault injection method for twelve faults	73
4.1	The best configuration of fuzzy model with GA-RLS for heating element system	97
4.2	The best configuration of fuzzy model with GA-RLS for heat exchanger system for hot water	97
4.3	The best configuration of fuzzy model with GA-RLS for heat exchanger system for cold water	98
4.4	The best configuration of fuzzy model with GA-RLS for compartment tank system	98
4.5	Mean squared error comparison	99
4.6	Residuals compared to normal condition	105
4.7	Fault classification using ANN for learning rate 0.2 and momentum rate 0.5	106
4.8	Fault classification using ANN for 3000 epoch	107

LIST OF FIGURES

FIGURE NO.	TITLE	PAGE
2.1	Model-free methods	8
2.2	Stage of model-based fault detection and diagnosis	10
2.3	Methods of residual generation	11
2.4	Fault-symptom relation for diagnosis system: from symptoms to faults	15
2.5	Methods of residual evaluation	16
2.6	Neural network based fault diagnosis	17
2.7	General structure for fuzzy logic	22
2.8	Block diagram of TS fuzzy model	24
2.9	The symmetrical Gaussian membership function	25
2.10	System model identification block diagram	28
2.11	Flowchart of a basic genetic algorithm	33
3.1	Research development flow	37
3.2	A schematic diagram of process control rig	38
3.3	Dynamic input and output of the models	39
3.4	A block diagram of process control rig model	40
3.5	Heat transfer direction in heating element system	42
3.6	Single cell heat exchanger	44
3.7	Heat transfer direction in heat exchanger system	44
3.8	Liquid level system for compartment tank	46
3.9	Configuration between hardware and software	48
3.10	Current to voltage converter	49
3.11	Voltage versus level	49
3.12	Level sensor to computer configuration	50
3.13	Voltage versus secondary flow	51
3.14	Flow sensor to computer configuration	51

3.15	Voltage divider circuit	52
3.16	Voltage versus temperature	53
3.17	Voltage to current converter	53
3.18	Servo valve to computer configuration	54
3.19	Heater control from computer configuration	54
3.20	Solenoid valve control from computer configuration	55
3.21	A block diagram of the TS fuzzy model	56
3.22	Flowchart of binary GA operation	60
3.23	An arrangement of membership functions of inputs in a chromosome for the TS fuzzy model	61
3.24	Chromosome contains information of membership functions of all input variables	62
3.25	A graphical view of the GA-RLS algorithms	67
3.26	Residual generation	74
3.27	Block diagram to generate residual	75
3.28	Neural network based fault diagnosis	76
4.1	Software configuration for a) data acquisition b) fuzzy modeling c) fault detection and diagnosis	78
4.2	Software for data acquisition	79
4.3	Software for fuzzy modeling	80
4.4	The mean squared error as a performance index for fuzzy model on every generation	81
4.5	The antecedents and consequents parameter of fuzzy model and the graph of membership	81
4.6	FDD main window software	82
4.7	Fault model generation tab page	83
4.8	Fault type and sensor type panel	84
4.9	Fault type panel	85
4.10	All fault panel	85
4.11	Residual generation tab page	86
4.12	Residual evaluation tab page	87
4.13	Backpropagation trainer	88
4.14	Setup network tab page	89
4.15	Trainer tab page	90
4.16	Backpropagation evaluator	91
4.17	Report dialog	92
4.18	Fault detection and diagnosis demo tab page	92

4.19	The antecedent parameters of heating element model which is the T_{he} model	95
4.20	The antecedent parameters of heating element model which is the T_h model	95
4.21	The antecedent parameters of heating element model which is the T_c model	96
4.22	The antecedent parameters of heating element model which is the h model	96
4.23	T_{he} sub-system modeling among the 3 approaches with the actual data a) Comparison for all 554 data, b) A detailed view of the comparison between data 220 to 225	99
4.24	T_h sub-system modeling among the 3 approaches with the actual data a) Comparison for all 554 data, b) A detailed view of the comparison between data 238 to 245	100
4.25	T_c sub-system modeling among the 3 approaches with the actual data a) Comparison for all 554 data, b) A detailed view of the comparison between data 274 to 281	100
4.26	h sub-system modeling among the 3 approaches with the actual data a) Comparison for all 554 data, b) A detailed view of the comparison between data 48 to 54	101
4.27	Actual and model system output graph for non-fault condition	102
4.28	The residuals for heating element, T_{he} for non-fault condition	103
4.29	Actual and model system output graph for faulty condition	103
4.30	The residuals for heating element, T_{he} for faulty condition	104
4.31	Residual generation for every fault	104

LIST OF SYMBOLS AND ABBREVIATIONS

q	-	volumetric flowrate
U	-	heat transfer coefficient
A	-	area of heat transfer
ρ	-	density
V	-	volume
C	-	specific heat capacity
T_{he}	-	temperature of heating element
T_h	-	temperature of hot water of heat exchanger
T_c	-	temperature of cold water of heat exchanger
h	-	level of compartment tank
FDD	-	Fault Detection and Diagnosis
GA-RLS	-	Genetic Algorithm and Recursive Least Square
ANN	-	Artificial Neural Network
DAQ	-	Data Acquisition
GA	-	Genetic Algorithm
RLS	-	Recursive Least Square
PCA	-	Principle Component Analysis
ICA	-	Independent Component Analysis
IC	-	Independent Component
DICA	-	Dynamic Independent Component Analysis
FDA	-	Fisher Discriminant Analysis
MLP	-	Multilayer Perceptron
AI	-	Artificial Intelligence
TS	-	Takagi Sugeno
TSK	-	Takagi Sugeno Kang
COG	-	Centre of Gravity
MISO	-	Multi Input Single Output

MIMO	-	Multi Input Multi Output
FCCU	-	Fluidised Catalytic Cracking Unit
ARX	-	Auto Regression with eXogenous
BPR	-	Basic Process Rig
TPR	-	Temperature Process Rig
VI	-	Virtual Instrument
FLT	-	Float Level Transmitter
PI	-	Process Interface
PFT	-	Pulse Flow Transmitter
NTC	-	Negative Temperature Coefficient
PWM	-	Pulse Width Modulation
MSE	-	Mean of Squared Error

LIST OF APPENDICES

APPENDIX	TITLE	PAGE
A	List of Journals Publication	117
B	List of Conferences Proceeding	118

CHAPTER 1

INTRODUCTION

1.1 General

Monitoring system that can monitor process control system component and diagnose fault detected is important to develop since the performance of computers into daily activities is growing fastest. This will provide the solutions without human intervention. The increasing demand of quality in production processes has encouraged the research and development on fault detection and diagnosis (FDD) in industrial plant. An unexpected change of system functionality may call a “fault” which it is maybe related to a failure in a physical component or in a system sensor or actuator.

Fault detection and fault diagnosis are the two main tasks that should perform in monitoring system. The first task is to determine whether a fault has occurred in the system. To achieve this goal, all the available information from the system should be collected and processed to detect any changes from nominal behaviour of the process. The second task is classifying the fault into several categories of faults such as the location and type of faults.

There are several methods that may solve the problem of FDD. Classical methods also called model-free FDD methods used physical redundancy, limit sensors, frequency spectrum and logic reasoning (Gertler, 1998). Eventhough the methods is easy to implement, the disadvantages are high cost, extra space and complex computation.

Model-based FDD is the innovative methods in recent years. The classical model-based FDD used dynamic models of the process. Because faults are supposed to appear as state changes caused by malfunctions, they are often monitored using estimation techniques (Willsky, 1976; Isermann, 1984; Baseville, 1988; Trank, 1990), or parity equations (Gertler, 1991; Patton et al., 1991). The basic idea is very simple: the behaviours such as input-output time series of the model and real system are compared to generate residual signals, which, in the presence of faults, take non-zero values. Rule-based expert systems have also been investigated very intensively for FDD problems (Kramer, 1987; Rich et al., 1987; Patton et al., 1989). However, these systems need an extensive database of rules and the accuracy of diagnosis depends on the rules. Therefore, the less number of rules with accurate model is represented in this research.

In order to get accurate fault diagnosis, the optimized model is developed. In this research, fuzzy model with genetic algorithm and recursive least square (GA-RLS) is proposed. This fuzzy model is developed to representing the process control rig sub-model. Four sub-models is proposed from the test bed of process control rig which are heating element, heat exchanger for hot water, heat exchanger for cold water and compartment tank models. In this proposed fuzzy model, the mean squared error is used as a performance index. The minimum error will produced the optimized model of the system. The model for every fault occurred is also developed by using the same approach. The residual is generating based on the differences between fault model and system model. Then, artificial neural network (ANN) is used to classify the fault. The highest accuracy is the best classification.

1.2 Problem Statement and Importance of Research

In the process plant application, many variables and instruments involved needs to monitor to make sure the process functioning and running accordingly. If there is just a small problem or faults occurred, sometimes it is undetected by the operator. Normally, only expert personnel know about the fault and will cause the late action to detect the fault. The late detection of fault may result in high

maintenance cost because may be the fault is already spread to other system. Therefore, a good and intelligent fault monitoring and diagnosis system is needed. In order to do that, the fault detection and diagnosis software with the optimized fuzzy model was developed to overcome the problem of the tedious process of detecting fault in the process control application.

1.3 Research Objectives and Scope

1.3.1 Objectives

The objectives of the thesis are:

1. To derive a mathematical model for process control rig.
2. To develop an optimized fuzzy model using genetic algorithm and recursive least square.
3. To use optimized fuzzy in development of fault detection and diagnosis system.
4. To develop an intelligent fault detection and diagnosis for process control rig.

1.3.2 Research Scope

The scopes of the research are

1. To use Labview 8.6 as the computation platform for developing of data acquisition (DAQ), fuzzy modeling and fault detection and diagnosis software.
2. To use the process control rig as test bed system as a reference system for model development.
3. To model and validate the system using input and output data from experiments on the process control rig.

4. To model and classify the fault through simulated or offline process for fault detection and diagnosis.

1.4 Methodologies

There are two methods proposed in this research which in general depend on the scopes and objectives of the work as follows:

1.4.1 Part 1

Fuzzy model with GA-RLS is proposed to model the process control rig to represent the real system. Because of the fuzzy model is the blackbox model, the input and output data is required to model the system. To acquire the data, the data acquisition software for the process needs to be done. In this research, there are three sub-systems, which are heating element, heat exchanger and compartment tank. The heat exchanger contents of two mathematical models such as heat exchanger for hot water and heat exchanger for cold water. Therefore, there is four model developed in this research. The input and output variables to the fuzzy model is depending on the mathematical model of the system. In fuzzy modeling, genetic algorithm (GA) is used for tuning the antecedent parts parameters and recursive least square (RLS) is used for tuning the consequents part parameters of fuzzy model.

1.4.2 Part 2

In this part the fault model is develop by using the proposed technique fuzzy modeling. The input and output data of the faults is obtained from the experiments based on the fault injection discussed in Chapter 3. The residuals are generated by comparing this fault model and system model obtained in Part 1. Then the residuals are fed into ANN to classify the fault.

1.5 Contribution of Thesis

The most important contributions of this thesis are the development of a fuzzy model with GA-RLS applied to process control rig and to classify the fault by using ANN. It can be summarized as follows:

1. Mathematical derivation for modeling of process control rig.
2. Optimized model by using fuzzy model with GA-RLS.
3. Development of FDD software.

1.6 Outline of Thesis

The thesis is divided into five chapters:

- Chapter 1 introduces the thesis which covers some background information on FDD problems. The proposal to resolve the phenomena is also described. Fuzzy model with GA-RLS is identified to model the system in this research. The chapter consists of scope and objective, research methodology, the contribution and layout of the thesis.
- Chapter 2 reviews the FDD, fuzzy modeling and optimization techniques through literature search. A summary on the previous research dealing with FDD and fuzzy model is described in this chapter. It also covers the traditional and the intelligent FDD and the achievements made by other researchers in this field.
- Chapter 3 presents the methodology of this research. The mathematical models of process control rig are derived for each-subsystem in this chapter. The techniques used on the developments of the three softwares such as DAQ, fuzzy modeling and FDD are described. The optimization techniques such as GA and RLS are also discussed. In FDD, the method how the residual is generated and classified is presented.
- Chapter 4 discusses the results and discussion of the fuzzy modeling and FDD application on process control rig. In the modeling part, the

proposed model, fuzzy model with GA-RLS is used to model the system and then compared with another two methods such as conventional fuzzy model and linear model. In FDD, the residual is generated by comparing the system model and fault model. Then it is classified by using ANN. The used of three softwares are also discussed in this chapter.

- Chapter 5 concludes the thesis on a fuzzy model with GA-RLS and the FDD applied to process control rig. It also summarizes the achievements made in this research and further work recommended to be carried out.

REFERENCES

- Abdelazim, T. and Malik, O.P. (2005). Identification of Nonlinear Systems by Takagi-Sugeno Fuzzy Logic Grey Box Modeling for Real-time Control. *Control and Direct Practice, Elsevier*. 13: 1489-1498.
- Amine, T., Frederic, L., Mohamed, K. and Gilles, E. (2007). Fuzzy Identification of a Greenhouse. *Applied Soft Computing*. 7: 1092–1101.
- Ashutosh, T. and Mirna-Urquidi, M. (2010). Knowledge-based parameter identification of TSK fuzzy models. *Applied Soft Computing*. 10: 481–489.
- Babuska R., Roubus J.A. and Verbruggen H.B. (1998). Identification of MIMO systems by input-output TS fuzzy models. *Proceedings of the IEEE World Congress on computational intelligence*. May 4-9. Alaska: IEEE, 657-662.
- Baseville, M. (1988). Detecting Changes in Signal and Systems: A Survey. *Automatica*, 24 (3): 309-326.
- Chang-Ho, H., Chang-Woo, P. and Seungwoo, K. (2010). Takagi–Sugeno Fuzzy Model Based Indirect Adaptive Fuzzy Observer and Controller Design. *Information Sciences*. 180: 2314–2327.
- Chen, J., Patton, R. J. and Zhang, H. (1996). Design of Unknown Input Observers and Robust Fault Detection Filters. *International Journal on Control*. 63 (1): 85-105.
- Chiang, L.H., Russell, E.L. and Braatz, R.D. (2000). Fault Diagnosis in Chemical Processes using Fisher Discriminant Analysis, Discriminant Partial Least Squares, and Principal Component Analysis. *Chemometrics and Intelligent Laboratory Systems*. 50(2): 243-252.
- Christopher, H. and Stefan, J. (2006). New Concepts for the Identification of Dynamic Takagi–Sugeno Fuzzy Models. *IEEE Conference on Cybernetics and Intelligent System*. 1–6.
- Faisal, I. (2006). *Fuzzy Modelling and Control for a Nonlinear Reboiler System of a Distillation Column*. Universiti Teknologi Malaysia. Tesis Ijazah Sarjana.
- Fan, Y., Xin-Jian, Z. and Guang-Yi, C. (2007). Nonlinear Fuzzy Modeling of a MCFC Stack by an Identification Method. *Journal of Power Sources*. 166: 354–361.

- Frank, P. M. (1990). Fault Diagnosis in Dynamic Systems using Analytical and Knowledge-based Redundancy: A Survey and Some New Results. *Automatica*. 26: 459-474.
- Frank, P. M. and Ding, X. (1997). Survey of Robust Residual Generation and Evaluation Methods in Observer-based Fault Detection System. *Journal of Process Control*. 7 (6): 403-424.
- Geankoplis C.J. (1995). *Transport Processes and Unit Operations*. Singapore: Prentice Hall.
- Gertler, J. (1991). Generating Directional Residuals with Dynamic Parity Equations. Proc. *IFAC SAFEPROCESS'91 Symposium*. Baden-baden. Pergamon Press: Oxford.
- Gertler, J. and Monajemy, R. (1995). Generating Fixed Direction Residuals with Dynamic Parity Equations. *Automatica*. 31: 627-635.
- Gertler, J. (1998). *Fault Detection and Diagnosis in Engineering Systems*. New York: Marcel Dekker, Inc.
- Goldberg D.E. (1989). *Genetic Algorithms in Search, Optimization and Machine Learning*. Reading, MA: Addison-Wesley.
- Gong, H., Chowdhury, F.N., Xing, J. (2010). System Modelling Approach Fault Detection in Nonlinear Systems. *2010 3rd International Symposium on System and Control Aeronautics*. 8-10 June 2010. Harbin, 665-669.
- Haiping, D. and Zhang, Z. (2008). Application of Evolving Takagi–Sugeno Fuzzy Model to Nonlinear System Identification. *Applied Soft Computing*. 8: 676–686.
- Holland, J.H. (1975). *Adaptation in Natural and Artificial Systems*. University of Michigan Press, Ann Arbor.
- Huang, S. and Tan K.K. (2009). Fault Detection and Diagnosis Based on Modeling and Estimation Methods. *IEEE Transaction on Neural Networks*. 20(5): 872-881.
- Isermann, R. (1984). Process Fault Detection Based on Modeling and Estimation Methods: A Survey, *Automatica*. 20: 387-404.
- Isermann, R. (2006). *Fault-Diagnosis Systems: An Introduction from Fault Detection to Fault Tolerance*. Germany: Springer.
- Isermann, R. and Belle, P. (1997). Trends in Application of Model-based Fault Detection and Diagnosis of Technical Processes. *Control Engineering Practice*. 5 (5): 709-719.

- Jiang, L.Y. and Wang, S.Q. (2004). Fault Diagnosis Based on Independent Component Analysis and Fisher Discriminant Analysis. *Proceedings of the Third International Conference on Machine Learning and Cybernetics*. 26-29 August 2004. Shanghai, China, 3638-3643.
- Jie, Y., Xi, L., Hong-Gang, M. and Li, J. (2009). *Journal of Power Sources*. 193: 699–705.
- Koskinen J., Yliniemi L. and Leiviskii K. (1998). Fuzzy Modelling of Pilot Plant Rotary Dryer. *Proceedings of UKACC International Conference on Control*. September 1-4. Swansea, UK: IEEE, 515-518.
- Kramer M. A. (1987). Malfunction Diagnosis using Quantitative Models with Non-boolean Reasoning in Expert Systems. *AIChE Journal*. 33(1): 130-140.
- Lee, J.M., Qin, S.J. and Lee, I.B. (2006). Fault Detection and Diagnosis Based on Modified Independent Component Analysis. *AIChE Journal*. 52(10): 3501-3514.
- Lian, X. (2011). A Modified T-S Model Fuzzy Adaptive Control System Based on Genetic Algorithm. *I.J. Information Technology and Computer Science*. 3: 8-14.
- Luyben W.L. (1990). *Process Modeling, Simulation and Control for Chemical Engineers*. Singapore: McGraw-Hill.
- Luzar, M. (2012). Actuators and Sensors Fault Diagnosis with Dynamic, State-space Neural Networks. *2012 17th International Conference on Methods and Models in automation and Robotics*. 27-30 August 2012. Miedzyzdrojcie, 196-201.
- Mamdani E.H. and Assilian S. (1975). An Experiment in Linguistic Synthesis with a Fuzzy Logic Controller. *International Journal Man-machine Studies*. 7: 1-13.
- Mannle M. (2001). Parameter Optimization for Takagi-Sugeno Fuzzy Models-lessons Learnt. *IEEE Transactions on Systems, Man and Cybernetics*. 1: 111-116.
- Min, H., Yannan, S. and Yingnan, F. (2008). An Improved Fuzzy Neural Network Based on T–S Model. *Expert Systems with Application*. 34: 2905–2920.
- Ming, S. and Rhinehart, R.R. (2010). A generalized TSK model with a novel rule antecedent structure: structure identification and parameter estimation. *Computers and Chemical Engineering*. 34(8): 1199-1219.
- Misra, M., Yue, H.H., Qin S.J. and Ling, C. (2002). Multivariate process monitoring and fault diagnosis by multi-scale PCA. *Journal of Computers & Chemical Engineering Elsevier*. x26(9): 1281-1293.

- Mohammadi, R., Naderi, E., Khorasani, K. and Hashtrudi-Zad (2011). Fault diagnosis of Gas Turbine Engines by Using Dynamic Neural Networks. *2011 IEEE International Conference on Quality and Reliability*. 14-17 September 2011. Bangkok, Thailand, 25-30.
- Negnevitsky, M. (2004). *Artificial Intelligence: A Guide to Intelligent Systems*. 2nd Edition. England: Addison Wesley.
- Nie, J., Loh, A.P. and Hang, C.C. (1994). Fuzzy modeling of nonlinear pH processes through neural approach. *Proceedings of the IEEE World Congress on Computational Intelligence*. June 26–July 2. Orlando, FL, 1224–1229.
- Noureddine, G. Ar, G. and Mohamed, K. (2006). Nonlinear model reference adaptive control using Takagi–Sugeno fuzzy systems, *Journal of Intelligent & Fuzzy Systems: Applications in Engineering and Technology*. 17 (1): 47–57.
- Ogata K. (2010). *Modern Control Engineering*. 5th Edition. New Jersey: Pearson
- Passino K.M. and Yurkovich S. (1998). *Fuzzy control*. Menlo Park, California: Addison Wesley Longman Inc.
- Patton R.J. and Chen J. (1991). Parity space approach to model based fault diagnosis: a tutorial survey and some new results, Proc. IFAC/IMACS Symp. SAFEPROCESS'91. Baden-Baden (G).
- Patton R.J., and Chen, J. (1994). Review of Parity Space Approaches to Fault Diagnosis for Aerospace Systems. *Journal of Guidance, Control, and Dynamics*. 17(2): 278-285.
- Patton, R.J. and Chen, J. (1997). Observer-based Fault Detection and Isolation: Robustness and Applications. *Control Engineering Practice*. 5 (5): 671-682.
- Rich, S. H and Venkatasubramanian, V. (1987). Model-based reasoning in diagnostic expert system for chemical process plant. *Journal of Computers and Chemical Engineering Elsevier*. 11(2): 111-122.
- Richard, B (1998). *Genetic Algorithms in Search and Optimization*. Financial Engineering News. Retrieved December 2004.
- Routray, A., Rajaguru, A. and Singh. S. (2010). Data reduction and clustering techniques for fault detection and diagnosis in automotives. *2010 IEEE Conference on Automation Science and Engineering*. 21-24 August 2010. Toronto, ON, 326-331.
- Rubiyah Y., Marzuki K. and Mohd Faisal I., Fuzzy Modeling for Reboiler System. *IEEE TENCON 2004*. Chiang Mai, Thailand, 2004.
- Rubiyah, Y., Marzuki, K. and Faisal, I. (2005). Fuzzy modeling for distillation column. *Proceedings of the 24th IASTED International Conference on Modeling, Identification and Control*. Innsbruck, Austria.

- Schwarzenbach J. and Gill K. F. (1992). *System Modelling and Control*. 3rd Edition. Edward Arnold: Elsevier.
- Seng T.L., Khalid M. and Yusof R. (1999). Tuning of a Neuro-Fuzzy Controller by Genetic Algorithms. *IEEE Transactions on Systems, Man and Cybernetics*.29(2): 226-236.
- Setnes M. and Roubos H. (2000). GA-Fuzzy modelling & classification: complexity and performance. *IEEE Transactions on Fuzzy System*.8(5): 509-522.
- Simani, S. and Fantuzzi, C. (2000). Fault Diagnosis in Power Plant using Neural Networks. *An International Journal Information Science Elsevier*. 127: 125-136.
- Sugeno M. and Kang G.T. (1985). Fuzzy Modeling and Control of Multilayer Incinerator. In: Nguyen H.T. and Prasad N.R. *Fuzzy Modeling and Control, Selected works of M.Sugeno*. Florida: CRC Press. 113 – 128.
- Taedong, P. and Kiheon, P. (2008). Kalman Filter-based Fault Detection and Isolation of Direct Current Motor: Robustness and Applications. *International Conference on Control, automation and Systems*. 14-17 October, 2008. Seoul, Korea, 933-936.
- Takagi T. and Sugeno M. (1985). Fuzzy identification of systems and its application to modelling and control. *IEEE Transactions on Systems, Man and Cybernetics*. 15(1): 116-132.
- Tayarani-Bathaie, S.S., Sadough Vanini, Z.N. and Khorasani, K. (2012). Fault Detection of gas Turbine Engines using Dynamic Neural Networks. *2012 25th IEEE Canadian Conference on Electrical and Computer Engineering*. April 29 – May 2 2012. Montreal, QC, 1-5.
- Teng Y.W. and Wang W.J. (2002). System approximation via GA-based fuzzy model. *Proceedings of APCCAS '02 Conference on Circuits and Systems*. October 28-31. Bandung, Indonesia: IEEE, 547-550.
- Trank, P.M. (1990). Fault Diagnosis in Dynamic Systems using Analytical and Knowledge Based Redundancy: A survey of Some New Results. *Automatica*. 26 (3): 459-474.
- Villegas, T., Fuente, M.J. and Sainz-Palmero G.I (2010). Fault Diagnosis in a Wastewater Treatment Plant using Dynamic Independent Component Analysis. *18th Mediterranean Conference on Control & Automation*. 23-25 June 2010. Marrakech, Morocco, 874 - 879.
- Wang, F. (2011). Fault Diagnosis for Power Systems Based on Neural Networks. *2011 IEEE 2nd International Conference on Software Engineering and Service Science*. 15-17 July 2011. Beijing, China, 352-355.

- Willsky, A.S. (1976). A Survey of Design Methods for Failure Detection in Dynamic Systems, *Automatica*. 12: 601-611.
- Wong C.C. and Chen C.C. (2000). A GA-based method for constructing fuzzy systems directly from numerical data. *IEEE Transactions on Systems, Man and Cybernetics*. 30(6): 904-911.
- Xiang-Qun, L., Hong-Yue Z. , Jun L., and Jing Y. (2000). Fault Detection and Diagnosis of Permanent-Magnet DC Motor Based on Parameter Estimation and Neural Network. *IEEE Transactions on Industrial Electronics*. 47 (5): 1021-1030.
- Xu C.W. (1989). Fuzzy Systems Identification. *IEE Proceedings Part D*. 136(4): 146-150.
- Xun, W., Kruger, U. and Irwin G. W. (2008). Nonlinear PCA with the Local Approach for Diesel Engine Fault Detection and Diagnosis. *IEEE Transactions on Control Systems Technology*. 16(1): 122-129.
- Yi, Y. (1998). *On fuzzy modeling of nonlinear dynamical systems*, National University of Singapore . Ph.D. Thesis.
- Yiqiu, L. and Cobourn, W.G. (2007). Fuzzy system models combined with nonlinear regression for daily ground-level ozone predictions. *Atmospheric Environment*. 41: 3502–3513.
- Zadeh L.A. (1968). Fuzzy algorithm. *Information and Control*. 12(2): 94-102.
- Zadeh, L. (1965). Fuzzy Sets. *Information and Control*. 8(3): 338-353.
- Zhang, J. (1995). A Data Based Approach to On-line Process Fault Diagnosis. *Studies in Informatics and Control Journal*. 4 (2).
- Zhang, J. (2006). Improved On-line Process Fault Diagnosis through Information Fusion in Multiple Neural Networks. *Journal of Computer and Chemical Engineering, Elsevier*. 30: 558-571.
- Zheng Li (2009). Neural Network Based Fault Diagnosis and Fault Tolerant Control for BLDC Motor. *IEEE 6th International Power Electronics and Motion Control Conference*. 17-20 May 2009. Wuhan, 1925-1929.