

DESIGN OF STAND ALONE SOLAR SYSTEM WITH CONSIDERATION OF  
WIND SPEED FACTOR FOR REMOTE AREA

NORHANA BINTI BAHAROM

A project report submitted in partial fulfilment of the  
requirements for the award of the degree  
of Master of Engineering (Electrical Power)

Fakulty of Electrical Engineering  
Universiti Teknologi Malaysia

JANUARY 2018

*“My dearest mum, family, Dr Jasrul and friends”*

This is for all of you

## ACKNOWLEDGEMENT

First and foremost, I would like to give my thanks to Allah SWT for giving me a strength and ability to complete this papers from beginning until the end without any problems. Without His permission, this project will not successful complete.

I also own a debt of gratitude to my project supervisor, Dr. Jasrul Jamani Bin Jamian for the vision and foresight which inspired me to conceive this project. I really appreciate for all the guidance and advice that have been given to me.

In addition, my grateful thanks also go to my parents and my friends who have support, help to guide me and gave suggestion that related to this project. I have to appreciate the guidance given by other supervisors as well as panels especially to improve my final year project report.

Again, I wish to extend my sincere thanks for the great kindness shown to me in my bereavement, the many expressions of sympathy have been a source of comfort and will be remembered with gratitude.

## ABSTRACT

Utilization of Stand-alone Solar PV system or Off-grid Solar PV system is one of the availability approaches that can provide the electricity to a rural or remote area which is far away from the national electricity grid or enable to be reach. Theoretically, the successful application of Stand-alone Solar system reached the electricity demand while improving the living condition of local people at that place. The design of Stand-alone Solar system is much complicated compared to the Grid-connected Solar PV system where the design have to design properly with consideration of many factors. For design this system, the energy demand, irradiation to load ratio, system voltage, total load current, day of autonomy, depth of discharge of battery, ambient temperature with temperature correction factor, the limit of parallels stings of batteries factor have to seriously take into account to designing the size of capacity of the battery bank. In designing the sizing of PV array, the temperature derating factor, nominal operating cell temperature (NOCT), dirt factor, over-supply coefficient, coulombic efficiency, peak sun hours, and maximum solar irradiance is very important factors to design the sizing of PV array. These factors are covered in system sizing of design. The purpose of these consideration is to ensure the designed system will operate under design potential without any failure when worse case condition happen at some days and also to maximize the lifetime of the system. The economic analysis of Stand-alone Solar system also be covered to analyze the startup cost and the return of investment. The different between using calculation analysis and using HOMER software while designing the stand-alone solar system also being discussed in this paper.

## ABSTRAK

Penggunaan sistem Stand-alone Solar PV atau sistem Off-grid Solar PV adalah satu daripada pendekatan yang berkeupayaan menyediakan sumber elektrik di kawasan luar bandar atau pedalaman yang jauh daripada grid elektrik negara atau tidak langsung dapat mencapai grid elektrik tersebut. Penggunaan system ini dapat memenuhi keperluan tenaga elektrik kepada penduduk di kawasan tersebut disamping meningkatkan lagi taraf kehidupan dengan adanya tenaga elektrik. Reka bentuk sistem Stand-alone Solar PV adalah lebih rumit berbanding sistem Grid-connected Solar PV di mana reka bentuk untuk sistem ini perlulah di reka bentuk dengan amat teliti dengan mangambil kira banyak faktor. Untuk merekabentuk sistem ini, antara faktor yang perlu diambil kira adalah permintaan tenaga, kadar irradiation terhadap beban, sistem voltan, jumlah arus beban, hari autonomi, kedalaman discharge bateri, suhu persekitaran dengan mangambil kira faktor pembetulan suhu, dan had penyambungan bateri disambung secara selari untuk menyira jumlah kapasiti bank bateri. Manakala, Untuk mengira saiz PV array, faktor seperti nyahkadaran suhu, nominal suhu PV sel beroperasi (NOCT), faktor kekotoran, lebihan bekalan, kecekapan coulombic, waktu kemuncak matahari, dan maksimum irradiance solar adalah fator yang amat penting untuk menentukan saiz PV array. Kebiasaanya, faktor-faktor ini digunakan dalam reka bentuk sistem saiz dan ianya amat penting untuk memastikan reka bentuk sistem beroperasi dibawah potensi reka bentuk tanpa sebarang masalah apabila berlaku satu keadaan yang tidak dijangkakan pada beberapa hari. Ia juga amat penting untuk memaksimumkan jangka hayat sistem tersebut. Analisa ekonomik untuk sistem ini juga dilakukan untk menganalisa kos permulaan sistem dan juga pemulangan hasil pelaburan. Perbezaan menggunakan analisis secara pengiraan dan juga menggunakan system HOMER dalam merekabentuk system Stand-alone Solar PV juga dibincangkan didalam kertas ini.

## TABLE OF CONTENTS

<b>CHAPTER</b>	<b>TITLE</b>	<b>PAGE</b>
	<b>ACKNOWLEDGEMENT</b>	<b>iv</b>
	<b>ABSTRACT</b>	<b>v</b>
	<b>ABSTRAK</b>	<b>vi</b>
	<b>TABLE OF CONTENTS</b>	<b>vii</b>
	<b>LIST OF TABLES</b>	<b>xi</b>
	<b>LIST OF FIGURES</b>	<b>xii</b>
	<b>LIST OF APPENDIX</b>	<b>xiii</b>
<b>1</b>	<b>INTRODUCTION</b>	<b>1</b>
	1.1 Overview	1
	1.2 Problem Statement	2
	1.3 Objective	2
	1.4 Scope of work	3
	1.5 Thesis Layout	3
<b>2</b>	<b>LITERATURE REVIEW</b>	<b>5</b>
	2.1 Introduction	5
	2.2 Comparison Between Stand-alone Solar System with Grid-connected Solar System	5
	2.2.1 Stand_alone Solar System	6
	2.2.2 Grid-connected Solar System	7
	2.2.3 Comparison of PV System	8
	2.3 The components of Stand-alone Solar System	8
	2.3.1 Solar Cell	8

	2.3.2	The Function of Charge Controller in Stand-alone Solar System	10
	2.3.3	The Function of Battery Bank in Stand-alone Solar System	11
	2.3.4	The Function of Inverter in Stand-alone Solar System	12
	2.4	System Protection	13
	2.5	System Sizing	15
	2.6	Economic Analysis of Stand-alone Solar System	15
<b>3</b>	<b>METHODOLOGY</b>		<b>16</b>
	3.1	Stand-alone PV Solar System Sizing Design Calculation	16
	3.1.1	Load Analysis	16
	3.1.2	Irradiation to Load Ratio ( $R_{IL}$ )	16
	3.1.3	System Voltage (SV)	19
	3.1.4	Total Load Current (A)	19
	3.1.5	Total Capacity Required Daily (Ah)	20
	3.1.6	Battery Bank Capacity Required (Ah)	20
	3.1.7	The Required Revised Battery Bank Capacity	21
	3.1.8	Current Discharge Bank	23
	3.1.9	The Rate of Bank Discharge	23
	3.1.10	The Total Batteries Installed in Series String	23
	3.1.11	The Total Batteries Installed in Parallel	24
	3.1.12	Daily Depth of Discharge of Bank $DOD_d$	24
	3.1.13	The Sizing of PV Array	24
	3.1.14	Sizing of Inverter	29
	3.1.15	Charger Controller	29
	3.1.16	Bypass Diodes	30
	3.1.17	Blocking Diodes	30
	3.1.18	Fuses/Circuit Breaker Sizing	31
	3.2	Economic Analysis	32
	3.2.1	Life Cycle Cost Analysis of Stand-alone Solar System	32

	3.2.2	Annual Lifetime Cost Unit Electrical Cost	35
	3.2.3	Payback Period	36
	3.3	Methodology Flowchart	37
<b>4</b>		<b>RESULTS AND DISCUSSION</b>	<b>38</b>
	4.1	The Design of Stand-alone Solar System	38
	4.1.1	Analysis of the Load	40
	4.1.2	Irradiation of Load Ratio	42
	4.1.3	Determination of System Voltage (SV) for the System	43
	4.1.4	The Value of Total Load Current (A)	43
	4.1.5	The Value of Total Capacity Required Daily	42
	4.1.6	The Capacity of Battery Bank Required	44
	4.1.7	The Required Capacity of Revised Bank	44
	4.1.8	The Current of Bank Discharge	45
	4.1.9	The Rate of Bank Discharge	45
	4.1.10	Total of Batteries Required in Series String	46
	4.1.11	Total of Batteries Required in Parallel String	46
	4.1.12	Total of Batteries Required in Battery Bank	47
	4.1.13	Daily Depth of Discharge of Bank $DOD_d$	48
	4.1.14	Sizing of PV Array	48
	4.1.15	Charger Controller	51
	4.1.16	Sizing of Inverter	51
	4.1.17	Bypass Diodes	52
	4.1.18	Fuses/Circuit Breaker Sizing	53
	4.1.19	Design Drawing	56
	4.2	Economic Analysis for System Design	57
	4.2.1	Life Cycle Cost (LCC) Analysis for System Design	57
	4.2.2	Annual Lifetime Cost and Unit Electrical Cost	61
	4.2.3	Payback Period	62
	4.3	Calculation Analysis VS HOMER Software Analysis	62
<b>5</b>		<b>CONCLUSION</b>	<b>65</b>



<b>REFERENCES</b>	<b>67</b>
<b>APPENDIX</b>	<b>69</b>

**LIST OF TABLES**

<b>NO. TABLE</b>	<b>TITLE</b>	<b>PAGE</b>
2.1	Comparison of Grid-connected solar system and stand alone Solar system	8
3.1	Recommendation of System Voltage (V).	19
3.2	Vented lead-acid battery (IEEE485) temperature correction factor	22
4.1	Load demand of the design system	38
4.2	Solar energy and surface meteorology of Malacca	39
4.3	Load analysis for the system	40
4.4	The data for $R_{IL}$ for each months	42
4.5	Comparison between calculation analysis and HOMER software analysis	63

## LIST OF FIGURES

<b>NO. FIGURES</b>	<b>TITLE</b>	<b>PAGE</b>
2.1	Illustration of Stand-alone solar system with battery bank	5
2.2	Illustration of Grid-connected solar system without battery bank	7
2.3	Four type of solar cells in the market	9
2.4	Charger Controller for Solar System	10
2.5	Battery Bank	11
2.6	Parallel and series connection string of batteries	11
2.7	Solar Inverter	12
2.8	Blocking Diodes Installation	13
2.9	Bypass Diodes Connection and their Operation	14
3.1	Methodology Flowchart	37
4.1	Fuses characteristic chart for PV strings	54
4.2	Fuses characteristic chart for PV sub-array	55
4.3	The drawing of designing system	56
4.4	Result by using HOMER software.	64

**LIST OF APPENDICES**

<b>APPENDIX</b>	<b>TITLE</b>	<b>PAGE</b>
A	PV Modules (BP Solar SX 3175N 175 Watt) datasheet	69
B	ALLERGO TC10/48 Inverter datasheet	70
C	LONGWAY 6FM150S Battery datasheet	71
D	HOPPECKE 5 OpzS Battery Datasheet	73
E	TROJAN L16RE-2V Battery Datasheet	75
F	PLASMATRONICS PL60 Charger Controller	77

## **CHAPTER 1**

### **INTRODUCTION**

#### **1.1 Overview**

In Malaysia, the demand of electrical power is increasingly day by day in order to fulfill the daily demand from the loads. However, there is a problem for specific area especially in rural places which normally have a lack of electricity because of difficulty to reach to the national electric grid. Due to improvise and to overcome this problem, renewable energy is one of the best solution because this is the type of energy that comes from the natural energy which is the sunlight. By using renewable energy, it will give an extra advantage to the load since they will not exhaust unlike the conventional energy. Due to that, in order to convert the sunlight energy to a useful energy, some device with a specific system is required. The device that normally used for energy conversion is photovoltaic (PV) module. PV module is assembled with PV cells that know as solar cells. The installation of photovoltaic typically involve an array of photovoltaic panels or module, batteries, interconnection wiring and the type of inverter [1-2].

In addition, there are many design and application process for solar system. One of the best design that able to be installed in rural area is Stand-alone solar system. However, the design of Stand-alone solar system is complex because it will be operated without connected to the main electric's grid. On the other hand, the system needs to be design properly to ensure the system is operated with high efficiency and to reduce any

troubles during its application even though the system have a highest startup and cost of maintenance. The followed section of this paper will discussed a lots of factors that need to be considered during designing the system. The load calculation in order to determine the lowest of life cycle cost of the system and also the return of investment of the system are also discussed in this paper.

## **1.2 Problem Statement**

Since the demand of electricity in rural area is increasingly day by day, the interest toward renewable energy also grown constantly in order to produce the electricity. Renewable energy become most popular nowadays since the energy will not exhaust unlike conventional energy form. One of the best system that will be selected for conversion energy is solar Photovoltaic. Stand-alone solar system and Grid connected solar system are two types of Photovoltaic system that normally used in Malaysia.

In order to design Stand-alone solar system, designer need to consider many important aspect because the system is more complex compared to the Grid connected Solar System. The designing system need to design properly to ensure the system operated without failed and the system able to operate with high efficiency. On the other hand, the economics analysis of the designing system must be done by designer in order to determine the cost of system from start-up the system until the maintenance cost of the system.

## **1.3 Objective**

The objective of this project was focused clearly to design a simple Stand-alone solar system for rural areas based on a lot of factors in order to ensure the system operate successfully and to determine the economic analysis in order to know the lowest of life

cycle cost of the system and also the return of investment of designing Stand-alone solar system.

#### **1.4 Scope of Work**

Scope of this work involved

1. The analysis of Stand-alone solar system for remote area and their economic analysis starting from start-up the system until the maintenance cost of the system.
2. The design of Stand-alone solar system with consideration a lot of important factor to ensure the designing system is operated on design potential since the design is more complex compare to Grid-connected solar system
3. The economic analysis involve the cost of installation, life of cycle cost, the payback period and maintenance cost of the system.

#### **1.5 Project Report Layout**

This paper are divided into 5 chapters. Chapter 1 gives an introduction about the project which give a briefly explanation about the renewable energy and the selected design have been choose based on the case study. The background, problem statement of the project, objectives, scope of project and report outlines are included in this chapter.

Chapter 2 consist the overview of the project that has been done. This chapter included the information of Stand-alone solar system design and the basic information for economic analysis of the system. Meanwhile the equipment that have been used is stated at the end of this chapter.

Chapter 3 gives the methodology of this research. Readers can have a clear view on how the Stand-alone solar system and economic analysis of the designing system can be done. The calculation procedure and all the equation that will be used in the designing system is stated precisely.

Chapter 4 described the obtained results of designing system such as the sizing of the PV system with their economic analysis which referred from the equation that have been stated in Chapter 3.

Chapter 5 gives conclusion and recommendation of this project. The knowledge obtained from this project and the usefulness of this project is concluded. The weakness of this project is suggested in the recommendation to enable improvement to be done.



## REFERENCES

- [1] A. Kay and M. Grätzel, "Low cost photovoltaic modules based on dye sensitized nanocrystalline titanium dioxide and carbon powder," *Solar Energy Materials and Solar Cells*, vol. 44, pp. 99-117, 2010.
- [2] M. A. Green, et al., "Solar cell efficiency tables (version 39)," *Progress in photovoltaics: research and applications*, vol. 20, pp. 12-20, 2011.
- [3] Mingzhi Zhao, Zhizhang Liu."Design and Application of Off-Grid Solar PV System in Inner Mongolia of China" University Of Technology Hohhot, China, 2009
- [4] Shen Weixiang."Design of Standalone Photovoltaic System at Minimum Cost in Malaysia" School Of Engineering, Monash University, 2008.
- [5] Prof Mad Gan Chin Kim, Kyairul Azmi Baharin, and Tan Pi Hua. "Two-Day Course On Grid-Connected Solar PV System: Hands-On Approach", 2014.
- [6] Frank Yeboah Dadzie, "Design of A Grid Connected Photovoltaic System for KNUST and Economic and Environmental Analysis of the Design System", February 2008
- [7] Grid-Tied, Off-Grid and Hybrid Solar Systems, Retrieved From [Http://Energyinformative.Org/Grid-Tied-Off-Grid-And-Hybrid-Solar-Systems/](http://Energyinformative.Org/Grid-Tied-Off-Grid-And-Hybrid-Solar-Systems/)
- [8] Bp Solar Distributor "Blocking Diode Installation Instructions", SM 335 Issue C 03.11.05, Marlec Engineering Co Ltd
- [9] A. Boronat, A. Chouder. "Study of Bypass Diodes Configuration on PV Modules". Electronics Engineering Department – UPC, 2008
- [10] Assad, Abu-Jasser. "A Stand-Alone Photovoltaic System, Case Study: A Residence in Gaza". *Journal of Applied Sciences in Environmental Sanitation*. 5(1), 81-92, 2010.
- [11] *Solar Electric System Design, Operation and Installation*, Washington State University, 2009.
- [12] Sulaiman Shaari, Ahmad Maliki Omar. "Solar Photovoltaic Power: Design Stand Alone Systems".2010.
- [13] San Ramon. "A Guide to Photovoltaic (PV) System Design and Installation" California Energy Commission Report, 2001.

- [14] MS 62257-1-1:2010. "Recommendations for Small Renewable Energy and Hybrid Systems for Rural Electrification" Department Of Standards Malaysia, 20
- [15] MS 62257-5:2009. "Recommendations for Small Renewable Energy and Hybrid Systems for Rural Electrification - Part 5: Protection against Electrical Hazards", Department Of Standards Malaysia. 2009.
- [16] Robert Lyons, Jr. "Sizing Fuses for Photovoltaic Systems per the National Electrical Code". Tech Topics: PV Protection Note 5, Issue 1, 2012.
- [17] IRENA Secretariat "RENEWABLE ENERGY TECHNOLOGIES: COST ANALYSIS SERIES" Volume 1: Power Sector Issue 4/5, June 2012.
- [18] Donald Chung, Carolyn Davidson, Ran Fu, Kristen Ardani, and Robert Margolis "U.S. Photovoltaic Prices And Cost Breakdowns", Q1 2015 Benchmarks For Residential, Commercial, And Utility-Scale Systems, September 2015.
- [19] David Feldman, Galen Barbose, Robert Margolis, Ted James, Samantha Weaver, Naim Darghouth, Ran Fu, Carolyn Davidson, Sam Booth, And Ryan Wisner Photovoltaic "System Pricing Trends" Historical, Recent, And Near-Term Projections 2014 Edition, Sunshot U.S Department Of Energy, September 2014.
- [20] Abd El-Shafy A. Nafeh, "Design And Economic Analysis Of A Stand-Alone PV System To Electrify A Remote Area Household In Egypt", Electronics Research Institute, Cairo, Egypt, 2009.
- [21] Zulaika Binti Mohd Zain,"Design And Analysis Of 1MW On Grid Connected Solar PV Power System In Malaysia",Universiti Teknikal Malaysia Melaka, 2015.
- [22] J. Abdulateef, K. Sopian, W. Kader, B. Bais, R. Sirwan, B. Bakhtyar And O. Saadatian "Economic Analysis Of A Stand-Alone PV System To Electrify A Residential Home In Malaysia", Solar Energy Research Institute (SERI), University Kebangsaan Malaysia.
- [23] SENTRON,"Fuse Systems Configuration Manual", SIEMENS, 2012