

CONTROL OF AIR-CONDITIONING SYSTEM FOR LOAD MANAGEMENT

AZMI BIN AHMAD

A project report submitted in partial fulfilment of the
requirements for the award of the degree of
Master of Engineering (Electrical Power)

School of Electrical Engineering
Faculty of Engineering
Universiti Teknologi Malaysia

JANUARY 2019

DEDICATION

This thesis is dedicated to:

My father, Haji Ahmad Bin Sahuri, who taught me that the best kind of knowledge to have is that which is learned for its own sake.

My mother, Hajjah Hasnah Bte Shud, who taught me that even the largest task can be accomplished if it is done one step at a time.

My spouse, Hawa Binti Bakri for being very understanding and supportive in keeping me going, enduring the ups and downs during the completion of this thesis.

My family, for their patience, support, love and prayers

ACKNOWLEDGEMENT

In preparing this thesis, I was in contact with many people, researchers, academicians, and practitioners. They have contributed towards my understanding and thoughts. In particular, I wish to express my deepest appreciation to all those who helped me, in one way or another, to complete this thesis. Alhamdulillah! First and foremost, I thank to the Almighty Allah S.W.T for His blessings and guidance for providing me with strength, direction and showered me in completing this project. My sincerest gratitude to my supervisor, Dr. Siti Maherah Hussin for her continuous guidance, support, advices and motivation. With his expert guidance and immense knowledge, I was able to overcome all the obstacles that I encountered during my journey of completing this Master Project. I could not have imagine having a better advisor and mentor who has been more like a fatherly figure to me.

I am also indebted to Universiti Teknologi Malaysia (UTM) and Kerajaan Malaysia for allowing to continue my Master's Degree study. Assistant Engineers and Researcher's Officers at Power Quality Laboratory and Centre of Electrical Energy System, UTM, also deserve special thanks for their assistance in supplying the relevant equipment.

My fellow postgraduate student should also be recognised for their support. My sincere appreciation also extends to all my colleagues and others who have provided assistance at various occasions. Their views and tips are useful indeed. Unfortunately, it is not possible to list all of them in this limited space. I am grateful to all my family member. Without their continued support and interest, this thesis would not have been the same as presented here.

ABSTRACT

The cooling system is one of the major and critical energy consuming loads in any premise. Efficient energy management of this critical load is important to achieve economic operation. Controlling the air conditioning (AC) system allows to reduce the peak consumption, indirectly the electricity bills. Due to privacy concerns, users' participation and limitation of AC's program interfaces is major obstacles in load management. In order to maintain the indoor comfort level and working efficiency, the users' temperature set point is controlled by an adaptive control algorithm. Changing the AC's temperature set-point into multiple time slot show the significant potential in electricity savings. Simulation model using PID controller based on load profile of ACs' installed at Jabatan Penyiaran Negeri Johor will be conducted to determine the effectiveness of proposed control strategy. Then, field measurement is done based on group of AC's unit and individual by setting its temperature set-point and operation time without any changes in comfort level. Both simulation and field measurement results show significantly peak load reduction of 56% which lead to lowering the overall electricity bill of premises.

ABSTRAK

Sistem penyejukan adalah salah satu beban utama dan kritikal dalam mana-mana premis. Pengurusan tenaga yang cekap untuk beban kritikal ini penting untuk mencapai operasi ekonomi. Mengawal sistem penyaman udara (AC) membolehkan mengurangkan penggunaan puncak, secara tidak langsung bil elektrik. Disebabkan kebimbangan privasi, penyertaan pengguna dan had antara muka program AC adalah halangan utama dalam pengurusan beban. Bagi mengekalkan tahap keselesaan dalam bilik dan kecekapan kerja, tetapan suhu oleh pengguna boleh dikawal oleh satu algoritma kawalan penyesuaian. Mengubah tetapan suhu dan menghidupkan / matikan AC ke dalam slot kawalan masa dapat menunjukkan potensi yang ketara dalam penjimatan elektrik. Model simulasi menggunakan pengawal PID berdasarkan profil beban AC yang dipasang di Jabatan Penyiaran Negeri Johor akan dijalankan untuk menentukan keberkesanan strategi kawalan yang dicadangkan. Kemudian, pengukuran lapangan dilakukan berdasarkan kumpulan unit dan individu AC dengan menetapkan suhu tetapan dan masa pengoperasian tanpa sebarang perubahan dalam tahap keselesaan. Kedua-dua hasil pengukuran lapangan dan simulasi menunjukkan pengurangan beban puncak yang ketara sebanyak 56% yang membawa penurunan kepada keseluruhan bil elektrik sesebuah premis.

TABLE OF CONTENTS

	TITLE	PAGE
	DECLARATION	ii
	DEDICATION	iii
	ACKNOWLEDGEMENT	iv
	ABSTRACT	v
	ABSTRAK	vi
	TABLE OF CONTENTS	vii
	LIST OF TABLES	x
	LIST OF FIGURES	xi
	LIST OF ABBREVIATIONS	xiii
	LIST OF SYMBOLS	xiv
	LIST OF APPENDICES	xv
CHAPTER 1	INTRODUCTION	1
1.1	Chapter Overview	1
1.2	Motivation of Study	3
1.3	Problem Statement	4
1.4	Project Objectives	4
1.5.	Project Scope	5
1.6	Project Report Outline	5
1.7	Chapter Summary	6
CHAPTER 2	LITERATURE REVIEW	7
2.1	Chapter Overview	7
2.2	Review of Control Strategy Method For Air Conditioning System	7
2.3	Research Gap	12
2.4	Brief Description on Closed Loop Control System	13
2.4.1	Closed-loop Summing Points	14

2.4.2	Closed-loop System Transfer Function	14
2.5	Brief Description on Temperature Control System	15
2.5.1	PID Temperature Control	15
2.5.2	Proportional Action	18
2.5.3	Integral Action	19
2.5.4	Derivative Action	19
2.5.5	High and low cutback	19
2.6	Chapter Summary	20
CHAPTER 3	RESEARCH METHODOLOGY	21
3.1	Chapter Overview	21
3.1.1	Research Framework	21
3.1.2	Proposed Method	22
3.2	Load Research	23
3.2.1	Load Profile Acquisition	24
3.3	Determining the Control Strategy	26
3.4	Control System Modelling	28
3.5	Simulation Process by MATLAB ® Simulink	30
3.6	Chapter Summary	32
CHAPTER 4	RESULTS AND DISCUSSIONS	34
4.1	Chapter Overview	34
4.2	Simulation Result	34
4.3	Field Measurement	36
4.3.1	Group Field Measurement	37
4.3.2	Individual Field Measurement	39
4.4	Result Validation	42
4.4.1	Validation 1: YORK/YWM15G (1.5 HP)	43
4.4.2	Validation 2: YORK/YWM20G (2.0 HP)	43
4.4.3	Validation 3: YORK/YCC25C (2.5 HP)	44
4.4.4	Validation 4: Combination of 1.5HP, 2.0HP and 2.5HP	45

4.4	Chapter Summary	46
CHAPTER 5	CONCLUSION AND RECOMMENDATIONS	49
5.1	Research Outcomes	49
5.2	Future Works	49
REFERENCES		51
APPENDICES A – D		53-59

LIST OF TABLES

TABLE NO.	TITLE	PAGE
Table 1.1	Load (AC unit) Information at Jabatan Penyiaran Negeri Johor	3
Table 2.1	Literature Review On Control Strategy Method For Air Conditioning System	10-11
Table 3.1	Energy Consumption of AC unit at Jabatan Penyiaran Negeri Johor	24
Table 4.1	List of AC units of group field measurement	38
Table 4.2	Power Reduction of Individual Field Measurement	41

LIST OF FIGURES

FIGURE NO.	TITLE	PAGE
Figure 1.1	Different type of load shape objective	1
Figure 2.1	Proposed strategy of temperature control method	12
Figure 2.2	Summing point use in closed-loop system	14
Figure 2.3	Typical Closed-loop System Representation	15
Figure 2.4	PID Control Method	17
Figure 2.5	PID Control – Proportional Action	18
Figure 2.6	PID Control – High and low back Action	20
Figure 3.1	Research Methodology	22
Figure 3.2	Electrical Single Line Diagram	25
Figure 3.3	Daily Load Profile of Studio Block and Auditorium	25
Figure 3.4	Daily Load Profile of Studio Block	26
Figure 3.5	Electricity Bills For Incoming TNB No.2	27
Figure 3.6	Algorithm for Temperature Control System	28
Figure 3.7	Sample of Temperature PID Controller in MATLAB [®] Simulink	29
Figure 3.8	Developed Temperature Control Model in MATLAB [®] Simulink	30
Figure 3.9	PID (a) tune signal (b) response signal (output controller of developed model) by PID tuning module (MATLAB [®] Simulink)	31
Figure 3.10	Simulation of developed model (T_{out} , T_{set} & T_{ctrl})	32
Figure 3.11	Simulation of AC's power consumption using developed model	32
Figure 4.1	Simulation result of YORK/YWM15G (1.5 HP)	35
Figure 4.2	Simulation result of YORK/YWM20G (2.0 HP)	35
Figure 4.3	Simulation result of of YORK/YCC20C (2.5 HP)	36
Figure 4.4	Electrical Single Diagram For Field Measurement	36

FIGURE NO.	TITLE	PAGE
Figure 4.5	Location and measurement point of group field measurement	37
Figure 4.5	Group field measurement of Studio Block	39
Figure 4.6	Individual field measurement point	27
Figure 4.7	Results of individual field measurement	41-42
Figure 4.8	Validation of simulation result with field measurement (Single type) for YORK/YWM15G (1.5HP)	43
Figure 4.9	Validation of simulation result with field measurement (Single type) for YORK/YWM20G (2.0HP)	44
Figure 4.10	Validation of simulation result with field measurement (Single type) for YORK/YCC25C (2.5HP)	45
Figure 4.11	Final Validation of simulation result with field measurement (Combination)	46
Figure 4.12	Load Profile of Studio Block (before and after)	47
Figure 5.10	Future works in controlling the AC's compressor unit at new set-point	50

LIST OF ABBREVIATIONS

AC	-	Air-Conditioning
DB	-	Distribution Board
DSM	-	Demand Side Management
HP		Horsepower of AC Conditioning
PID	-	Proportional, Integral and Derivative
RTM	-	Radio Televisyen Malaysia

LIST OF SYMBOLS

θ_{user}	-	Initial AC set-point temperature by user
$\theta_{setpoint}$	-	In-control set-point temperature
θ_{new}	-	New set-point temperature
θ_{max}	-	Maximum set-point temperature

LIST OF APPENDICES

APPENDIX	TITLE	PAGE
Appendix A	Air Conditioning Units' Specification	53
Appendix B	Letter of Request For Load Research	56
Appendix C	Government's Circular on Energy Saving Campaign	57
Appendix D	MATLAB Function Code	59

CHAPTER 1

INTRODUCTION

1.1 Chapter Overview

Demand Side Management (DSM) is the modification of consumer's demand of electricity through various methods such as financial incentives and consumer education. The goal of DSM is to encourage the consumers to use less energy during peak hours or to move the time of energy use to the off-peak hours or night time. Many ways to achieve the load shape objective to reduce the total power consumption by consumers as shown in Figure 1.1. The most popular approach in reducing the demands are peak clipping (peak shaving) application for premises which have shorter working hours. Whereas, conservation and load shifting approach is applicable to premises operated 24 hours daily. Many researchers have proposed peak shaving application in their load management strategies [1]–[3], [7] while [4] proposed the load shifting purposes.




Figure 1.1 Different type of load shape objective

Many premises or buildings especially in big city installed large amount of air conditioning unit either in package unit or individual unit. There are many types of AC unit produced by manufacturers to fit the purposes of functional of premises or building in offering the thermal comfort to whom occupied the offices, spaces and rooms. Spaces like Auditorium require a package water-chiller cooling system to provide desired level of comfort to audiences, where as rooms or offices require one

or more individual air-conditioning (AC) unit either split, cassette or fan-coil type depending on their size, application and functionality.

Due to this, the specification of AC is depended on the area of coverage need to be covered. One of most popular parameters need to be considered is BTU (British Thermal Unit) rating, which indicates the amount of heat it can remove from a room. The air conditioner EER is its British thermal units (BTU) rating over its wattage. For example, if a 10,000-BTU air conditioner consumes 1,200 watts, its rating is 8.3 (10,000 BTU/1,200 watts). The higher the BTU rating is, the more efficient the air conditioning unit is. Besides that, horsepower (HP) also is among the most popular parameter in which measuring the power consumed by AC unit. Converting to wattage unit is a matter of multiplying by a conversion factor where one HP is equal to 745.7 watts, and one kilowatt equals 1.337 HP. The higher the HP rating is the higher the power consumption.

Imagine that, the large number of AC units installed in premises will increase the power consumption as well as the load demand. If the load is not managed properly, the generation needs to be expanded that will increase the cost to utilities, indirectly the energy (electricity) cost will also increase. It will burden the consumers. The loads need to be controlling to overcome the shortage of demand.

The AC unit is a machine operated on the vapor compression cycle. It consists of an evaporator, a condenser, a compressor and an expansion valve. Conventionally, when the indoor temperature is higher than the set point, the compressor turns on; otherwise it turns off. The on/off operation not only consume significant power, but also causes large variations in indoor temperature. Thus, an adaptive control system to AC units need to be developed and designed based on simulation and field measurement.

MathWorks MATLAB is an applicable software in various aspects of engineering such as Electrical engineering and its different sub majors. There are a lot of examples and demos on these majors, although there is a few text or example on MATLAB application in energy management. In this project, I have provided a

simulation model of set-point temperature control algorithm for air-conditioning unit using MATLAB® Simulink software.

1.2 Motivation of Study

The purpose of this study is to investigate the simulation of MATLAB® Simulink in modelling control system for air-conditioning (AC) unit and develop an adaptive control algorithm based on simulation model. Temperature control method was used as the benchmark for the proposed algorithm. A PID controller based on power consumption of AC's installed in Jabatan Penyiaran Negeri Johor as in Table 1.1 has been proposed in this study to reduce the energy consumption of each AC unit.

The effect of changing the AC's temperature set-point into multiple time slots was studied and the effectiveness and shortcomings of control strategy were highlighted. Results were compared between actual load profile and benchmark temperature control method. It was discovered that with different load characteristic, in most cases, temperature control method performs effectively in contribution of peak load reduction of each AC.

Table 1.1 : Load (AC unit) Information at Jabatan Penyiaran Negeri Johor

Model No.	Quantity	Energy Consumption (W)	Operation hours	Total Consumption (W)
YORK/YWM20G-AMLBF	14	1793	9	225,918.00
YORK/YWM15G-AMLBF	17	1201	9	183,753.00
YORK/YCC25C-AMSLA	7	2060	24	346,080.00
ACSON A5WM25S	4	2140	24	205,440.00
YORK/YCK20AL-AFAB	6	2071	9	111,834.00
ACSON A5CK30F-AMOIA-R	1	2568	9	23,112.00
Grand Total	49			1,096,137.00

1.3 Problem Statement

Air-conditioning (AC) systems are one of the major consumers of energy and have significant influence on the overall energy usage of homes and buildings. Thus, controlling the energy consumption of ACs can lead to a significant energy savings for an entire electricity system and enormous impact of ACs on the overall energy consumption of buildings. Studying the energy consumption behavior and developing means for effective control without compromising users' comfort have become a central focal point of energy management research. Air conditioning units that can be controlled remotely and the customers can purchase such units that subsidies from the utilities company. The approach where the utilities can turn off the air conditioners through network for about 10 to 15 min each time when it needs to shed the loads. However, it is inconvenient to both the customers and the utilities company. Each customer does not know when the air conditioner is going to be turned off. For the utilities company, controlling hundreds of small air conditioner loads is neither effective nor efficient. Thus, this project is proposed with an approached a simulation model of control strategy to changing the AC's temperature set-point and switching on/off into multiple time slot show the significant potential in electricity savings.

1.4 Project Objectives

The objectives of this project have been identified and it should be achieved to produce a successful simulation system for air-conditioning temperature control system. The objectives of this project are as follows:

- (a) To design of temperature control strategy using PID controller on MATLAB® Simulink.
- (b) To determine the effectiveness of the proposed control algorithm in peak shaving application
- (c) To *validate* the proposed method based on field testing for peak load reduction

1.5 Project Scope

In achieving the objectives of the project, the scope is required to assist and set milestone and direction of the project development. These scopes should be identified and planned appropriately, which are:

- (a) Perform load research on total power consumption to shape the real-time load curve on daily energy consumption at Jabatan Penyiaran Negeri Johor (RTM).
- (b) Study the load shape of power consumption of AC unit installed in offices and rooms at Studio Block based on user set-point temperature.
- (c) Model the algorithm for temperature control using PID controller to meet new set-point temperature.
- (d) Use MATLAB® Simulink to simulate load characteristics for AC unit of 1.0HP, 2.0HP and 2.5HP type of related to temperature control system.
- (e) Perform field test to verify the load characteristics for individual and group of AC units using proposed control strategy.
- (f) Validate the simulation results with field measurement to show the effectiveness of control strategy for verification of peak load reduction.

1.6 Project Report Outline

This project report presented in five chapters which is beginning with Introduction (Chapter 1), Literature Review (Chapter 2), Methodology (Chapter 3), Result and Discussions (Chapter 4) and Conclusion (Chapter 5). Chapter 1 will give an introduction of project contains project's background, motivation of study, problem statement, objectives and scopes.

Chapter 2 focuses on literature review of various control method in demand side management as well as their advantages in reducing power consumption.

Studying in each limitation presented by past researchers, the gap is laid out to propose new control strategy based on selected pilot papers.

The methodology involved in completing this project was designated in Chapter 3. The determination of the proposed control strategy based on load research and the development of control model in MathWorks MATLAB are briefly explained. Then, the develop model are tested for verification on effectiveness of control system.

Chapter 4 provides the discussion on the results obtained from simulation and field measurement. The developed model will run on simulation and validate with field test to access the performance and effectiveness of the proposed control system.

In last chapter, the project outcomes are concluded, and recommendation of future works are stated.

1.7 Chapter Summary

As summary, this chapter briefly discussed about the DSM and its application, and the AC load and its control in which provided the motivation to overcome problem stated to meet the objectives based on scopes presented in next the following chapter.

REFERENCES

1. S.C. Lee, S.J. Kim, S.H. Kim, "Demand Side Management With Air Conditioner Loads Based on the Queuing System Model", *IEEE Transactions On Power Systems*, Vol. 26, No. 2, pp. 661-668, May 2011
2. K. Le, T. Tran-Quoc, J. C. Sabonnadiere, Ch. Kieny, N. Hadjsaid, "Peak load reduction by air-conditioning regulators", *MELECON 2008 - The 14th IEEE Mediterranean Electrotechnical Conference*, pp. 713 – 718, 2008.
3. R.G Sai; W.T Li; T.W Tushar; Y. Chau; U.H Naveed, W. Kristin, C.K Wen and H.V. Poor, "Energy Management by Controlling Air Conditioning Systems in Residential Settings" *IEEE Workshop on Environmental, Energy, and Structural Monitoring Systems (EESMS)*, pp. 1 – 5, 2016.
4. H. Xiaoqing, W. Beibei, Y. Shengchun, Z. Lei, S. Thorsten, "A Closed-Loop Control Strategy for Air Conditioning Loads to Participate in Demand Response", *Energies* 2015, 8, pp. 8650-8681, doi:10.3390/en8088650.
5. F. Kyosuke, N. Hiroaki, "Evaluation of Power Consumption and Comfort using Inverter Control of Air-conditioning", *IECON 2011 - 37th Annual Conference of the IEEE Industrial Electronics Society* pp. 3236 – 3241, 2011.
6. A.G Adnan, U. Nadeim, "Air Conditioner Control Using Neural Network and PID Controller", 2012 8th International Symposium on Mechatronics and its Applications, pp. 1-5, 2012.
7. Z. Wei, L. Jianming, C. Chin-Yao, K. Karanjit, "Aggregated Modeling and Control of Air Conditioning Loads for Demand Response", *IEEE Transactions On Power Systems*, Vol.28, No.4, pp. 4655-4664, November 2013.
8. Y. Snejana, M. Daniel. J. Lakhmi, "A Two-Variable Fuzzy Control Design With Application to an Air-Conditioning System", *IEEE Transactions on Fuzzy Systems*, Vol. 23, Issue. 2, pp. 474 – 481, April 2015.
9. T. Yasushi, K. Kenichi, K. Nobuhisa, M. Junichi, G. Tadahiro, "Energy Efficient Demand Control for Air-Conditioning Systems", 2013 IEEE Power & Energy Society General Meeting, pp. 1–5, 2013
10. K.Mahmoud, "Modeling and Simulation of Residential HVAC System Energy Consumption", The 5th International Conference on Sustainable Energy Information Technology (SEIT 2015), pp.754-763, 2015.
11. N. Kocyigit, M.E. Sahin, "Design of Laboratory Unit Air-Conditioning System with Matlab/Simulink Software", 3rd International Conference on Computational and Experimental Science and Engineering (ICCESEN 2016), Vol.132, No.3-1, pp.839-842, 2017

12. D. Jackravut, T. Nutthaphong, "A Simplified Air-conditioning System Model with Energy Management", 2016 International Electrical Engineering Congress (iEECON2016), pp. 361-364, 2016.