

POWER CONDITIONING FOR ENERGY SYSTEMS IN GREEN BUILDINGS

JAVED AHMAD

A project report submitted in partial fulfilment of the
requirements for the award of the degree of
Master of Engineering (Electrical Power)

School of Electrical Engineering
Faculty of Engineering
Universiti Teknologi Malaysia

JANUARY 2019

DEDICATION

Specially dedicated to my supervisor, my family, and Jasmine who encouraged me throughout my journey of education.

ACKNOWLEDGEMENT

First and foremost, all gratitude to the omnipresent Allah for giving me the strength through my prayers.

I would like to express my gratitude to my supervisor Assoc. Prof. Dr. Naziha Binti Ahmad Azli for her cooperation, guidance, inspiration, and valuable bits of advice while doing this project.

In addition, I sincerely thank all the lecturers who have taught me, for the lessons delivered and the morals supported, not to forget mentioning my friends whom I sincerely thank for their useful ideas, suggestion, and help. I would like to express my love, gratitude, and appreciation to my beloved parents, my brothers, and my friends for their love, prayers, patience, support, and encouragement they provide during my studies.

ABSTRACT

This research work proposes an improved model of stand-alone renewable energy system for green buildings by using a sinusoidal pulse width modulation (SPWM) multilevel inverter with a smaller number of power switches. The energy sources for this system is photovoltaic (PV) solar panels. The main advantage of using multilevel inverter rather than normal two-level inverter is the reduction in the output voltage harmonics and this leads to a reduction in the filter size. In this case, the number of power switches used as well as the number of the gate driver circuits required is less compared to the cascaded H-bridge multilevel inverter (CHMI), therefore the weight and switching losses due to the inverter is reduced. To test the effectiveness of the proposed model simulations are carried out using MATLAB/Simulink under temperature and irradiance varying conditions. In addition to the use of the multilevel inverter, a perturb and observe (P&O) maximum power point tracking (MPPT) algorithm is used for the PV array and a feedforward control system is used for the output voltage control. This research work is carried out to develop a model of stand-alone renewable energy system which is capable to provide constant 240 volts to the load at 50 Hz irrespective to the disturbances on the PV side. Simulations are carried out for both constant as well as for varying conditions and it is found that the output voltage of the inverter is constant and stable for both the cases at 240 volts, 50 Hz.

ABSTRAK

Kerja penyelidikan ini mencadangkan satu model sistem tenaga diperbaharui untuk bangunan hijau dengan menggunakan penyongsang pelbagai aras “sinusoidal pulse width modulation (SPWM)” yang lebih kecil. Sumber kuasa untuk sistem ini ialah panel solar fotovolta (PV). Kelebihan utama menggunakan penyongsang pelbagai aras berbanding penyongsang dua aras ialah pengurangan harmonik voltan keluaran yang membawa kepada pengurangan saiz penapis. Dalam kes ini, jumlah suis kuasa yang digunakan dan bilangan litar pemacu get yang diperlukan adalah kurang berbanding dengan penyongsang pelbagai aras litar-jambatan H (CHMI), maka berat dan kehilangan pensuisan disebabkan oleh penyongsang dapat dikurangkan. Bagi menguji keberkesanan model simulasi yang dicadangkan menggunakan MATLAB / Simulink telah dijalankan di bawah keadaan suhu dan jradiasi berubah-ubah. Sebagai tambahan kepada penggunaan penyongsang pelbagai aras, algoritma pengesanan dan pemantauan (P&O) pengesanan titik kuasa maksimum (MPPT) digunakan untuk jajaran PV dan sistem kawalan suapan hadapan digunakan untuk kawalan voltan keluaran. Kerja penyelidikan ini dijalankan untuk membangunkan satu model sistem tenaga boleh diperbaharui sendiri yang dapat memberikan 240 Volt yang berterusan kepada beban pada 50 Hz tanpa mengira gangguan pada bahagian PV. Simulasi dijalankan untuk kedua-dua keadaan malar dan berubah-ubah dan didapati bahawa voltan keluaran penyongsang adalah malar dan stabil untuk kedua-dua kes pada 240 Volt, 50 Hz.

TABLE OF CONTENTS

	TITLE	PAGE
	DECLARATION	iii
	DEDICATION	iv
	ACKNOWLEDGEMENT	v
	ABSTRACT	vi
	ABSTRAK	vii
	TABLE OF CONTENTS	viii
	LIST OF TABLES	xi
	LIST OF FIGURES	xii
	LIST OF ABBREVIATIONS	xiv
CHAPTER 1	INTRODUCTION	1
	1.1 Background Study	1
	1.2 Problem Statement	2
	1.3 Objective	3
	1.4 Scope	3
	1.5 Contributions of Research Work	4
	1.6 Report Organization	4
CHAPTER 2	LITERATURE REVIEW	5
	2.1 Microgrid System.	5
	2.1.1 Grid-Connected Mode	5
	2.1.2 Stand-Alone or Islanded Mode	6
	2.2 Components Microgrid System	6
	2.3 Distributed generation	6
	2.3.1 Solar Power	7
	2.3.2 Fuel Cell	7
	2.3.3 Wind Turbine Generation	9
	2.4 Energy Storage System	9
	2.4.1 Battery Energy Storage System	10

2.4.2	Flywheel Energy Storage	11
2.4.3	Superconducting Magnetic Energy Storage (SMES)	11
2.4.4	Supercapacitors	11
2.5	Control and Communication System	11
2.6	Different Types of Load	12
2.7	Challenges in Microgrid Systems	12
2.8	Control Topologies in Microgrid System	12
2.8.1	Grid-Connected Mode	13
2.8.2	Stand-Alone Mode (Island Mode)	13
2.8.3	Battery Charging Mode	13
2.9	Microgrid Control for Islanded Operation	14
2.9.1	Microgrid Operation Based on Inverter Control Modes.	14
2.9.2	Microgrid Operation Based on the Conventional Synchronous Machine Control.	16
2.10	Maximum Power Point Tracking	17
2.11	Multilevel Inverter	22
2.12	Summary	22
CHAPTER 3	RESEARCH METHODOLOGY	23
3.1	Introduction	23
3.2	Modeling and Standalone microgrid System	24
3.2.1	Modeling of Multilevel Inverter for Standalone Microgrid System	25
3.2.2	Low Pass Filter Design	28
3.2.3	MATLAB Function Code for MPPT	29
3.2.4	Modeling of Battery Charging Unit for Auxiliary Power	30
3.3	Summary	31
CHAPTER 4	RESULTS AND DISCUSSION	33

4.1	Introduction	33
4.2	Results and Discussion	33
4.2.1	Case 1 Insolation and Temperature for the PV Array are Constant	34
4.2.1.1	Battery Charging at SOC 30%	37
4.2.2	Case 2 Insolation is Varying while Temperature is Constant for the PV Array	38
4.2.2.1	Battery Charging at SOC 50%	40
4.2.3	Case 3 Insolation is Varying while Temperature is Constant for the PV Array	41
4.2.3.1	Battery Charging at SOC 90%	43
4.2.4	THD Comparison	44
4.3	Summary	46
CHAPTER 5	CONCLUSION AND FUTURE OUTLOOKS	47
5.1	Conclusion	47
5.2	Future Outlooks	47
REFERENCES		49

LIST OF TABLES

TABLE NO.	TITLE	PAGE
Table 3.1	Switching Table	27
Table 4.1	MG parameters	35
Table 4.2	THD of the output voltage and current	44

LIST OF FIGURES

FIGURE NO.	TITLE	PAGE
Figure 2.1	A simple representation of a PV system	7
Figure 2.2	Fuel cell	8
Figure 2.3	A simple representation of wind energy generation system	9
Figure 2.4	MG architecture, comprising MS, loads, and control devices	14
Figure 2.5	PQ inverter control system.	15
Figure 2.6	Frequency vs active power droop	17
Figure 2.7	P-V curve with the variation of insolation at 298 Kelvin	18
Figure 2.8	I-V curve with a variation of insolation at 298 Kelvin	18
Figure 2.9	P-V curve with the variation of temperature at 1000 W/m ² insolation	19
Figure 2.10	I-V curve with a variation of temperature at 1000 W/m ² insolation	19
Figure 2.11	The operating principle of P&O MPPT	20
Figure 2.12	Flow chart for P&O MPPT	21
Figure 3.1	Research flowchart	23
Figure 3.2	Block diagram of the proposed model	24
Figure 3.3	Multilevel inverter with less number of switches [24]	25
Figure 3.4	Inverter switching and output voltage	27
Figure 3.5	Battery charging unit	31
Figure 4.1	Simulink model of standalone MG system with proposed control topology	34
Figure 4.2	Output voltages at different stages at constant insolation and constant temperature	36
Figure 4.3	Inverter output voltage at constant insolation and constant temperature	37
Figure 4.4	Battery charging voltage and current at 30% SOC	38
Figure 4.5	Constant temperature and variable insolation	38
Figure 4.6	DC output voltages at different stages at variable insolation and constant temperature	39

Figure 4.7	Output voltage of the inverter at variable insolation and constant temperature	40
Figure 4.8	Battery charging voltage and charging current at 50% SOC	41
Figure 4.9	Variable temperature and variable insolation for PV	41
Figure 4.10	DC output voltages at different stages at variable insolation as well as variable temperature	42
Figure 4.11	Output voltage of the inverter at variable insolation as well as variable temperature	43
Figure 4.12	Battery charging current at 90% of SOC	43
Figure 4.13	FFT analysis with the filter for the output voltage	44
Figure 4.14	FFT analysis with the filter for the output current	45
Figure 4.15	FFT analysis without the filter for the output voltage	45
Figure 4.16	FFT analysis without the filter for the output current	46

LIST OF ABBREVIATIONS

MG	–	Microgrid
DG	–	Distributed Generation
P	–	Active Power
Q	–	Reactive Power
PWM	–	Pulse Width Modulation
SPWM	–	Sinusoidal Pulse Width Modulation
IGBT	–	Insulated-Gate Bipolar Transistor
PV	–	Photovoltaic
THD	–	Total Harmonic Distortion
DG	–	Distributed Generation
P&O	–	Perturb & Observe
SMES	–	Superconducting Magnetic Energy Storage
FFT	–	Fast Fourier Transform
VSI	–	Voltage Source Inverter
CSI	–	Current Source Inverter
MPPT	–	Maximum Power Point
F_s	–	Sampling Frequency
F_c	–	Cutoff Frequency
ref	–	Reference Value
i	–	Current
v	–	Voltage
	–	
	–	

CHAPTER 1

INTRODUCTION

1.1 Background Study

Power is one of the most critical components for economic growth and welfare of the nations. Currently, the Malaysian power system is based on fossil fuel and fossil fuels have many disadvantages such as environmental pollution and global warming. The price of these fuels also increases day by day this is since we have a limited amount of fossil fuels and the energy requirement is increasing because of the modernization and development.

Nowadays, a large part of the world population lives without access to electricity. According to the report of the IEA (International Energy Agency), 1.3 billion people still have no access to electricity [1]. This lack of access to energy is because a large proportion of the population in developing countries lives in rural areas far from the main grid.

The solution to these problems is to shift from conventional power to renewable power. Renewable energy is clean and freely available, except for the cost of the system used to convert this energy into electrical energy. Nowadays people are turning towards the concept of microgrid. A microgrid is a small energy system which consists of different combinations of energy sources such as wind/solar, wind/solar/hydro, hydro/solar/biomass etc. The combination of the energy sources depends upon the location of the microgrid system that is on the availability of the different types of the resources on the particular location. Since ample amount of solar energy is available almost everywhere in Malaysia throughout the year, therefore, it is beneficial to use solar energy as one of the energy sources for the energy systems in Malaysia.

A microgrid system is basically a small power grid, which can operate independently, as well as with the main power grid. Various sources of energy such as solar, wind, geothermal, hydro, biomass are used to feed the power to the load by using suitable energy converters, inverters, and controllers. It makes it possible to generate local power for local loads. It comprises several small sources of power that makes it extremely flexible and efficient. Enables grid upgrading, improves the integration of renewable and distributed sources of energy to the main grid.

When we deal with renewable energy sources, there are always the issues of harmonics and power fluctuations. Harmonics is because of the power electronic converters and power fluctuations is because of the variation in the renewable power. For example, in the case of solar PV the intensity of the solar radiation striking on the PV panels changes with the position of the sun and this radiation also depends on the weather conditions.

The purpose of this study is to develop a standalone microgrid system for a green building by using solar PV as the energy source and multilevel inverter with smaller number of switches. A PWM multilevel inverter is used to reduce the THD in the load voltage as well as in the load current. This chapter describes the problem statement, the objective of this project and the significance of this study.

1.2 Problem Statement

When we deal with a system in which power source is DC such as photovoltaic (PV) and the load requires AC power, then DC to AC conversion is required. There are harmonics in the output voltage and current at the AC side. These harmonics in the load voltage and load current can be reduced by using various techniques such as a PWM inverter with low pass filter or by using a multilevel inverter with low pass filter. In both the cases we can also use active filters, but the designing of the active filters is more difficult than passive filters. The size of the passive filters is large in the case of PWM inverter, but the size of the filters is smaller in the case of multilevel PWM inverters. As the number of output voltage levels increases the size of the filter

decreases. This is due to the fact, that as the number of levels is increased the output voltage of the multilevel inverter looks more sinusoidal. In a standalone microgrid system, the voltage and frequency of the system need to be controlled to a predefined value, which is suitable for the load.

1.3 Objective

The objectives of this research work are:

- (a) To develop a small microgrid system for a green building by using PV as the power source using MATLAB/Simulink.
- (b) To improve the power quality by using a multilevel inverter with less number of power switches along with a passive low pass filter.
- (c) To design a control scheme which produces a constant 240 Volts, 50 Hz inverter output voltage irrespective of any change at the PV side.

1.4 Scope

This project is totally based on simulation, with no actual hardware implementation. This work covers the design of a microgrid system for green buildings with an SPWM multilevel inverter. In addition, of the use of the SPWM multilevel inverter a perturb and observe (P&O) maximum power point tracking (MPPT) algorithm is used for the PV array and a control circuit is used to control the output voltage of the inverter to a constant value of 240 Volts at 50 Hz irrespective of the changes on the PV side. In this project, the effects of partial shading and load variation are not considered.

1.5 Contributions of Research Work

The most important contributions to this research work are as follows:

1. A microgrid system for green building has been developed.
2. The performance evaluation of the proposed system has been carried out under different conditions for the PV such as constant insolation and constant temperature, varying insolation and constant temperature, varying insolation as well as varying temperature.
3. An SPWM multilevel inverter is used to reduce the THD in the load voltage and load current. A battery-charging unit is also included in the system to charge an electric vehicle at a constant current.

The outcome of this research shows the effectiveness of the SPWM inverter in the reduction of the THD in the load voltage as well as in the load current and the effectiveness of the buck converter, which keeps the inverter output voltage constant regardless of the changes on the PV side.

1.6 Report Organization

There are five chapters in this report. Chapter 1 includes the discussion of the microgrid systems, problem statement, objective, scope, and significance of this project. Chapter 2 includes a literature review of the microgrid system, solar PV and how the magnitude and frequency of the voltage of the microgrid systems can be controlled in standalone mode. Chapter 3 will discuss the methodology of the project. Chapter 4 will discuss the simulation and results. Chapter 5 will provide the conclusion of this project and some recommendations for future work.

REFERENCES

1. Baudoin, S., I. Vechiu, and H. Camblong. A review of voltage and frequency control strategies for islanded microgrid. in System theory, control and computing (ICSTCC), 2012 16th international conference on. 2012. IEEE.
2. H. J. Liu, K. J. Li, H. X. Gao, Y. Sun, K. Q. Sun, and W. J. Lee, "Control and simulation of grid-connected microgrid," IEEE Power Energy Soc. Gen. Meet., pp. 1–6, 2012.
3. A. R. Natsheh, E. M. Natsheh, and A. Albarbar, "Intelligent controller for managing power flow within standalone hybrid power systems," IET Sci. Meas. Technol., vol. 7, no. 4, pp. 191–200, 2013.
4. Y. Li, Q. Xu, T. Lin, J. Hu, Z. He, and R. Mai, "Analysis and design of load-independent output current or output voltage of a three-coil wireless power transfer system," IEEE Trans. Transp. Electrification, vol. 4, no. 2, pp. 364–375, 2018.
5. R. Shalchi Alishah, D. Nazarpour, S. H. Hosseini, and M. Sabahi, "Reduction of power electronic elements in multilevel converters using a new cascade structure," IEEE Trans. Ind. Electron., vol. 62, no. 1, pp. 256–259, 2015.
6. M. A. Laughton, "Fuel cells," in Engineering Science and Education Journal, vol. 11, no. 1, pp. 7-16, Feb. 2002.
7. A. Henry and E. Janzén, "Titanium related luminescence in SiC," Superlattices Microstruct., vol. 40, no. 4–6 SPEC. ISS., pp. 328–331, 2006.
8. A. López-González, B. Domenech, D. Gómez-Hernández, and L. Ferrer-Martí, "Renewable microgrid projects for autonomous small-scale electrification in Andean countries," Renew. Sustain. Energy Rev., vol. 79, no. May, pp. 1255–1265, 2017.
9. H. Kuang, S. Li, and Z. Wu, "Discussion on advantages and disadvantages of distributed generation connected to the grid," 2011 Int. Conf. Electr. Control Eng. ICECE 2011 - Proc., pp. 170–173, 2011.

10. H. Jiayi, J. Chuanwen, and X. Rong, "A review on distributed energy resources and MicroGrid," *Renew. Sustain. Energy Rev.*, vol. 12, no. 9, pp. 2465–2476, 2008.
11. V. A. Boicea, "Energy Storage Technologies: The Past and the Present," in *Proceedings of the IEEE*, vol. 102, no. 11, pp. 1777-1794, Nov. 2014.
12. M. Faisal, M. A. Hannan, P. J. Ker, A. Hussain, M. B. Mansor and F. Blaabjerg, "Review of Energy Storage System Technologies in Microgrid Applications: Issues and Challenges," in *IEEE Access*, vol. 6, pp. 35143-35164, 2018.
13. E. Unamuno and J. A. Barrena, "Hybrid ac/dc microgrids - Part I: Review and classification of topologies," *Renew. Sustain. Energy Rev.*, vol. 52, pp. 1251–1259, 2015.
14. J. A. P. Lopes, C. L. Moreira, and A. G. Madureira, "Defining control strategies for microgrids islanded operation," *IEEE Trans. Power Syst.*, vol. 21, no. 2, pp. 916–924, 2006.
15. H. Ibrahim and N. Anani, "Variations of PV module parameters with irradiance and temperature," *Energy Procedia*, vol. 134, pp. 276–285, 2017.
16. M. S. Mahmoud, F. M. A.L.-Sunni, and M. Saif Ur Rahman, "Review of microgrid architectures – a system of systems perspective," *IET Renew. Power Gener.*, vol. 9, no. 8, pp. 1064–1078, 2015.
17. J. A. P. Lopes et al., "Control strategies for microgrids emergency operation," in *2005 International Conference on Future Power Systems*, 2005.
18. P. V. Joshi and S. S. Dhamal, "Study of different converter topologies for interconnecting microgrid with utility grid," *2015 Int. Conf. Control Instrum. Commun. Comput. Technol. ICCICCT 2015*, pp. 731–734, 2016.
19. M. N. Ambia, A. Al-Durra, C. Caruana, and S. Muyeen, "Islanding Operation of Hybrid microgrid System with Power Management Control Scheme," *Power Energy Syst.*, no. August, 2012.
20. Kumar, N., et al., Framework of maximum power extraction from solar PV panel using self predictive perturb and observe algorithm. *IEEE Transactions on Sustainable Energy*, 2018. 9(2): p. 895-903.

21. Ahmed, J. and Z. Salam, A modified P&O maximum power point tracking method with reduced steady-state oscillation and improved tracking efficiency. *IEEE Transactions on Sustainable Energy*, 2016. 7(4): p. 1506-1515.
22. N. Femia, G. Petrone, G. Spagnuolo, and M. Vitelli, "Optimizing sampling rate of Perturb and Observe MPPT technique," *Power Electron. Spec. Conf. 2004. PESC 04. 2004 IEEE 35th Annu.*, vol. 3, p. 1945–1949 Vol.3, 2004.
23. T. Ackermann, "Distributed generation- a definition .pdf," vol. 57, pp. 195–204, 2001.
24. R. S. Alishah, D. Nazarpour, S. H. Hosseini, and M. Sabahi, "Novel multilevel inverter topologies for medium and high-voltage applications with lower values of blocked voltage by switches," *Iet Power Electron.*, 2014.
25. Lasseter, R.H. Microgrids. in *Power Engineering Society Winter Meeting, 2002. IEEE. 2002. IEEE.*
26. M. Tarafdar Hagh, F. Najaty Mazgar, S. Roozbehani, and A. Jalilian, "THD minimisation of multilevel inverter with optimised dc sources magnitude and switching angles," *CIREN - Open Access Proc. J.*, vol. 2017, no. 1, pp. 875–878, 2017.
27. Karasani, R.R., et al., A three-phase hybrid cascaded modular multilevel inverter for renewable energy environment. *IEEE Transactions on Power Electronics*, 2017. 32(2): p. 1070-1087.
28. Natsheh, E.M., A.R. Natsheh, and A. Albarbar, Intelligent controller for managing power flow within standalone hybrid power systems. *IET Science, Measurement & Technology*, 2013. 7(4): p. 191-200.
29. Subudhi, B. and R. Pradhan, A comparative study on maximum power point tracking techniques for photovoltaic power systems. *IEEE Transactions on sustainable energy*, 2013. 4(1): p. 89-98.
30. B. Khan, *Non-conventional energy resources: Tata McGraw-Hill Education, 2006.*
31. E. Unamuno and J. A. Barrena, "Hybrid ac/dc microgrids—Part I: Review and classification of topologies," *Renewable and Sustainable Energy Reviews*, vol. 52, pp. 1251-1259, 12// 2015.

32. M. S. Mahmoud, M. S. U. Rahman, and M.-S. Fouad, "Review of microgrid architectures—a system of systems perspective," *IET Renewable Power Generation*, vol. 9, pp. 1064-1078, 2015.
33. Lidula, N. and A. Rajapakse, Microgrids research: A review of experimental microgrids and test systems. *Renewable and Sustainable Energy Reviews*, 2011. 15(1): p. 186-202.
34. Ackermann, T., G. Andersson, and L. Söder, Distributed generation: a definition1. *Electric power systems research*, 2001. 57(3): p. 195-204.
35. Kuang, H., S. Li, and Z. Wu. Discussion on advantages and disadvantages of distributed generation connected to the grid. in *Electrical and Control Engineering (ICECE), 2011 International Conference on*. 2011. IEEE.
36. Ibrahim, H. and N. Anani, Variations of PV module parameters with irradiance and temperature. *Energy Procedia*, 2017. 134: p. 276-285.
37. Parida, B., S. Iniyar, and R. Goic, A review of solar photovoltaic technologies. *Renewable and sustainable energy reviews*, 2011. 15(3): p. 1625-1636.
38. Kirubakaran, A., S. Jain, and R. Nema, A review on fuel cell technologies and power electronic interface. *Renewable and Sustainable Energy Reviews*, 2009. 13(9): p. 2430-2440.
39. Herbert, G.J., et al., A review of wind energy technologies. *Renewable and sustainable energy Reviews*, 2007. 11(6): p. 1117-1145.
40. Tummala, A., et al., A review on small scale wind turbines. *Renewable and Sustainable Energy Reviews*, 2016. 56: p. 1351-1371.
41. Guney, M.S. and Y. Tepe, Classification and assessment of energy storage systems. *Renewable and Sustainable Energy Reviews*, 2017. 75: p. 1187-1197.
42. Ibrahim, H., A. Ilinca, and J. Perron, Energy storage systems—characteristics and comparisons. *Renewable and sustainable energy reviews*, 2008. 12(5): p. 1221-1250.
43. Brearley, B.J. and R.R. Prabu, A review on issues and approaches for microgrid protection. *Renewable and Sustainable Energy Reviews*, 2017. 67: p. 988-997.

44. Wang, B., M. Sun, and B. Dong. The existed problems and possible solutions of distributed generation microgrid operation. in Power and Energy Engineering Conference (APPEEC), 2011 Asia-Pacific. 2011. IEEE.
45. Vandoorn, T.L., et al., Analogy between conventional grid control and islanded microgrid control based on a global DC-link voltage droop. IEEE Transactions on Power Delivery, 2012. 27(3): p. 1405-1414.
46. Lopes, J.P., C. Moreira, and A. Madureira, Defining control strategies for microgrids islanded operation. IEEE Transactions on power systems, 2006. 21(2): p. 916-924.
47. Yazdanian, M. and A. Mehrizi-Sani, Distributed control techniques in microgrids. IEEE Transactions on Smart Grid, 2014. 5(6): p. 2901-2909.
48. Subudhi, B. and R. Pradhan, A comparative study on maximum power point tracking techniques for photovoltaic power systems. IEEE Transactions on sustainable energy, 2013. 4(1): p. 89-98.
49. Hsieh, C.-H., et al., Design and implementation of a novel multilevel dc-ac inverter. IEEE Transactions on Industry Applications, 2016. 52(3): p. 2436-2443.